# **Evidence of performance**

## Airbourne sound insulation of building elements

Test report 161 36711/Z1e\*)


\*) This is a translation of the test report No. 161 36711/Z1 dated 12. November 2008



Basis

EN ISO 140-1:1997+A1:2004 EN 20140-3:1995+A1:2004 EN ISO 717-1: 1996+A1:2006

Representation



Instructions for use

This test report may be used to classify the sound insulation of building elements.

For germany DIN 4109:1989-11

- $R_w$  is equivalent to  $R_{w,P}$ ,  $R_{w,R} = R_{w,P} - 2 dB$
- Rw.R for "Bauregelliste"

#### Validity

The data and results given relate solely to the described, tested object.

Testing for sound insulation does not allow any statement to be made on further characteristics of the present structure which could define performance and quality.

### Notes on publication

The ift notice "Conditions and notes for the use of ift test documents" applies.

The cover sheet can be used as a summary.

## Contents

The report comprises a total of 8 pages

- Object
- Procedure
- 3 Detailed results
- Instruction for use Data sheet (1 page)

Client

Ege Profil Tic. ve San. A.S. Atatürk Org. Sanayi Bölgesi

10003 Sokak No: 5

Cigli/Izmir Turkey

Product	Single window, one leaf
Product designa- tion	Everest Max
Size (W x H)	1230 mm x 1480 mm
Material	Plastic (PVC-U) with reinforcement, white
Opening	Tilt and turn
Rebate sealings	2 sealants
Filling	Insulating glass unit, 4 / 16 / 4
Special features	-/-

Weighted sound reduction index R<sub>w</sub> Spectrum adaptation terms C and C<sub>tr</sub>



 $R_w(C; C_{tr}) = 33 (-1; -4) dB$ 

ift Rosenheim 12. November 2008

Dr. Machim Hessinger, Diel.-Phys. Head of Testing Department ift Centre for Acoustics

Bernd Saß, Dipl.-Ing. (FH) Assistant Head of Testing Department ift Centre for Acoustics