

อุปกรณ์แจ้งเหตุเพลิงไหม้

FIRE ALARM EQUIPMENT

“CM” รุ่น: CM-808 เครื่องตรวจจับก๊าซรั่ว

“CM” Model: CM-808 Gas Leak Detector



Approval: CE RoHS

รายละเอียดผลิตภัณฑ์

- การตรวจจับก๊าซรั่ว 2 ประเภท: สามารถตรวจจับก๊าซ LPG (ก๊าซปิโตรเลียมเหลว) และ LNG (ก๊าซธรรมชาติ/มีเทน) ได้
- ระบบแจ้งเตือน 2 รูปแบบ: มีทั้งเสียงข้อความพูด (Voice Message) และเสียงบี๊บเซอร์ในตัว ซึ่งจะแจ้งเตือนอย่างดังเมื่อเกิดสัญญาณเตือน
- ระบบทดสอบอัตโนมัติ 2 ฟังก์ชัน: ตรวจสอบความขัดข้องของเซนเซอร์อัตโนมัติ และมีปุ่มทดสอบการทำงานด้วยตนเองที่ใช้งานง่าย
- การใช้งานได้ 2 รูปแบบ: ใช้งานแบบเดี่ยว (Standalone) สำหรับที่อยู่อาศัย หรือสามารถต่อสายเข้าสู่ตัวควบคุมเพื่อใช้งานในระบบมอนิเตอร์ส่วนกลาง
- ไฟแสดงสถานะ 3 สี: ใช้งานง่าย และสามารถแยกสถานะ Alarm / Fault / Normal ได้ทันที
- ความไวสูง: เครื่องตรวจจับก๊าซไวไฟอัจฉริยะ พร้อมชุดควบคุมไมโครโปรเซสเซอร์ในตัว

A FIRE PLUS

จำหน่ายสินค้าประเภทงานดับเพลิงทุกชนิด

© COPYRIGHT ALL RIGHTS RESERVED. WWW.AFIRE.CO.TH

PRODUCT DATA SHEET | PRODUCT SPECIFICATION

อุปกรณ์แจ้งเหตุเพลิงไหม้

FIRE ALARM EQUIPMENT

“CM” รุ่น: CM-808 เครื่องตรวจจับก๊าซรั่ว

“CM” Model: CM-808 Gas Leak Detector

Operation

MODEL	CM-808P (Wall Type)	CM-808C (Ceiling Type)
Power Supply	Plug Type	Cable Type
Power ON	Green LED is ON with voice-warning message.	
Stand by	Green LED is ON	
Alarm Indication	Green LED is ON & Red LED is Flashing Continue Di-Di sound with voice-warning message	
Signal output	Relay output: Green: NC / White: NO / Blue: COM	
Installing Location	Semi-diameter to gas source < 1.5m	
	1. LPG : height from floor 0.3 ~ 1.0m	
	2. LNG : height from ceiling 0.3 ~ 1.0m	

คุณสมบัติผลิตภัณฑ์

Sensor	Semiconductor	Alarm Density	2500PPM (±1500PPM)
Initial Stabilizaation	Within 3 minutes	Operating Temperature	0°C ~ 50-°C
Operating Voltage	AC 90V ~ 240V, 50- 60Hz	Humidity Range	10% ~ 95%
Dimension	H112xW73xD42 mm	Sound Output	85dB/1M
Indicating Light	Red: Alarm / Orange: Fault / Green: Normal		
Remarks	1. This is a Combustible Gas Detector, cannot detect the poisonous gas such as CO. 2. Do not use the detergent to clean the gas detector. It will be damaged. 3. Do not spray on the gas detector, such as air freshener and hair spray ... ,etc.		