

# CTW

บริษัท ซีที อิเลคทริค ซัพพลาย จำกัด

CT ELECTRIC SUPPLY CO., LTD.


โทร : 02 550 9555

## BUILDING WIRE AND LOW VOLTAGE POWER CABLE

CHAROONG THAI WIRE & CABLE  
PUBLIC COMPANY LIMITED

CTW

บริษัท จรุ่งไทยไวน์ด์เคเบิล จำกัด (มหาชน)





# ISO 9001

To be confident  
in our international standard



# COMPANY PROFILE:

Charoong Thai Wire & Cable Public Company Limited (CTW) is one of the largest manufacturers of The Electric Wire & Cable and Telecommunication Cables in Thailand. The company established since 1967, and had experience in developing high quality wire & cable products to Thailand market



The company had obtained the board of investment of Thailand (BOI) privileges to manufacturing and marketing Aluminium and Copper wires and cable for various of The Electricity Authorities in the country.

Under carefully control of its operation and expansion scheme, the company had gone through its time after time development in machineries and productions to meet all the customer's requirement. All functions including product development and total quality control have been emphasized to deliver high quality products to the market.

The company registered as a listed company and shares has been traded at the Securities Exchanges of Thailand (SET) in 1976. In connection to over all improvement in production capacity, quality and financial status, the company gradually increased its capital investment from Baht 10 million to 21,42,150,410 and eventually CTW has grown from strength to strength and increased its registered to 1,999,280,350 Baht in 2015 with a staff of nearly 510 employees

In 1977, the company began to install machineries to manufacture telephone cable and in order to meet the rapidly increasing demand and in advanced

technology requirement, then highly skill and sophisticated technologies were to implemented. The company went into Technical Collaboration with the Showa Electric Wire & Cable Co.,Ltd. Of Japan during 1982-1987 and Fujikura Ltd. of Japan since 1992. And also the new plant at Bangnarmprueo District, Chachoengsao Province had been set up to increase capacity of wire and cable products and also to produce the new line of product. The plant incorporates the latest technology and highest quality control standards throughout the production process. At present, bringing CTW to new technical, is its The Catenary Continuous Vulcanisation (CCV) Line for producing the Medium - High voltage power cables with most modern High Voltage Testing lab, the company went into Technical Collaboration with the Fujikura Ltd. of Japan since 1992. The other facility can also produce low voltage power cables, internal and external telecommunication cables, and aluminium cables.

The Company strictly applies the TQC (Total Quality Control) System in every production section, using advanced precision instruments. Production quality is tested at every stage of production process, and monitor again when the product is finished, to assure compliance with all international standard. i.e., TIS, IEC, ASTM, BS, DIN, VDE, UL, JIS, AS/NZS, ICEA, FAA etc. at the request of the customers, CTW has adopted ISO 9001 to ensure its business and operations management are in line with recognized global standards. We finally gain confidence and good reputation from our customers; EGAT, MEA, PEA, TOT CAT, NBIA, The Construction Company and many othe



## **Product Line:**

The plant incorporates the latest technology and highest quality control standards throughout the production process. At present,

1. Aluminium cable plant.
2. Low voltage power cable plant.
3. High voltage power cable plant.
4. Telecommunication cable plant.

## **Our value customers:**

CTW is upgrading the products operations through research, advanced technology and machinery, to serve the expanding needs of Thailand's economy at competitive prices. The company is committed to offer high quality products to achieve customer satisfaction. The company is trusted to supply wire and cable to various reputable firms and local state enterprises.

## **Production Capacity:**

1. Aluminium weights of Aluminium wire & cable product (A) 1,200 MTS / Month.
2. Copper weights of Low voltage wire & cable products (C) 600 MTS / Month.
3. Copper weights of High voltage wire & cable products (K) 400 MTS / Month.
4. Lengths of Telecommunication cable products (T) 120,000 Pairs-Km / Month

**EGAT :** Electricity Generating Authority of Thailand  
**PEA :** Provincial Electricity Authority  
**MEA :** Metropolitan Electricity Authority  
**TOT :** TOT Corporation Public Company Limited  
**CAT :** CAT Telecom Public Company Limited  
**NBIA :** New Bangkok International Airport  
**Export :** CTW has been exporting its quality cable to ASEAN region, Specifically Singapore, Indonesia, Philippines and Indochina for many year. etc.

## **Quality Policy & Assurance:**

### **"CUSTOMER SATISFACTION AND CONTINUALLY IMPROVEMENT"**

CTW follows continuous and strict procedures throughout every production process. Our quality control begins with the careful scrutinisation of product designs, raw materials and continues to the testing of final products; where every finished length of cable must also pass rigorous test to meet required specifications before it is shipped to our customers.



**Certification Awarded :**

CTW is recognized as the premier electric wire and cables manufactures that achieved both local and international standard.

\*The Thai industrial Standard Institute (TISI), Ministry of Industry has award its "Standard Mark"




**TIS 11-2553**  
**TIS 293-2541**



**TIS 64-2517**  
**TIS 85-2548**  
**TIS 118-2522**  
**TIS-838-2531**

\*\* ISO 9001 (Quality Management System Certification)  
- In order to improve the effectiveness of the quality management system and enhance customer satisfaction be meeting customer requirement.

- The plant is certified for the scope: Design and development and manufacture of electric wire/cablecable and telephone wire/cable.



**Local accreditation : Approval by**  
Management System Certification  
(Thailand) (MASCI)




**1**

**ALUMINIUM WIRE AND CABLE**  
THWA, AAC, ACSR, etc.



**2**

**BUILDING WIRE AND LOW VOLTAGE POWER CABLES**  
THW, VAF, VCT, NYY, CV, etc.



**3**

**MEDIUM AND HIGH VOLTAGE POWER CABLES**  
24 KV-115 KV  
Maximum Diameter 1,200 sq.mm.  
PIC, SAC, CV, etc.



**4**

**FIRE RESISTANCE AND FLAME RETARDANT CABLES**  
FRC, LSF, etc.



**5**

**TELECOMMUNICATION CABLES**  
AP, AP-8, AP-FSF, TPEV, TIEV, etc.



**6**

**CONTROL AND INSTRUMENT CABLES**  
CVV, NYCY, RE-Y, etc.

CT ELECTRIC SUPPLY CO., LTD.

: 02-509555

CTW


CHAROONG THAI WIRE & CABLE  
PUBLIC COMPANY LIMITED

# WE BRING THE POWER TO YOU



Power Plant

Arial Transmission  
230 kV.



Step-Up Transmission  
Substation

บริษัท ชีวี่ อิเลคทริค ซัพพลาย จำกัด

CT ELECTRIC SUPPLY CO., LTD.

โทร : 02 550 9555





Factory



Transportation





**Business & Commercial**

## Real Estate & Property and Highlight Building.

- ณูศากิริ เอกมัย
- Holiday Inn Phuket
- S&S Condo สุขุมวิท 101
- ชีวาทัย
- The Sixsence Hotel Phuket
- Casa เฟส1 & เฟส2
- พัทยา บีช Pattaya Beach Hotel
- Tuntect Factory
- Parkland [ ศรีนคินทร์, วงศ์สว่าง, เพชรบุรี ฯลฯ ]
- หอสมุดแห่งชาติ
- Marriot Rayong
- Thai Farmer Bank  
( Computer Center )
- Bank of Ayudthaya  
( Computer Center )
- คาชาลูนา ชลบุรี
- คอนโด Bridge สาทร-นราธิวาส
- โรงแรมแขวงการีล่า เชียงใหม่
- The Pano Rama 3
- The Plaza Athenee
- นอร์ท ปาร์ค
- Le Raffine Condo Sukhumvit 32
- Beer Thai Factory Plant  
( Carlberg beer )
- Ao Po bay Marina
- S9 Condo บางใหญ่-รัตนเอเช็น
- We Condo
- Chapter one Condo
- The NYE ตากสิน-วงเวียนใหญ่
- The Reserve
- D Condo [ ระยอง, เอแบค บางนา ฯลฯ ]
- The Aspire [ งามวงศ์วาน, สุขุมวิท 48 ฯลฯ ]
- Box Hotel สุขุมวิท 31
- พัทยา พอร์ช อ.บางละมุง
- Centrio Condo Phuket
- Delong บ่อavin
- บ้านกลางเมือง บางบอน
- ไชนิส นางริ้นจี่
- โชว์รูม ชูชูกิ บางนา
- The Key ประชาชื่น & แจ้งวัฒนา
- โครงการอโวร่า 31
- WHIZDOM 2 อาคาร 2
- ทรอ ทองหล่อ คอนโด
- ไชนิส สุขุมวิท 31 & สุขุมวิท 39
- M Sathon
- Thai Farmer Bank
- โครงการแสนสิริ บางนา
- Amway Ramkhamhaeng
- The Metro Rattanathibet
- The NYN Pattaya
- Elio สุขุมวิท 64
- แสนสิริ บางนา
- นิชาดาเรนี
- I-Condo งามวงศ์วาน
- โรงงานถ้าแก่น้อย นพวงศ์
- WHA factory (M7 WHA MEGA)
- โรงงาน KCE ลาดกระบัง
- Unilever บางนาเบรี้ยว
- CP Morokot solar roof ชุมพร
- Perfect ราชพฤกษ์
- The ASCENT เอกมัย 19
- Tsix 5 Hotel Pattaya-Nua
- HST บางนา กม.7
- บ้านแสนดาว เข้าใหญ่
- โครงการเรืองปัญญา
- The PLUM บางใหญ่
- TE นิคมเกตเวย์ ฉะเชิงเทรา
- THE MATRIX CONDOMINIUM
- THE EDITOR
- AMRA BANGKOK HOTEL
- HONDA 304
- เทียนทริค ติวนันท์
- IDEO สาทร-ท่าพระ
- อโศก คอร์ท
- THE TRUST RESIDENCE
- Water Fall
- Holiday Inn
- Bayan Tree Resort and Spa (Samui)
- Metro Condominium
- Sathorn Heritage
- Bangkok Insurance Tower  
(ตึกกรุงเทพประกันภัย สาทร)
- Italian Thai Tower (อาคารอิตาเลี่ยนไทย)
- Retchada Square
- FMC Plant นิคมเหมราช
- The Legacy Golf
- THE SERIES อุดมสุข
- Chidlom Tunnel
- BMA Flood Protection Tunnel
- ENCO
- Studio - One
- Resota
- The Renaisenco Hotel Phuket
- CP Orange Muangthong Base
- อัมตตรา พัทยา
- Sky Walk สุขุมวิท
- Star View Condo
- Grand Four Wing
- อมารี [ หัวหิน, พัทยา, Bangkok Hotel ฯลฯ ]
- ลุมพินี Lumpini  
[ จอมเทียนเพส 1 & 2, นาเกลือ, พัฒนาการ, พระราม 9, อ่อนนุช 46, อ่อนนุช 55, รามอินทรา กม.2, รามอินทรา กม.8, สุขสวัสดิ์, สุขุมวิท 24, พระราม 3, ลาดปลาเค้า, เมกะบางนา, พัทยาเหนือ ฯลฯ ]

บริษัทฯ ขอแสดงความยินดี  
CT ELECTRIC SUPPLY LTD. : 02 550 9555



# Department Store & Shopping Mall



- สหไทย พลาซ่า (สุราษฎร์)
- จำจูรี สแควร์
- พาราไดซ์ (เสรีเอ็นเตอร์)
- CDS หาดใหญ่
- Siam Square One
- MEGA Bangna
- Terminal 21
- ตั้งชั่วເຕັ້ງ ຢນບູຮີ
- Sukhumvit City Tower (The Empodium Dep.)
- Homepro หาดใหญ่
- Makro [กัลปพฤกษ์, สุราษฎร์ฯ]
- ไวนส์ดู [นวมินทร์, วังน้อย ฯ]

- Robinson  
[ตรัง, ร้อยเอ็ด, ฉะเชิงเทรา, ปราจีนฯ, สุพรรณบุรี, ศรีราชา ฯ]
- Central World
- Central [ ชลบุรี, ระยอง ]
- Central [ สีลม & วังบูรพา (Renovatc) ]
- Central ลาดพร้าว
- Carrefour [ เชียงใหม่, พระราม 4, ราชภัฏบูรณะ, อุดมสุข ]
- Big C [ ราชดำเนิน, น่าน1, น่าน3, หัวหมาก, หาดใหญ่, มุกดาหาร ฯ ]
- Tesco Lotus [ ก้าแพงเพชร, บ่ออวน, กระทุมແບນ, กาฬสินธุ์,  
เชียงใหม่ 1, เชียงใหม่ 2, ระยอง, แกลง, ภูเก็ต, เวียงสา  
สุราษฎร์ธานี, บางเลน, คลองหลวง, نان, สุขุมวิท, บ้านบึง ฯ ]

บริษัท อิเลคทริก พาวเวอร์ กรุ๊ป

CT ELECTRIC SUPPLY CO., LTD.

โทร : 02 550 9555

## Oil & Gas , Industrial and Power Generative Plant

- Electricity Generating Authority of Thailand (EGAT)
- Provincial Electricity Authorization (PEA)
- Metropolitan Electricity Authorization (MEA)
- Communication Authority of Thailand (CAT)
- TOT Public Company Limited (TOT)
- TT&T Public Company Limited (TT&T)
- โรงไฟฟ้า GLOW 5 (Combined Cycle)
- โรงไฟฟ้า Gulf 7 Substation  
[ GCRN, GNK2, GKP1, GKP2, GTLC, GNNK and GNLL Power-  
Plant]
- โรงไฟฟ้านอม
- อาคารวิจัย PTT วังน้อย
- Nam Thuen Power Plant
- โรงไฟฟ้าพรมนครเหนือ Phase II
- Transmission System Expansion Project No.II
- CHANA Combined Cycle Power Plant (Block2)
- Rayong Olefine Cracker [ เครื่อง SCG ]
- โรงปูน ตราราชสีห์ [บ.ภูมิใจไทยซีเมนต์]
- Siam City Cement PLC. (ปูนตราชก้อนทรีย์)
- Butterworth Penang

- Central Sub. [ PTT ]
- GAS Separation Plant 6 (GSP6) [ PTT ]
- Ethane Separation Plant 3 (ESP3) [ PTT ]
- Oil Tank [ Thai Oil ]
- PTT : Fire Alarm System
- North Bangkok Plant (GAS Pipeline Project)
- Oil Tank [ ESSO ]
- Rocs#1 [ PTT ]
- Siam City Cement Plant (K6)
- EGAT office Building
- PTT (Sriracha , Mapraput)



# Mega Project & Public Utility

- ศูนย์ราชการพม่า (กรุงเนปิดอว์)
- ศูนย์ราชการแจ้งวัฒนะ (สัญญา 1-5 )
- ศาลาปกครองแจ้งวัฒนะ
- Suwanaphumi Airport
  - [ Air Field Pavement , Passenger Terminal (NBIA) , Duck Bank (HV.), Airport Lighting 5 kV., Distribution Line, Land Side Road , Cattering (NBIA) , etc. ]
- MRT Purple Line [ Contract 1,2,3,4 ]
- MRT Blue Line [ Contract 1,2,3,4 ]
- BTS (Taksin-Petchkasem)
- BTS Extension Onnut-Bearing
- SRT Double Track (รฟท.)
  - [ ST3 , ST4 , Track Rehcp , etc. ]
- BTS (Depot Morchit)
- MRTA Subway Train (Metro Mall)
- Office Building MRTA (อาคาร รฟม.)
- Airport Rail Link (Signalling System)
- สำนักงานปลัดฯ ศรีสมาน
- ประจำมหาสวัสดิ์
- กองทัพเรือพวนนก
- Lamchabang Deep See Port [ A1 , A2 , C0 , A3 ]
- ฐานทัพเรือสตทบ
- สะพานข้ามแม่น้ำโขง (นครพนม)
- หอสมุดแห่งชาติ



- Toll Way Phase II
- Expressway (Bangna-Bangprakong)
- Asian Games Sport Complex (Rangsit)
- Government Housing Authority of Thailand
  - [ Hnongjok , Bang Khun-Tien , Taladthai , Navanakorn , บ้านคลองสวน , ดีศรีราษฎร์ , Suan Pul , Ban Klong Suan , 12 Project Bann-uar-ar-thorn (ITD) , etc. ]
- งานพืชสวนโลกเฉลิมพระเกียรติ ๑ ราชพุทธ ๒๕๔๙

บริษัท ซีที อิเลคทริก สพล. จำกัด  
CT ELECTRIC SUPPLY CO., LTD.

## OUR VALUED CUSTOMERS

Line : 02 550 9555

Department Store



## Goverment & State Enterprise Project



## High-Rise Building Project



## Industrial Project



## Telecommunication



# CONTENT

PAGE	BUILDING WIRE & LOW VOLTAGE POWER CABLE	CABLE TYPE	STANDARD	CABLE NAME	APPLICATION
12		CTW-CSC (HD)	TIS 64-2517	Bare cooper standard conductor. (Hard Drawn: HD)	Aerial power transmission and overhead distribution line.
13		CTW-CSC (SD)	TIS 11-2553 ASTM B3 & B8	Bare anneal copper stranded conductor. (Soft Drawn : SD)	The cable suitable for conductor insulated
14		CTW-60227 IEC 01	TIS 11-2553 Part 3 Table 1	450/750 V 70°C PVC insulated, Single core.	Building wiring for installation in wire way or raceway, dry location. Do not install in conduit and direct burial in ground.
16		CTW-60227 IEC 02	TIS 11-2553 Part 3 Table 3	400/750 V 70°C PVC insulated, Flexible single core.	Building wiring for installation in wire way or raceway, dry location. Do not install in conduit and direct burial in ground.
17		CTW-60227 IEC 05	TIS 11-2553 Part 3 Table 5	300/500 V 70°C PVC insulated, Single core.	Building wiring for installation in wire way or raceway, dry location. Do not install in conduit and direct burial in ground.
18		CTW-60227 IEC 06	TIS 11-2553 Part 3 Table 7	300/500 V 70°C PVC insulated, Flexible single core.	Building wiring for installation in wire way or raceway, dry location. Do not install in conduit and direct burial in ground.
19		CTW-60227 IEC 07	TIS 11-2553 Part 3 Table 9	300/500 V 90°C PVC insulated, Single core.	Building wiring for installation in wire way or raceway, dry location. Do not install in conduit and direct burial in ground.
20		CTW-60227 IEC 08	TIS 11-2553 Part 3 Table 11	300/500 V 90°C PVC insulated, Flexible single core.	Building wiring for installation in wire way or raceway, dry location. Do not install in conduit and direct burial in ground.
21		CTW-60227 IEC 10	TIS 11-2553 Part 4 Table 1	300/500 V 70°C PVC insulated, and double sheathed, two-five cores.	Building wiring for installation in wire way or raceway, dry location. Do not install in conduit and direct burial in ground.
25		CTW-60227 IEC 43	TIS 11-2553 Part 5 Table 5	300/300 V 70°C PVC double insulated, Flexible single core.	Using for decorative lights in building.
26		CTW-60227 IEC 52	TIS 11-2553 Part 5 Table 7	300/300 V 70°C PVC insulated and sheathed, flexible two cores, flat type.	Using for electrical home apparatus (small indoor electrical appliances such as desk-lamp, fan etc.)
27		CTW-60227 IEC 52	TIS 11-2553 Part 5 Table 7	300/300 V 70°C PVC insulated and sheathed, flexible two-three cores,	Using for electrical home apparatus (small indoor electrical appliances such as desk-lamp, fan etc.)
29		CTW-60227 IEC 53	TIS 11-2553 Part 5 Table 9	300/500 V 70°C PVC insulated and sheathed, flexible two cores, flat type.	Using for electrical home apparatus (Heavy duty), down light etc
30		CTW-60227 IEC 53	TIS 11-2553 Part 5 Table 9	300/500 V 70°C PVC insulated and sheathed, flexible two-three cores,	Using for electrical home apparatus (Heavy duty), down light etc
34		CTW-60227 IEC 56	TIS 11-2553 Part 5 Table 11	300/300 V 90°C PVC insulated and sheathed, flexible two cores, flat type.	Using for electrical home apparatus (Heavy duty)

# CONTENT

PAGE	BUILDING WIRE & LOW VOLTAGE POWER CABLE	CABLE TYPE	STANDARD	CABLE NAME	APPLICATION
35		CTW-60227 IEC 56	TIS 11-2553 Part 5 Table 11	300/300 V 90°C PVC insulated and sheathed, flexible two-three cores.	Using for electrical home apparatus (Heavy duty).
37		CTW-60227 IEC 57	TIS 11-2553 Part 5 Table 13	300/500 V 90°C PVC insulated and sheathed, flexible two cores, flat type.	Using for electrical home apparatus (Heavy duty), down light etc.
38		CTW-60227 IEC 57	TIS 11-2553 Part 5 Table 13	300/500 V 90°C PVC insulated and sheathed, flexible two-three cores.	Using for electrical home apparatus (Heavy duty), down light etc.
42		CTW-VAF	TIS 11-2553 Part 101 Table 1	300/500 V 70°C PVC insulated and sheathed, two cores, flat type.	Using for surface or above ceiling wiring, direct embedded in plaster. Do not using in conduit and burial in ground.
43		CTW-VAF-G	TIS 11-2553 Part 101 Table 1	300/500 V 70°C PVC insulated and sheathed, two cores, flat type. with ground	Using for surface or above ceiling wiring, direct embedded in plaster. Do not using in conduit and burial in ground.
44		CTW-NYY	TIS 11-2553 Part 101 Table 3	450/750 V 70°C PVC insulated and double sheathed, single core.	Building wiring for installation on cable tray, conduits and direct burial in ground.
46		CTW-NYY	TIS 11-2553 Part 101 Table 4	450/750 V 70°C PVC insulated and double sheathed, two-four cores.	Building wiring for installation on cable tray, conduits and direct burial in ground.
49		CTW-NYY-G	TIS 11-2553 Part 101 Table 5	450/750 V 70°C PVC insulated and double sheathed, two-four cores with ground.	Building wiring for installation on cable tray, conduits and direct burial in ground.
52		CTW-VCT	TIS 11-2553 Part 101 Table 7	450/750 V 70°C PVC insulated and sheathed, flexible single core.	Building wiring for installation on cable tray, in conduit, direct burial in ground and using for electrical home apparatus.
53		CTW-VCT	TIS 11-2553 Part 101 Table 7	450/750 V 70°C PVC insulated and sheathed, flexible two-four cores.	Building wiring for installation on cable tray, in conduit, direct burial in ground and using for electrical home apparatus.
56		CTW-VCT-G	TIS 11-2553 Part 101 Table 8	450/750 V 70°C PVC insulated and sheathed, flexible two-four cores with ground.	Building wiring for installation on cable tray, in conduit, direct burial in ground and using for electrical home apparatus.
59		CTW-CV	IEC 60502-1	CU/XLPE/PVC 0.6/1 (1.2) kV single core.	Preferably used for installation exposed or in raceway, wet or dry location.
61		CTW-CV	IEC 60502-1	CU/XLPE/PVC 0.6/1 (1.2) kV two-four cores.	Preferably used for installation exposed or in raceway, wet or dry location.
64		CTW-CV-AWA	IEC 60502-1	CU/XLPE/AWA/PVC 0.6/1 (1.2) kV single core.	Preferably used for installation exposed or in raceway, wet or dry location, or direct burial in ground.
66		CTW-CV-SWA	IEC 60502-1	CU/XLPE/SWA/PVC 0.6/1 (1.2) kV two-four cores.	Preferably used for installation exposed or in raceway, wet or dry location, or direct burial in ground.


# CONTENT


PAGE	TECHNICAL DATA & GENERAL INFORMATION	
70	CURRENT CAPACITIES FOR INSTALLATION OF BUILDING	
93	WIRE GAUGE	
97	STANDARD COEFFICIENT OF CONVERSION	
98	SYMBOLS OF ELECTRICAL UNITS & ELETICAL FORMULAS	
99	TABLE OF THE DIMENSIONS FOR MOTOR STARTERS	
100	POWER FACTOR CORRECTION FACTOR FOR POWER CAPACITOR	
101	POWER TRANSFORMER CURRENT CAPACITY	
103	COPPER CONDUCTOR RESISTANCE RATIOS	
106	CONDUCTIVITY AND DENSITY OF METALS	
108	PROPERTIES OF INSULATION AND SHEATH METERIALS - Resistance to industial chemical - Electrical properties	- Thermal properties - Long-time heat aging curves - General comparison data



บริษัท ซีที อิเลคทริก ซัพพลาย จำกัด  
**CT ELECTRIC SUPPLY CO., LTD.**

โทร : 02 550 9555





## CONSTRUCTION

**Conductor** Hard drawn copper wires ,  
Concentric stranded conductor  
Size 10 sq.mm. up to 500 sq.mm.

Direction of outermost layer Z  
(Right-Handed)



## APPLICATION

Aerial power transmission and overhead distribution line.

## CLASSIFICATION

Based on 97% Conductivity.  
Max. Volume Resistivity at 20°C  
0.01777 Ω-mm<sup>2</sup>/m


## REFERENCE

TIS 64-2517

## NOTE

CT ELECTRIC SUPPLY CO., LTD.

CTW-CSC (HD)		Number and Dia. of Wire	Overall Diameter	Maximum Conductor Resistance at 20°C	Breaking Strength	Cable Weight (Approx.)	Standard Packing
PRODUCT CODE	SIZE sq.mm.	No./mm	mm	Ω/km	kgf	kg/km	m/R
C00013010	10	7/1.35	4.05	1.80548	438	90	1,000
C00013016	16	7/1.70	5.10	1.13857	694	143	1,000
C00013025	25	7/2.14	6.42	0.71851	1,076	227	1,000
C00013035	35	7/2.52	7.56	0.51815	1,459	314	1,000
C00013050	50	7/3.02	9.06	0.35896	2,095	452	1,000
C00013050*	50	19/1.78	8.90	0.38252	2,021	428	1,000
C00013070	70	19/2.14	10.70	0.26466	2,921	618	1,000
C00013095	95	19/2.52	12.60	0.19183	3,961	858	1,000
C00013120	120	19/2.85	14.25	0.14922	5,067	1,097	1,000
C00013150	150	37/2.25	15.75	0.12384	6,289	1,334	1,000
C00013185	185	37/2.52	17.64	0.09873	7,713	1,673	1,000
C00013240	240	61/2.25	20.25	0.07528	10,369	2,200	1,000
C00013300	300	61/2.52	22.68	0.06002	12,717	2,760	1,000
C00013400	400	61/2.85	25.65	0.04692	16,266	3,530	1,000
C00013500	500	61/3.20	28.80	0.03703	20,506	4,451	1,000

**CONSTRUCTION**

**Conductor** Soft drawn copper wires,  
Concentric stranded conductor  
Size 10 sq.mm. up to 500 sq.mm.

Direction of outermost layer S  
(Left-Handed)

**APPLICATION**

For conductor insulated with various materials.  
The cable being suitable for used in distribution line and grounded electric system.

**CLASSIFICATION**

Based on 100% Conductivity.  
Max. Volume Resistivity at 20°C  
0.017241 Ω-mm<sup>2</sup>/m


**REFERENCE**

TIS 11-2553  
ASTM B3 & B8

**NOTE**

บริษัท ชาร์โอง ไทย วายร์ แอนด์ เคเบิล จำกัด  
CT ELECTRIC SUPPLY CO., LTD.

CTW-CSC (SD)		Number and Dia. of Wire	Overall Diameter	Maximum Conductor Resistance at 20°C	Cable Weight (Approx.)	Standard Packing
PRODUCT CODE	SIZE sq.mm.	No./mm	mm	Ω/km	kg/km	m/R
C00014010	10	7/1.35	4.05	1.830	90	1,000
C00014016	16	7/1.70	5.10	1.150	143	1,000
C00014025	25	7/2.14	6.54	0.727	227	1,000
C00014035	35	19/1.53	7.56	0.524	314	1,000
C00014050	50	19/1.78	8.90	0.387	428	1,000
C00014070	70	19/2.14	10.70	0.268	618	1,000
C00014095	95	19/2.52	12.60	0.193	858	1,000
C00014120	120	19/2.85	14.25	0.153	1,097	1,000
C00014150	150	37/2.25	15.75	0.124	1,334	1,000
C00014185	185	37/2.52	17.64	0.0991	1,673	1,000
C00014240	240	61/2.25	20.25	0.0754	2,200	1,000
C00014300	300	61/2.52	22.68	0.0601	2,760	1,000
C00014400	400	61/2.85	25.65	0.0470	3,530	1,000
C00014500	500	61/3.20	28.80	0.0366	4,451	1,000



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, solid or stranded Sizes 1.5 sq.mm. up to 400 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) (Any colour as requested)

## APPLICATION

Building wiring for installation in wire way or raceway, dry location.  
Do not install in conduit and direct burial in ground.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.


## REFERENCE

TIS 11-2553 Part 3 Table 1  
IEC 60227 Part 3 Table 1  
AC Test Voltage : 2.5 kV

## NOTE



CTW-60227 IEC 01		Conductor			Thickness of Insulation	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area	Number of Wire	Diameter (Approx.)						
		sq.mm.	No.	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFD011501	1 x 1.5	1.5	1	1.37	0.7	3.2	20	12.10	0.0110	100/C
CFD014501	1 x 1.5	1.5	7	1.56	0.7	3.3	25	12.10	0.0100	100/C
CFD011502	1 x 2.5	2.5	1	1.74	0.8	3.9	35	7.41	0.0100	100/C
CFD014502	1 x 2.5	2.5	7	2.01	0.8	4.0	40	7.41	0.0090	100/C
CFD011004	1 x 4	4	1	2.21	0.8	4.4	50	4.61	0.0085	100/C
CFD014004	1 x 4	4	7	2.52	0.8	4.6	55	4.61	0.0077	100/C
CFD011006	1 x 6	6	1	2.70	0.8	5.0	70	3.08	0.0070	100/C
CFD014006	1 x 6	6	7	3.09	0.8	5.2	75	3.08	0.0065	100/C
CFD011010	1 x 10	10	1	3.52	1.0	6.4	115	1.83	0.0070	100/C
CFD014010	1 x 10	10	7	3.99	1.0	6.7	125	1.83	0.0065	100/C
CFD014016	1 x 16	16	7	5.04	1.0	7.8	185	1.15	0.0050	100/C
CFD014025	1 x 25	25	7	6.33	1.2	9.7	290	0.727	0.0050	100/C
CFD014035	1 x 35	35	7	7.47	1.2	10.9	390	0.524	0.0043	100/C
CFD014050	1 x 50	50	19	8.80	1.4	12.8	520	0.387	0.0043	500/R
CFD014070	1 x 70	70	19	10.55	1.4	14.6	730	0.268	0.0035	500/R
CFD014095	1 x 95	95	19	12.45	1.6	17.1	1,010	0.193	0.0035	500/R



### CONSTRUCTION

<b>Conductor</b>	Anneal copper, solid or stranded Sizes 1.5 sq.mm. up to 400 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) (Any colour as requested)

### APPLICATION

Building wiring for installation in wire way or raceway, dry location.  
Do not install in conduit and direct burial in ground.

### CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.


### REFERENCE

 TIS 11-2553 Part 3 Table 1  
IEC 60227 Part 3 Table 1  
AC Test Voltage : 2.5 kV

### NOTE



CTW-60227 IEC 01		Conductor			Overall			Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area	Number of Wire	Diameter (Approx.)	Thickness of Insulation	Overall Diameter (Approx.)	Cable Weight (Approx.)			
		sq.mm.	No.	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFD014120	1 x 120	120	37	14.00	1.6	18.8	1,250	0.153	0.0032	500/R
CFD014150	1 x 150	150	37	15.54	1.8	20.9	1,540	0.1240	0.0032	500/R
CFD014185	1 x 185	185	37	17.43	2.0	23.3	1,930	0.0991	0.0032	500/R
CFD014240	1 x 240	240	61	19.98	2.2	26.6	2,510	0.0754	0.0032	500/R
CFD014300	1 x 300	300	61	22.41	2.4	29.6	3,140	0.0601	0.0030	500/R
CFD014400	1 x 400	400	61	25.29	2.6	33.2	3,990	0.0470	0.0028	500/R

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 1.5 sq.mm. up to 240 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) (Any colour as requested)

**APPLICATION**

Building wiring for installation in wire way or raceway, dry location.  
Do not install in conduit and direct burial in ground.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

**REFERENCE**


TIS 11-2553 Part 3 Table 3  
IEC 60227 Part 3 Table 3  
AC Test Voltage : 2.5 kV

**NOTE**

CTW-60227 IEC 02		Conductor			Thickness of Insulation	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area	Number and Dia. of Wire	Diameter (Approx.)						
		sq.mm.	No./mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFF016501	1 x 1.5	1.5	30/0.26	1.58	0.7	3.4	25	13.30	0.0100	100/C
CFF016502	1 x 2.5	2.5	50/0.26	2.04	0.8	4.1	35	7.98	0.0090	100/C
CFF016004	1 x 4	4	56/0.31	2.59	0.8	4.8	55	4.95	0.0070	100/C
CFF016006	1 x 6	6	84/0.31	3.59	0.8	5.3	80	3.30	0.0060	100/C
CFF016010	1 x 10	10	80/0.41	4.67	1.0	6.8	130	1.91	0.0056	100/C
CFF016016	1 x 16	16	126/0.41	5.86	1.0	8.1	195	1.21	0.0046	100/C
CFF016025	1 x 25	25	196/0.41	7.31	1.2	10.2	295	0.78	0.0044	100/C
CFF016035	1 x 35	35	276/0.41	8.67	1.2	11.7	405	0.554	0.0038	500/R
CFF016050	1 x 50	50	396/0.41	10.51	1.4	13.9	550	0.386	0.0037	500/R
CFF016070	1 x 70	70	360/0.51	12.52	1.4	16.0	760	0.272	0.0032	500/R
CFF016095	1 x 95	95	475/0.51	14.38	1.6	18.2	1,000	0.206	0.0032	500/R
CFF016120	1 x 120	120	608/0.51	16.32	1.6	20.2	1,255	0.161	0.0029	500/R
CFF016150	1 x 150	150	756/0.51	18.20	1.8	22.5	1,560	0.129	0.0029	500/R
CFF016185	1 x 185	185	925/0.51	20.13	2.0	24.9	1,910	0.106	0.0029	500/R
CFF016240	1 x 240	240	1,221/0.51	23.16	2.2	28.4	2,505	0.0801	0.0028	500/R



## 300/500 V 70°C PVC INSULATED, SINGLE CORE



# CONSTRUCTION

<b>Conductor</b>	Anneal copper, solid Sizes 0.5 sq.mm. up to 1 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) (Any colour as requested)

## APPLICATION

Building wiring for installation in wire way or raceway, dry location.  
Do not install in conduit and direct burial in ground.

# CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.




## REFERENCE

 TIS 11-2553 Part 3 Table 5  
IEC 60227 Part 3 Table 5  
AC Test Voltage : 2.0 kV

## NOTE



## 300/500 V 70°C PVC INSULATED, FLEXIBLE SINGLE CORE



# CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.5 sq.mm. up to 1 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) (Any colour as requested)

# APPLICATION

Building wiring for installation in wire way or raceway, dry location.  
Do not install in conduit and direct burial in ground.

# CLASSIFICATION


Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.



## REFERENCE

 TIS 11-2553 Part 3 Table 7  
IEC 60227 Part 3 Table 7  
AC Test Voltage : 2.0 kV

## NOTE

**CONSTRUCTION**

**Conductor** Anneal copper, Solid  
Sizes 0.5 sq.mm. up to 2.5 sq.mm.  
**Insulation** Polyvinyl chloride (PVC/E)  
(Any colour as requested)

**APPLICATION**

Building wiring for installation in wire way or raceway, dry location.  
Do not install in conduit and direct burial in ground.

**CLASSIFICATION**


Maximum conductor temperature 90°C  
Circuit voltage does not exceed 500 volts.

**REFERENCE**

TIS 11-2553 Part 3 Table 9  
IEC 60227 Part 3 Table 9  
AC Test Voltage : 2.0 kV

**NOTE**

CTW-60227 IEC 07		Conductor			Thickness of Insulation	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area	Number and Dia. of Wire	Diameter (Approx.)						
		sq.mm.	No./mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFI011005	1 x 0.5	0.5	1/0.80	0.80	0.6	2.3	10	36.0	0.015	100/C
CFI011075	1 x 0.75	0.75	1/0.97	0.97	0.6	2.5	15	24.5	0.013	100/C
CFI011001	1 x 1	1	1/1.13	1.13	0.6	2.7	20	18.1	0.012	100/C
CFI011501	1 x 1.5	1.5	1/1.38	1.38	0.7	3.2	25	12.1	0.011	100/C
CFI011502	1 x 2.5	2.5	1/1.77	1.77	0.8	3.9	35	7.41	0.009	100/C

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.5 sq.mm. up to 2.5 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/E) (Any colour as requested)

**APPLICATION**

Building wiring for installation in wire way or raceway, dry location.  
Do not install in conduit and direct burial in ground.

**CLASSIFICATION**


Maximum conductor temperature 90°C  
Circuit voltage does not exceed 500 volts.

**REFERENCE**

TIS 11-2553 Part 3 Table 11  
IEC 60227 Part 3 Table 11  
AC Test Voltage : 2.0 KV

**NOTE**

CTW-60227 IEC 08		Conductor			Thickness of Insulation	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area	Number and Dia. of Wire	Diameter (Approx.)						
		sq.mm.	No./mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFJ016005	1 x 0.5	0.5	16/0.21	0.92	0.6	2.5	10	39.0	0.013	100/C
CFJ016075	1 x 0.75	0.75	24/0.21	1.13	0.6	2.7	15	26.0	0.012	100/C
CFJ016001	1 x 1	1	32/0.21	1.30	0.6	2.8	20	19.5	0.010	100/C
CFJ016501	1 x 1.5	1.5	30/0.26	1.57	0.7	3.4	25	13.3	0.009	100/C
CFJ016502	1 x 2.5	2.5	50/0.26	2.03	0.8	4.1	35	7.98	0.009	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, solid or stranded Sizes 1.5 sq.mm. up to 35 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Blue, Brown
<b>Inner sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black
<b>Outer sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

## APPLICATION

Building wiring for installation in wire way or raceway or on cable tray, dry location.  
Do not install in conduit and direct burial in ground.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.

## REFERENCE

TIS 11-2553 Part 4 Table 1  
IEC 60227 Part 4 Table 1  
AC Test Voltage : 2.0 kV

## NOTE

CTW-60227 IEC 10		Conductor			Thickness of Insulation	Thickness of Inner Sheath	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area	Number of Wire	Diameter (Approx.)	mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFL021501	2 x 1.5	1.5	1	1.37	0.7	0.4	1.2	10.0	140	12.10	0.0110	100/C
CFL024501	2 x 1.5	1.5	7	1.56	0.7	0.4	1.2	10.5	155	12.10	0.0100	100/C
CFL021502	2 x 2.5	2.5	1	1.74	0.8	0.4	1.2	11.5	185	7.41	0.0100	100/C
CFL024502	2 x 2.5	2.5	7	2.01	0.8	0.4	1.2	12.0	205	7.41	0.0090	100/C
CFL021004	2 x 4	4	1	2.21	0.8	0.4	1.2	12.5	230	4.61	0.0085	100/C
CFL024004	2 x 4	4	7	2.52	0.8	0.4	1.2	13.0	260	4.61	0.0077	100/C
CFL021006	2 x 6	6	1	2.70	0.8	0.4	1.2	13.5	295	3.08	0.0700	100/C
CFL024006	2 x 6	6	7	3.08	0.8	0.4	1.2	14.0	325	3.08	0.0065	100/C
CFL021010	2 x 10	10	1	3.52	1.0	0.6	1.4	16.5	465	1.83	0.0070	500/R
CFL024010	2 x 10	10	7	3.99	1.0	0.6	1.4	17.5	520	1.83	0.0065	500/R
CFL024016	2 x 16	16	7	5.04	1.0	0.6	1.4	20.0	710	1.15	0.0052	500/R
CFL024025	2 x 25	25	7	6.33	1.2	0.8	1.4	24.0	1,050	0.727	0.0050	500/R
CFL024035	2 x 35	35	7	7.47	1.2	1.0	1.6	27.5	1,380	0.524	0.0044	500/R

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, solid or stranded Sizes 1.5 sq.mm. up to 35 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Brown, Black, Grey.
<b>Inner sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black
<b>Outer sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

\*\* Product code "CGO03XXXX" for colour : Blue, Brown, Green with Yellow stripe \*\*

**APPLICATION**

Building wiring for installation in wire way or raceway or on cable tray, dry location.  
Do not install in conduit and direct burial in ground.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.

**REFERENCE**

TIS 11-2553 Part 4 Table 1  
IEC 60227 Part 4 Table 1  
AC Test Voltage : 2.0 kV

**NOTE**

CTW-60227 IEC 10		Conductor			Thickness of Insulation	Thickness of Inner Sheath	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire	Diameter (Approx.) mm	mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFL031501	3 x 1.5	1.5	1	1.37	0.7	0.4	1.2	10.5	165	12.10	0.0110	100/C
CFL034501	3 x 1.5	1.5	7	1.56	0.7	0.4	1.2	11.0	185	12.10	0.0100	100/C
CFL031502	3 x 2.5	2.5	1	1.74	0.8	0.4	1.2	12.0	220	7.41	0.0100	100/C
CFL034502	3 x 2.5	2.5	7	2.01	0.8	0.4	1.2	12.5	240	7.41	0.0090	100/C
CFL031004	3 x 4	4	1	2.21	0.8	0.4	1.2	13.0	280	4.61	0.0085	100/C
CFL034004	3 x 4	4	7	2.52	0.8	0.4	1.2	13.5	315	4.61	0.0077	100/C
CFL031006	3 x 6	6	1	2.70	0.8	0.4	1.4	14.5	375	3.08	0.0070	100/C
CFL034006	3 x 6	6	7	3.08	0.8	0.4	1.4	15.5	415	3.08	0.0065	100/C
CFL031010	3 x 10	10	1	3.52	1.0	0.6	1.4	17.5	575	1.83	0.0070	500/R
CFL034010	3 x 10	10	7	3.99	1.0	0.6	1.4	19.0	640	1.83	0.0065	500/R
CFL034016	3 x 16	16	7	5.04	1.0	0.8	1.4	21.5	895	1.15	0.0052	500/R
CFL034025	3 x 25	25	7	6.33	1.2	0.8	1.6	26.0	1,335	0.727	0.0050	500/R
CFL034035	3 x 35	35	7	7.47	1.2	1.0	1.6	29.0	1,735	0.524	0.0044	500/R

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, solid or stranded Sizes 1.5 sq.mm. up to 35 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Blue, Brown, Black, Grey.
<b>Inner sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black
<b>Outer sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

\*\* Product code "CGO04XXXX" for colour : Brown, Black, Grey, Green with Yellow stripe \*\*

**APPLICATION**

Building wiring for installation in wire way or raceway or on cable tray, dry location.  
Do not install in conduit and direct burial in ground.

**CLASSIFICATION**


Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.

**REFERENCE**

TIS 11-2553 Part 4 Table 1  
IEC 60227 Part 4 Table 1  
AC Test Voltage : 2.0 kV

**NOTE**

CTW-60227 IEC 10		Conductor			Thickness of Insulation	Thickness of Inner Sheath	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area	Number of Wire	Diameter (Approx.)	mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFL041501	4 x 1.5	1.5	1	1.37	0.7	0.4	1.2	11.5	195	12.10	0.0110	100/C
CFL044501	4 x 1.5	1.5	7	1.56	0.7	0.4	1.2	12.0	220	12.10	0.0100	100/C
CFL041502	4 x 2.5	2.5	1	1.74	0.8	0.4	1.2	13.0	265	7.41	0.0100	100/C
CFL044502	4 x 2.5	2.5	7	2.01	0.8	0.4	1.2	13.5	290	7.41	0.0090	100/C
CFL041004	4 x 4	4	1	2.21	0.8	0.4	1.4	14.5	360	4.61	0.0085	100/C
CFL044004	4 x 4	4	7	2.52	0.8	0.4	1.4	15.0	395	4.61	0.0077	100/C
CFL041006	4 x 6	6	1	2.70	0.8	0.6	1.4	16.0	475	3.08	0.0070	100/C
CFL044006	4 x 6	6	7	3.08	0.8	0.6	1.4	17.0	525	3.08	0.0065	100/C
CFL041010	4 x 10	10	1	3.52	1.0	0.6	1.4	19.0	715	1.83	0.0070	500/R
CFL044010	4 x 10	10	7	3.99	1.0	0.6	1.4	20.5	795	1.83	0.0065	500/R
CFL044016	4 x 16	16	7	5.04	1.0	0.8	1.4	23.5	1,115	1.15	0.0052	500/R
CFL044025	4 x 25	25	7	6.33	1.2	1.0	1.6	28.5	1,695	0.727	0.0050	500/R
CFL044035	4 x 35	35	7	7.47	1.2	1.0	1.6	32.0	2,180	0.524	0.0044	500/R

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, solid or stranded Sizes 1.5 sq.mm. up to 35 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Blue, Brown, Black, Grey, Green with Yellow stripe.
<b>Inner sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black
<b>Outer sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

**APPLICATION**

Building wiring for installation in wire way or raceway or on cable tray, dry location.  
Do not install in conduit and direct burial in ground.

**CLASSIFICATION**


Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.

**REFERENCE**

TIS 11-2553 Part 4 Table 1  
IEC 60227 Part 4 Table 1  
AC Test Voltage : 2.0 kV

**NOTE**

CTW-60227 IEC 10		Conductor			Thickness of Insulation	Thickness of Inner Sheath	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire	Diameter (Approx.) mm	mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CGO051501	5 x 1.5	1.5	1	1.37	0.7	0.4	1.2	12.0	230	12.10	0.0110	100/C
CGO054501	5 x 1.5	1.5	7	1.56	0.7	0.4	1.2	12.5	255	12.10	0.0100	100/C
CGO051502	5 x 2.5	2.5	1	1.74	0.8	0.4	1.2	14.0	315	7.41	0.0100	100/C
CGO054502	5 x 2.5	2.5	7	2.01	0.8	0.4	1.2	14.5	350	7.41	0.0090	100/C
CGO051004	5 x 4	4	1	2.21	0.8	0.6	1.4	16.0	340	4.61	0.0085	100/C
CGO054004	5 x 4	4	7	2.52	0.8	0.6	1.4	17.0	495	4.61	0.0077	100/C
CGO051006	5 x 6	6	1	2.70	0.8	0.6	1.4	17.5	575	3.08	0.0070	100/C
CGO054006	5 x 6	6	7	3.08	0.8	0.6	1.4	18.5	635	3.08	0.0065	100/C
CGO051010	5 x 10	10	1	3.52	1.0	0.6	1.4	21.0	865	1.83	0.0070	500/R
CGO054010	5 x 10	10	7	3.99	1.0	0.6	1.4	22.0	965	1.83	0.0065	500/R
CGO054016	5 x 16	16	7	5.04	1.0	0.8	1.6	26.0	1,370	1.15	0.0052	500/R
CGO054025	5 x 25	25	7	6.33	1.2	1.0	1.6	31.5	2,060	0.727	0.0050	500/R
CGO054035	5 x 35	35	7	7.47	1.2	1.2	1.6	35.0	2,685	0.524	0.0044	500/R



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.5 sq.mm. up to 0.75 sq.mm.
<b>Inner Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Black
<b>Outer Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Green

## APPLICATION

Using for decorative lights in building.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 300 volts.


## REFERENCE

TIS 11-2553 Part 5 Table 3  
IEC 60227 Part 5 Table 3  
AC Test Voltage : 2.0 kV

## NOTE



CTW-60227 IEC 43		Conductor			Thickness of each layer Insulation (Min.)	Overall Insulation Thickness (Min.)	Overall Insulation Thickness (Mean)	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFN016005	1 x 0.5	0.5	16/0.21	0.92	0.20	0.6	0.7	2.7	10	39.0	0.0140	100/C
CFN016075	1 x 0.75	0.75	24/0.21	1.13	0.20	0.6	0.7	2.9	15	26.0	0.0120	100/C

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.5 sq.mm. up to 0.75 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Blue, Brown
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : White

**APPLICATION**

Using for electrical home apparatus  
(small indoor electrical appliances such as desk-lamp, fan etc.)

**CLASSIFICATION**


Maximum conductor temperature 70°C  
Circuit voltage does not exceed 300 volts.

**REFERENCE**

TIS 11-2553 Part 5 Table 7  
IEC 60227 Part 5 Table 7  
AC Test Voltage : 2.0 kV

**NOTE**

CTW-60227 IEC 52		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFP026005	2 x 0.5	0.5	16/0.21	0.92	0.5	0.6	3.7 x 5.9	35	39.0	0.012	100/C
CFP026075	2 x 0.75	0.75	24/0.21	1.13	0.5	0.6	3.8 x 6.3	45	26.0	0.010	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.5 sq.mm. up to 0.75 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Blue, Brown
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

## APPLICATION

Using for electrical home apparatus  
(small indoor electrical appliances such as desk-lamp, fan etc.)

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 300 volts.

## REFERENCE


TIS 11-2553 Part 5 Table 7  
IEC 60227 Part 5 Table 7  
AC Test Voltage : 2.0 kV

## NOTE



## CTW-60227 IEC 52

CTW-60227 IEC 52		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFP026005	2 x 0.5	0.5	16/0.21	0.92	0.5	0.6	5.9	45	39.0	0.012	100/C
CFP026075	2 x 0.75	0.75	24/0.21	1.13	0.5	0.6	6.3	55	26.0	0.010	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.5 sq.mm. up to 0.75 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Blue, Brown, Green with Yellow stripe
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

## APPLICATION

Using for electrical home apparatus  
(small indoor electrical appliances such as desk-lamp,fans etc.)

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 300 volts.


## REFERENCE

TIS 11-2553 Part 5 Table 7  
IEC 60227 Part 5 Table 7  
AC Test Voltage : 2.0 kV

## NOTE



CTW-60227 IEC 52		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFP036005	3 x 0.5	0.5	16/0.21	0.92	0.5	0.6	6.3	55	39.0	0.012	100/C
CFP036075	3 x 0.75	0.75	24/0.21	1.13	0.5	0.6	6.7	70	26.0	0.010	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.75 sq.mm. up to 2.5 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Blue, Brown
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : White

## APPLICATION

Using for electrical home apparatus  
(Heavy duty), down light etc

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.


## REFERENCE

TIS 11-2553 Part 5 Table 9  
IEC 60227 Part 5 Table 9  
AC Test Voltage : 2.0 kV

## NOTE



CTW-60227 IEC 53		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFR026075	2 x 0.75	0.75	24/0.21	1.13	0.6	0.8	4.5x7.2	70	26.0	0.011	100/C
CFR026001	2 x 1	1	32/0.21	1.31	0.6	0.8	4.7x7.5	80	19.5	0.010	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.75 sq.mm. up to 2.5 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Blue, Brown
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

## APPLICATION

Using for electrical home apparatus  
(Heavy duty), down light etc.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.


## REFERENCE

TIS 11-2553 Part 5 Table 9  
IEC 60227 Part 5 Table 9  
AC Test Voltage : 2.0 kV

## NOTE



CTW-60227 IEC 53		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFR026075	2 x 0.75	0.75	24/0.21	1.13	0.6	0.8	7.2	70	26.0	0.011	100/C
CFR026001	2 x 1	1	32/0.21	1.31	0.6	0.8	7.5	80	19.5	0.010	100/C
CFR026501	2 x 1.5	1.5	30/0.26	1.58	0.7	0.8	8.6	105	13.3	0.010	100/C
CFR026502	2 x 2.5	2.5	50/0.26	2.04	0.8	1.0	10.6	155	7.98	0.009	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.75 sq.mm. up to 2.5 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Brown, Black, Grey
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

## APPLICATION

Using for electrical home apparatus  
(Heavy duty), down light etc.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.


## REFERENCE

TIS 11-2553 Part 5 Table 9  
IEC 60227 Part 5 Table 9  
AC Test Voltage : 2.0 kV

## NOTE

\*\* Product code "CGP036XXX" for colour : Blue, Brown, Green with Yellow stripe \*\*

CTW-60227 IEC 53		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFR036075	3 x 0.75	0.75	24/0.21	1.13	0.6	0.8	7.6	80	26.0	0.011	100/C
CFR036001	3 x 1	1	32/0.21	1.31	0.6	0.8	8.0	95	19.5	0.010	100/C
CFR036501	3 x 1.5	1.5	30/0.26	1.58	0.7	0.9	9.4	130	13.3	0.010	100/C
CFR036502	3 x 2.5	2.5	50/0.26	2.04	0.8	1.1	11.4	190	7.98	0.009	100/C

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.75 sq.mm. up to 2.5 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Blue, Brown, Black, Grey
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

**APPLICATION**

Using for electrical home apparatus  
(Heavy duty), down light etc.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.


**REFERENCE**

TIS 11-2553 Part 5 Table 9  
IEC 60227 Part 5 Table 9  
AC Test Voltage : 2.0 KV

**NOTE**

\*\* Product code "CGP036XXX" for colour :  
Blue, Brown, Black, Green with Yellow stripe \*\*

CTW-60227 IEC 53		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFR046075	4 x 0.75	0.75	24/0.21	1.13	0.6	0.8	8.3	100	26.0	0.011	100/C
CFR046001	4 x 1	1	32/0.21	1.31	0.6	0.9	9.0	120	19.5	0.010	100/C
CFR046501	4 x 1.5	1.5	30/0.26	1.58	0.7	1.0	10.5	160	13.3	0.010	100/C
CFR046502	4 x 2.5	2.5	50/0.26	2.04	0.8	1.1	12.5	235	7.98	0.009	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.75 sq.mm. up to 2.5 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Bule, Brown, Black, Grey, Green with Yellow stripe
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

## APPLICATION

Using for electrical home apparatus  
(Heavy duty), down light etc.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.


## REFERENCE

TIS 11-2553 Part 5 Table 9  
IEC 60227 Part 5 Table 9  
AC Test Voltage : 2.0 kV

## NOTE



CTW-60227 IEC 53		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CGP056075	5 x 0.75	0.75	24/0.21	1.13	0.6	0.9	9.3	120	26.0	0.011	100/C
CGP056001	5 x 1	1	32/0.21	1.31	0.6	0.9	9.8	140	19.5	0.010	100/C
CGP056501	5 x 1.5	1.5	30/0.26	1.58	0.7	1.1	11.6	190	13.3	0.010	100/C
CGP056502	5 x 2.5	2.5	50/0.26	2.04	0.8	1.2	13.9	280	7.98	0.009	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.5 sq.mm. up to 0.75 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/E) Colour : Blue, Brown
<b>Sheath</b>	Polyvinyl chloride (PVC/ST10) Colour : White

## APPLICATION

Using for electrical home apparatus.  
(Heavy duty)

## CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 300 volts.

## REFERENCE

TIS 11-2553 Part 5 Table 11  
IEC 60227 Part 5 Table 11  
AC Test Voltage : 2.0 kV

## NOTE



## CTW-60227 IEC 56


CTW-60227 IEC 56		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFS026005	2 x 0.5	0.5	16/0.21	0.92	0.5	0.6	3.7 x 5.9	35	39.0	0.012	100/C
CFS026075	2 x 0.75	0.75	24/0.21	1.13	0.5	0.6	3.8 x 6.3	45	26.0	0.010	100/C



CHAROONG THAI WIRE & CABLE PUBLIC COMPANY LIMITED

CABLE TYPE : CTW-60227 IEC 56

300/300 V 90°C PVC INSULATED AND SHEATHED, FLEXIBLE TWO CORES



# CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.5 sq.mm. up to 0.75 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/E) Colour : Blue, Brown
<b>Sheath</b>	Polyvinyl chloride (PVC/ST10) Colour : Black



# APPLICATION

Using for electrical home apparatus.  
(Heavy duty)

## CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 300 volts.

## REFERENCE



TIS 11-2553 Part 5 Table 11

IEC 60227 Part 5 Table 11

AC Test Voltage : 2.0 kV

## NOTE

C = Packing in coil  
R = Packing in reel


Building Wire & Low Voltage Power Cable 35



CHAROONG THAI WIRE & CABLE PUBLIC COMPANY LIMITED

CABLE TYPE : CTW-60227 IEC 56

300/300 V 90°C PVC INSULATED AND SHEATHED, FLEXIBLE THREE CORES



# CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.5 sq.mm. up to 0.75 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/E) Colour : Blue, Brown, Green with Yellow Stripe
<b>Sheath</b>	Polyvinyl chloride (PVC/ST10) Colour : Black



# APPLICATION

## Using for electrical home apparatus. (Heavy duty)

---

# REFERENCE


# CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 300 volts.

## REFERENCE

TIS 11-2553 Part 5 Table 11  
IEC 60227 Part 5 Table 11  
AC Test Voltage : 2.0 kV

NOTE



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.75 sq.mm. up to 1 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/E) Colour : Blue, Brown
<b>Sheath</b>	Polyvinyl chloride (PVC/ST10) Colour : White

## APPLICATION

Using for electrical home apparatus  
(Heavy duty), down light etc.

## CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 500 volts.


## REFERENCE

TIS 11-2553 Part 5 Table 13  
IEC 60227 Part 5 Table 13  
AC Test Voltage : 2.0 kV

## NOTE



CTW-60227 IEC 57		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFU026075	2 x 0.75	0.75	24/0.21	1.13	0.6	0.8	4.5 x 7.2	50	26.0	0.011	100/C
CFU026001	2 x 1	1	32/0.21	1.31	0.6	0.8	4.7 x 7.5	60	19.5	0.010	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.75 sq.mm. up to 2.5 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/E) Colour : Blue, Brown
<b>Sheath</b>	Polyvinyl chloride (PVC/ST10) Colour : Black

## APPLICATION

Using for electrical home apparatus  
(Heavy duty), down light etc.

## CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 500 volts.


## REFERENCE

TIS 11-2553 Part 5 Table 13  
IEC 60227 Part 5 Table 13  
AC Test Voltage : 2.0 kV

## NOTE



CTW-60227 IEC 57		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFV026075	2 x 0.75	0.75	24/0.21	1.13	0.6	0.8	7.2	70	26.0	0.011	100/C
CFV026001	2 x 1	1	32/0.21	1.31	0.6	0.8	7.5	80	19.5	0.010	100/C
CFV026501	2 x 1.5	1.5	30/0.26	1.58	0.7	0.8	8.6	105	13.3	0.010	100/C
CFV026502	2 x 2.5	2.5	50/0.26	2.04	0.8	1.0	10.6	155	7.98	0.009	100/C

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.75 sq.mm. up to 2.5 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/E) Colour : Brown, Black, Grey
<b>Sheath</b>	Polyvinyl chloride (PVC/ST10) Colour : Black

**APPLICATION**

Using for electrical home apparatus  
(Heavy duty), down light etc.

**CLASSIFICATION**

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 500 volts.

**REFERENCE**


TIS 11-2553 Part 5 Table 13  
IEC 60227 Part 5 Table 13  
AC Test Voltage : 2.0 kV

**NOTE**

\*\* Product code "CGQ036XXX" for colour :  
Blue, Brown, Green with Yellow stripe \*\*

**CTW-60227 IEC 57**

CTW-60227 IEC 57		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFV036075	3 x 0.75	0.75	24/0.21	1.13	0.6	0.8	7.6	80	26.0	0.011	100/C
CFV036001	3 x 1	1	32/0.21	1.31	0.6	0.8	8.0	95	19.5	0.010	100/C
CFV036501	3 x 1.5	1.5	30/0.26	1.58	0.7	0.9	9.4	130	13.3	0.010	100/C
CFV036502	3 x 2.5	2.5	50/0.26	2.04	0.8	1.1	11.4	190	7.98	0.009	100/C

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.75 sq.mm. up to 2.5 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/E) Colour : Blue, Brown, Black, Grey
<b>Sheath</b>	Polyvinyl chloride (PVC/ST10) Colour : Black

**APPLICATION**

Using for electrical home apparatus  
(Heavy duty), down light etc.

**CLASSIFICATION**

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 500 volts.


**REFERENCE**

TIS 11-2553 Part 5 Table 13  
IEC 60227 Part 5 Table 13  
AC Test Voltage : 2.0 KV

**NOTE**

\*\* Product code "CGQ046XXX" for colour :  
Brown, Black, Grey, Green with Yellow stripe \*\*

CTW-60227 IEC 57		Conductor			Thickness of Insulation	Thickness of Inner Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFV046075	4 x 0.75	0.75	24/0.21	1.13	0.6	0.8	8.3	100	26.0	0.011	100/C
CFV046001	4 x 1	1	32/0.21	1.31	0.6	0.9	9.0	120	19.5	0.010	100/C
CFV046501	4 x 1.5	1.5	30/0.26	1.58	0.7	1.0	10.5	160	13.3	0.010	100/C
CFV046502	4 x 2.5	2.5	50/0.26	2.04	0.8	1.1	12.5	235	7.98	0.009	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 0.75 sq.mm. up to 2.5 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/E) Colour : Blue, Brown, Black, Grey, Green with Yellow stripe
<b>Sheath</b>	Polyvinyl chloride (PVC/ST10) Colour : Black

## APPLICATION

Using for electrical home apparatus  
(Heavy duty), down light etc.

## CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 500 volts.


## REFERENCE

TIS 11-2553 Part 5 Table 13  
IEC 60227 Part 5 Table 13  
AC Test Voltage : 2.0 kV

## NOTE



CTW-60227 IEC 57		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CGQ056075	5 x 0.75	0.75	24/0.21	1.13	0.6	0.9	9.3	125	26.0	0.011	100/C
CGQ056001	5 x 1	1	32/0.21	1.31	0.6	0.9	9.8	140	19.5	0.010	100/C
CGQ056501	5 x 1.5	1.5	30/0.26	1.58	0.7	1.1	11.6	200	13.3	0.010	100/C
CGQ056502	5 x 2.5	2.5	50/0.26	2.04	0.8	1.2	13.9	290	7.98	0.009	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, solid or stranded Sizes 1 sq.mm. up to 16 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Blue, Brown
<b>Sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : White

## APPLICATION

Using for surface or above ceiling wiring,  
direct embedded in plaster.  
Do not using in conduit and burial in ground.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.

## REFERENCE

TIS 11-2553 Part 101 Table 1


AC Test Voltage : 2.0 kV

## NOTE



CTW-VAF		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFW021001	2 x 1	1	1	1.12	0.6	0.9	4.7 x 7.4	60	18.10	0.0110	100/C
CFW021501	2 x 1.5	1.5	1	1.37	0.7	0.9	5.4 x 8.4	75	12.10	0.0110	100/C
CFW021502	2 x 2.5	2.5	1	1.74	0.8	1.0	6.2 x 9.8	110	7.41	0.0100	100/C
CFW024004	2 x 4	4	7	2.52	0.8	1.1	7.2 x 11.5	165	4.61	0.0077	100/C
CFW024006	2 x 6	6	7	3.09	0.8	1.1	8.0 x 13.0	215	3.08	0.0065	100/C
CFW024010	2 x 10	10	7	3.99	1.0	1.2	9.6 x 16.0	335	1.83	0.0065	100/C
CFW024016	2 x 16	16	7	5.04	1.0	1.3	11.0 x 18.5	480	1.15	0.0052	100/C

300/500 V 70°C PVC INSULATED AND SHEATHED, FLAT TYPE, TWO CORES WITH GROUND

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, solid or stranded Sizes 1 sq.mm. up to 16 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Blue, Brown, Green with Yellow stripe
<b>Sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : White

**APPLICATION**

Using for surface or above ceiling wiring,  
in wire way.  
Do not wiring in conduit and burial inground.  
The cable being suitable for use in grounded  
electrical system.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 500 volts.

**REFERENCE**


 TIS 11-2553 Part 101 Table 1

AC Test Voltage : 2.0 kV

**NOTE****CTW-VAF-G****Phase Core****Ground Core**

02 550 9555

<b>PRODUCT CODE</b>	<b>SIZE sq.mm.</b>	Phase Core			Ground Core			<b>Overall Diameter (Approx.)</b>	<b>Cable Weight (Approx.)</b>	<b>Maximum Conductor Resistance at 20°C (Phase)</b>	<b>Maximum Conductor Resistance at 20°C (Ground)</b>	<b>Minimum Insulation Resistance at 70°C</b>	<b>Standard Packing</b>	
		<b>Number of Wire</b>	<b>Diameter (Approx)</b>	<b>Thickness of Insulation</b>	<b>Number of Wire</b>	<b>Diameter (Approx)</b>	<b>Thickness of Insulation</b>							
CFX021001	2 x 1/1	1	1.12	0.6	1	1.12	0.6	0.9	4.7 x 9.8	85	18.10	18.10	0.0110	100/C
CFX021501	2 x 1.5/1.5	1	1.37	0.7	1	1.37	0.7	0.9	5.4 x 11.5	110	12.10	12.10	0.0110	100/C
CFX021502	2 x 2.5/2.5	1	1.74	0.8	1	1.74	0.8	1.0	6.2 x 13.5	160	7.41	7.41	0.0100	100/C
CFX024004	2 x 4/4	7	2.52	0.8	7	2.52	0.8	1.1	7.4 x 16.5	240	4.61	4.61	0.0077	100/C
CFX024006	2 x 6/6	7	3.09	0.8	7	3.09	0.8	1.1	8.0 x 18.0	315	3.08	3.08	0.0065	100/C
CFX024010	2 x 10/10	7	3.99	1.0	7	3.99	1.0	1.2	9.6 x 22.5	495	1.83	1.83	0.0065	100/C
CFX024016	2 x 16/16	7	5.04	1.0	7	5.04	1.0	1.3	11.0 x 26.5	710	1.15	1.15	0.0052	100/C



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, solid or stranded Sizes 1 sq.mm. up to 500 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Black
<b>Sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

## APPLICATION

Building wiring for installation on cable tray,  
conduits and direct burial in ground.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

## REFERENCE


TIS 11-2553 Part 101 Table 3

AC Test Voltage: 2.5 KV

## NOTE



CTW-NYY		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFE011001	1 x 1	1	1	1.12	1.5	1.8	8.6	90	18.10	0.0207	100/C
CFE014001	1 x 1	1	7	1.29	1.5	1.8	8.8	95	18.10	0.0200	100/C
CFE011501	1 x 1.5	1.5	1	1.37	1.5	1.8	9.0	100	12.10	0.0184	100/C
CFE014501	1 x 1.5	1.5	7	1.56	1.5	1.8	9.2	105	12.10	0.0175	100/C
CFE011502	1 x 2.5	2.5	1	1.74	1.5	1.8	9.4	110	7.41	0.0157	100/C
CFE014502	1 x 2.5	2.5	7	2.01	1.5	1.8	9.8	120	7.41	0.0146	100/C
CFE011004	1 x 4	4	1	2.21	1.5	1.8	10.0	135	4.61	0.0135	100/C
CFE014004	1 x 4	4	7	2.52	1.5	1.8	10.5	140	4.61	0.0124	100/C
CFE014006	1 x 6	6	7	3.09	1.5	1.8	11.0	170	3.08	0.0107	100/C
CFE014010	1 x 10	10	7	3.99	1.5	1.8	12.0	225	1.83	0.0088	500/R
CFE014016	1 x 16	16	7	5.04	1.5	1.8	13.0	300	1.15	0.0074	500/R
CFE014025	1 x 25	25	7	6.33	1.5	1.8	14.5	410	0.727	0.0061	500/R
CFE014035	1 x 35	35	7	7.47	1.5	1.8	16.0	520	0.524	0.0053	500/R
CFE014050	1 x 50	50	19	8.80	1.5	1.8	17.0	655	0.387	0.0046	500/R
CFE014070	1 x 70	70	19	10.55	1.5	1.8	19.0	880	0.268	0.0039	500/R
CFE014095	1 x 95	95	19	12.45	1.7	1.8	21.5	1,180	0.193	0.0038	500/R



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, solid or stranded Sizes 1 sq.mm. up to 500 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Black
<b>Sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

## APPLICATION

Building wiring for installation on cable tray,  
conduits and direct burial in ground.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

## REFERENCE


TIS 11-2553 Part 101 Table 3

AC Test Voltage : 2.5 kV

## NOTE



CTW-NYY		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFE014120	1 x 120	120	37	14.00	1.7	1.8	23.0	1,440	0.153	0.0034	500/R
CFE014150	1 x 150	150	37	15.54	1.9	2.0	26.0	1,765	0.1240	0.0034	500/R
CFE014185	1 x 185	185	37	17.43	2.1	2.0	28.0	2,175	0.0991	0.0034	500/R
CFE014240	1 x 240	240	61	19.98	2.3	2.2	31.5	2,820	0.0754	0.0033	500/R
CFE014300	1 x 300	300	61	22.41	2.5	2.2	35.0	3,480	0.0601	0.0032	500/R
CFE014400	1 x 400	400	61	25.29	2.7	2.2	38.5	4,370	0.0470	0.0030	500/R
CFE014500	1 x 500	500	61	28.71	3.1	2.4	43.0	5,500	0.0366	0.0031	500/R

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, stranded Sizes 50 sq.mm. up to 300 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Blue, Brown
<b>Inner sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black
<b>Outer sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

**APPLICATION**

Building wiring for installation on cable tray, conduits and direct burial in ground.

**CLASSIFICATION**


Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

**REFERENCE**

 TIS 11-2553 Part 101 Table 4  
AC Test Voltage : 2.5 kV

**NOTE**

CTW-NYY		Conductor			Thickness of Insulation	Thickness of Inner Sheath	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFE024050	2 x 50	50	19	8.80	1.5	1.2	2.2	33.5	1,830	0.387	0.0046	500/R
CFE024070	2 x 70	70	19	10.55	1.5	1.5	2.2	38.0	2,460	0.268	0.0039	500/R
CFE024095	2 x 95	95	19	12.45	1.7	1.5	2.2	42.5	3,235	0.193	0.0038	500/R
CFE024120	2 x 120	120	37	14.00	1.7	1.5	2.4	46.5	3,945	0.153	0.0034	500/R
CFE024150	2 x 150	150	37	15.54	1.9	1.8	2.6	52.0	4,860	0.124	0.0034	500/R
CFE024185	2 x 185	185	37	17.43	2.1	1.8	2.8	57.0	5,875	0.0991	0.0034	500/R
CFE024240	2 x 240	240	61	19.98	2.3	2.0	3.0	64.0	7,700	0.0754	0.0033	300/R
CFE024300	2 x 300	300	61	22.41	2.5	2.0	3.2	70.5	9,460	0.0601	0.0032	300/R

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, stranded Sizes 50 sq.mm. up to 300 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Brown, Black, Grey
<b>Inner sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black
<b>Outer sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

**APPLICATION**

Building wiring for installation on cable tray,  
conduits and direct burial in ground.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.


**REFERENCE**

 TIS 11-2553 Part 101 Table 4

AC Test Voltage : 2.5 kV

**NOTE**

CTW-NYY		Conductor			Nominal Cross-Sectional Area	Thickness of Insulation	Thickness of Inner Sheath	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area	Number of Wire	Diameter (Approx.)	sq.mm.	No./mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFE034050	3 x 50	50	19	8.80	1.5	1.5	2.2	36.0	2,380	0.387	0.0046	500/R	
CFE034070	3 x 70	70	19	10.55	1.5	1.5	2.2	40.5	3,160	0.268	0.0039	500/R	
CFE034095	3 x 95	95	19	12.45	1.7	1.5	2.4	46.0	4,235	0.193	0.0038	500/R	
CFE034120	3 x 120	120	37	14.90	1.7	1.8	2.6	50.5	5,245	0.153	0.0034	500/R	
CFE034150	3 x 150	150	37	15.54	1.9	1.8	2.8	56.0	6,370	0.124	0.0034	300/R	
CFE034185	3 x 185	185	37	17.43	2.1	2.0	3.0	61.5	7,905	0.0991	0.0034	300/R	
CFE034240	3 x 240	240	61	19.98	2.3	2.0	3.2	69.0	10,135	0.0754	0.0033	200/R	
CFE034300	3 x 300	300	61	22.41	2.5	2.2	3.4	76.0	12,555	0.0601	0.0032	200/R	



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, stranded Sizes 50 sq.mm. up to 300 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Blue, Brown, Black, Grey
<b>Inner sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black
<b>Outer sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

## APPLICATION

Building wiring for installation on cable tray, conduits and direct burial in ground.

## CLASSIFICATION


Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

## REFERENCE


TIS 11-2553 Part 101 Table 4

AC Test Voltage : 2.5 kV

## NOTE



CTW-NYY		Conductor			Thickness of Insulation	Thickness of Inner Sheath	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFE044050	4 x 50	50	19	8.80	1.5	1.5	2.2	39.5	2,985	0.387	0.0046	500/R
CFE044070	4 x 70	70	19	10.55	1.5	1.5	2.4	44.5	4,035	0.268	0.0039	500/R
CFE044095	4 x 95	95	19	12.45	1.7	1.8	2.6	51.5	5,485	0.193	0.0038	500/R
CFE044120	4 x 120	120	37	14.90	1.7	1.8	2.8	56.0	6,700	0.153	0.0034	200/R
CFE044150	4 x 150	150	37	15.54	1.9	2.0	3.0	62.0	8,195	0.124	0.0034	300/R
CFE044185	4 x 185	185	37	17.43	2.1	2.0	3.2	68.0	10,120	0.0991	0.0034	200/R
CFE044240	4 x 240	240	61	19.98	2.3	2.2	3.4	76.5	13,055	0.0754	0.0033	200/R
CFE044300	4 x 300	300	61	22.41	2.5	2.2	3.8	85.0	16,170	0.0601	0.0032	100/R

**CONSTRUCTION**

<b>Conductor</b>	Annealed copper, stranded - Size 25 sq.mm. up to 300 sq.mm. (Phase Core) - Size 16 sq.mm. up to 150 sq.mm. (Ground Core)
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Blue, Brown, Green with Yellow stripe
<b>Inner Sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black
<b>Outer Sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

**APPLICATION**

Building wiring for installation on cable tray, conduit, direct burial in ground.  
The cable being suitable for use in grounded electrical system.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

**REFERENCE**


TIS 11-2553 Part 101 Table 5

AC Test Voltage : 2.5 kV

**NOTE**

CTW-NYY-G		Phase Core			Ground Core			Thickness of outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C (Phase)	Maximum Conductor Resistance at 20°C (Ground)	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	No.	mm	Thickness of Insulation	No.	mm	Thickness of Insulation							
CFY024025	2 x 25/16	7	6.33	1.3	7	5.04	1.1	1.2	2.0	28.0	1,300	0.727	1.150	0.0054
CFY024035	2 x 35/16	7	7.47	1.3	7	5.04	1.1	1.2	2.0	30.0	1,560	0.524	1.150	0.0047
CFY024050	2 x 50/25	19	8.80	1.5	7	6.33	1.3	1.2	2.2	34.0	2,090	0.387	0.727	0.0046
CFY024070	2 x 70/35	19	10.55	1.5	7	7.47	1.3	1.5	2.2	38.5	2,800	0.268	0.524	0.0039
CFY024095	2 x 95/50	19	12.45	1.7	19	8.80	1.5	1.5	2.2	43.5	3,695	0.193	0.387	0.0038
CFY024120	2 x 120/70	37	14.00	1.7	19	10.35	1.5	1.5	2.4	47.5	4,610	0.153	0.268	0.0034
CFY024150	2 x 150/95	37	15.54	1.9	19	12.45	1.7	1.8	2.6	53.0	5,815	0.124	0.193	0.0034
CFY024185	2 x 185/95	37	17.43	2.1	19	12.45	1.7	1.8	2.8	57.5	6,840	0.0991	0.193	0.0034
CFY024240	2 x 240/120	61	19.98	2.3	37	14.00	1.7	2.0	3.0	64.5	8,740	0.0754	0.153	0.0033
CFY024300	2 x 300/150	61	22.41	2.5	37	15.54	1.9	2.0	3.2	71.0	10,725	0.0601	0.124	0.0032

450/750 V 70°C PVC INSULATED AND DOUBLE SHEATHED, THREE CORES WITH GROUND

**CONSTRUCTION**

<b>Conductor</b>	Annealed copper, stranded - Size 25 sq.mm. up to 300 sq.mm. (Phase Core) - Size 16 sq.mm. up to 150 sq.mm. (Ground Core)
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Brown, Black, Grey, Green with Yellow stripe
<b>Inner Sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black
<b>Outer Sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

**APPLICATION**

Building wiring for installation on cable tray, conduit, direct burial in ground.  
The cable being suitable for use in grounded electrical system.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

**REFERENCE**


TIS 11-2553 Part 101 Table 5  
AC Test Voltage : 2.5 kV

**NOTE**

บริษัท ชาร์โงว์ ไทย วายรอนด์ จำกัด  
CT ELECTRIC SUPPLY CO., LTD.

CTW-NYY-G		Phase Core			Ground Core			Thickness of outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C (Phase)	Maximum Conductor Resistance at 20°C (Ground)	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	No.	mm	Thickness of Insulation	No.	mm	Thickness of Insulation							
CFY034025	3 x 25/16	7	6.33	1.3	7	5.04	1.1	1.2	2.0	30.5	1,655	0.727	1.150	0.0054
CFY034035	3 x 35/16	7	7.47	1.3	7	5.04	1.1	1.2	2.0	33.0	2,025	0.524	1.150	0.0047
CFY034050	3 x 50/25	19	8.80	1.5	7	6.33	1.3	1.5	2.2	38.5	2,760	0.387	0.727	0.0046
CFY034070	3 x 70/35	19	10.55	1.5	7	7.47	1.3	1.5	2.2	42.5	3,655	0.268	0.524	0.0039
CFY034095	3 x 95/50	19	12.45	1.7	19	8.80	1.5	1.5	2.4	48.5	4,895	0.193	0.387	0.0038
CFY034120	3 x 120/70	37	14.00	1.7	19	10.35	1.5	1.8	2.6	53.5	6,160	0.153	0.268	0.0034
CFY034150	3 x 150/95	37	15.54	1.9	19	12.45	1.7	1.8	2.8	59.0	7,615	0.124	0.193	0.0034
CFY034185	3 x 185/95	37	17.43	2.1	19	12.45	1.7	2.0	3.0	64.5	9,145	0.0991	0.193	0.0034
CFY034240	3 x 240/120	61	19.98	2.3	37	14.00	1.7	2.0	3.2	72.0	11,650	0.0754	0.153	0.0033
CFY034300	3 x 300/150	61	22.41	2.5	37	15.54	1.9	2.2	3.4	79.5	14,410	0.0601	0.124	0.0032

450/750 V 70°C PVC INSULATED AND DOUBLE SHEATHED, FOUR CORES WITH GROUND

**CONSTRUCTION**

<b>Conductor</b>	Annealed copper, stranded - Size 25 sq.mm. up to 300 sq.mm. (Phase Core) - Size 16 sq.mm. up to 150 sq.mm. (Ground Core)
<b>Insulation</b>	Polyvinyl chloride (PVC/C) Colour : Blue, Brown, Black, Grey, Green with Yellow stripe
<b>Inner Sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black
<b>Outer Sheath</b>	Polyvinyl chloride (PVC/ST4) Colour : Black

**APPLICATION**

Building wiring for installation on cable tray, conduit, direct burial in ground.  
The cable being suitable for use in grounded electrical system.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.


**REFERENCE**

TIS 11-2553 Part 101 Table 5  
AC Test Voltage : 2.5 kV

**NOTE**

บริษัท ชาร์โงว์ ไทย วายรอนด์ จำกัด  
CT ELECTRIC SUPPLY CO., LTD.

CTW-NYY-G		Phase Core			Ground Core			Thickness of inner Sheath	Thickness of outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C (Phase)	Maximum Conductor Resistance at 20°C (Ground)	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	No.	mm	Thickness of Insulation	No.	mm	Thickness of Insulation								
CFY044025	4 x 25/16	7	6.33	1.3	7	5.04	1.1	1.2	2.0	34.0	2,030	0.727	1.150	0.0054	500/R
CFY044035	4 x 35/16	7	7.47	1.3	7	5.04	1.1	1.5	2.2	39.0	2,600	0.524	1.150	0.0047	500/R
CFY044050	4 x 50/25	19	8.80	1.5	7	6.33	1.3	1.5	2.2	43.5	3,420	0.387	0.727	0.0046	500/R
CFY044070	4 x 70/35	19	10.55	1.5	7	7.47	1.3	1.5	2.4	49.0	4,605	0.268	0.524	0.0039	500/R
CFY044095	4 x 95/50	19	12.45	1.7	19	8.80	1.5	1.8	2.6	56.5	6,245	0.193	0.387	0.0038	300/R
CFY044120	4 x 120/70	37	14.00	1.7	19	10.35	1.5	1.8	2.8	61.5	7,730	0.153	0.268	0.0034	300/R
CFY044150	4 x 150/95	37	15.54	1.9	19	12.45	1.7	2.0	3.0	68.0	9,580	0.124	0.193	0.0034	300/R
CFY044185	4 x 185/95	37	17.43	2.1	19	12.45	1.7	2.0	3.2	75.0	11,530	0.0991	0.193	0.0034	200/R
CFY044240	4 x 240/120	61	19.98	2.3	37	14.00	1.7	2.2	3.4	84.5	14,800	0.0754	0.153	0.0033	200/R
CFY044300	4 x 300/150	61	22.41	2.5	37	15.54	1.9	2.2	3.8	93.5	18,310	0.0601	0.124	0.0032	100/R



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 4 sq.mm. up to 35 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Black
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

## APPLICATION

Building wiring for installation on cable tray, in conduit, direct burial in ground and using for electrical home apparatus.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

## REFERENCE


TIS 11-2553 Part 101 Table 7

AC Test Voltage : 2.5 kV

## NOTE



CTW-VCT		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFZ016004	1 x 4	4	56/0.31	2.59	0.9	1.4	8.6	100	4.95	0.0084	100/C
CFZ016006	1 x 6	6	84/0.31	3.59	0.9	1.4	9.4	135	3.30	0.0071	100/C
CFZ016010	1 x 10	10	80/0.41	4.67	1.1	1.8	12.0	215	1.91	0.0068	100/C
CFZ016016	1 x 16	16	126/0.41	5.86	1.1	1.8	13.5	290	1.21	0.0050	500/R
CFZ016025	1 x 25	25	196/0.41	7.31	1.3	2.2	16.0	435	0.780	0.0048	500/R
CFZ016035	1 x 35	35	276/0.41	8.67	1.3	2.2	17.5	555	0.554	0.0041	500/R

**CONSTRUCTION**

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 4 sq.mm. up to 35 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Blue, Brown
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

**APPLICATION**

Building wiring for installation on cable tray, in conduit, direct burial in ground and using for electrical home apparatus.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.


**REFERENCE**

TIS 11-2553 Part 101 Table 7

AC Test Voltage : 2.5 kV

**NOTE**

CTW-VCT		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFZ026004	2 x 4	4	56/0.31	2.59	0.9	1.6	14.5	250	4.95	0.0084	500/R
CFZ026006	2 x 6	6	84/0.31	3.59	0.9	1.6	16.0	330	3.30	0.0071	500/R
CFZ026010	2 x 10	10	80/0.41	4.67	1.1	1.8	20.0	515	1.91	0.0068	500/R
CFZ026016	2 x 16	16	126/0.41	5.86	1.1	2.2	23.0	735	1.21	0.0050	500/R
CFZ026025	2 x 25	25	196/0.41	7.31	1.3	2.4	27.5	1,075	0.780	0.0048	500/R
CFZ026035	2 x 35	35	276/0.41	8.67	1.3	2.6	31.0	1,410	0.554	0.0041	500/R



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 4 sq.mm. up to 35 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Brown, Black, Grey
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

## APPLICATION

Building wiring for installation on cable tray, in conduit, direct burial in ground and using for electrical home apparatus.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

## REFERENCE


TIS 11-2553 Part 101 Table 7

AC Test Voltage : 2.5 kV

## NOTE



CTW-VCT		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFZ036004	3 x 4	4	56/0.31	2.59	0.9	1.6	15.5	295	4.95	0.0084	500/R
CFZ036006	3 x 6	6	84/0.31	3.59	0.9	1.8	17.5	435	3.30	0.0071	500/R
CFZ036010	3 x 10	10	80/0.41	4.67	1.1	2.0	21.5	655	1.91	0.0068	500/R
CFZ036016	3 x 16	16	126/0.41	5.86	1.1	2.4	25.0	945	1.21	0.0050	500/R
CFZ036025	3 x 25	25	196/0.41	7.31	1.3	2.6	30.0	1,385	0.780	0.0048	500/R
CFZ036035	3 x 35	35	276/0.41	8.67	1.3	2.8	33.5	1,815	0.554	0.0041	500/R



## CONSTRUCTION

<b>Conductor</b>	Anneal copper, bunch stranded Sizes 4 sq.mm. up to 35 sq.mm.
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Blue, Brown, Black, Grey
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

## APPLICATION

Building wiring for installation on cable tray, in conduit, direct burial in ground and using for electrical home apparatus.

## CLASSIFICATION

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

## REFERENCE


TIS 11-2553 Part 101 Table 7

AC Test Voltage : 2.5 kV

## NOTE



CTW-VCT		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Min. Number and Max. Dia.of Wire No./mm	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
CFZ046004	4 x 4	4	56/0.31	2.59	0.9	1.8	17.0	375	4.95	0.0084	500/R
CFZ046006	4 x 6	6	84/0.31	3.59	0.9	2.0	19.5	545	3.30	0.0071	500/R
CFZ046010	4 x 10	10	80/0.41	4.67	1.1	2.2	24.0	830	1.91	0.0068	500/R
CFZ046016	4 x 16	16	126/0.41	5.86	1.1	2.6	28.0	1,195	1.21	0.0050	500/R
CFZ046025	4 x 25	25	196/0.41	7.31	1.3	2.8	33.0	1,755	0.780	0.0048	500/R
CFZ046035	4 x 35	35	276/0.41	8.67	1.3	3.1	37.0	2,325	0.554	0.0041	500/R

**CONSTRUCTION**

<b>Conductor</b>	Annealed copper, bunch stranded - Size 4 sq.mm. up to 35 sq.mm. (Phase Core) - Size 4 sq.mm. up to 16 sq.mm. (Ground Core)
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Blue, Brown, Green with Yellow stripe
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

**APPLICATION**

Building wiring for installation on cable tray, conduit, direct burial in ground and using for electrical home apparatus.  
The cable being suitable for use in grounded electrical system.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

**REFERENCE**


TIS 11-2553 Part 101 Table 8

AC Test Voltage : 2.5 kV

**NOTE**

CTW-VCT-G		Phase Core		Ground Core		Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C (Phase)	Maximum Conductor Resistance at 20°C (Ground)	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Min. Number and Max. Dia.of Wire	Thickness of Insulation	No./mm	mm							
CGA026004	2 x 4/4	56/0.31	0.9	56/0.31	0.9	1.6	15.5	295	4.95	4.95	0.0084	500/R
CGA026006	2 x 6/6	84/0.31	0.9	84/0.31	0.9	1.8	17.5	435	3.30	3.30	0.0071	500/R
CGA026010	2 x 10/10	80/0.41	1.1	80/0.41	1.1	2.0	21.5	695	1.91	1.91	0.0068	500/R
CGA026016	2 x 16/16	126/0.41	1.1	126/0.41	1.1	2.4	25.0	995	1.21	1.21	0.0050	500/R
CGA026025	2 x 25/16	196/0.41	1.3	126/0.41	1.1	2.6	28.5	1,370	0.780	1.21	0.0048	500/R
CGA026035	2 x 35/16	276/0.41	1.3	126/0.41	1.1	2.8	31.5	1,695	0.554	1.21	0.0041	500/R

450/750 V 70°C PVC INSULATED AND SHEATHED, FLEXIBLE THREE CORES WITH GROUND

**CONSTRUCTION**

<b>Conductor</b>	Annealed copper, bunch stranded - Size 4 sq.mm. up to 35 sq.mm. (Phase Core) - Size 4 sq.mm. up to 16 sq.mm. (Ground Core)
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Brown, Black, Grey,
<b>Sheath</b>	Green with Yellow stripe Polyvinyl chloride (PVC/ST5) Colour : Black

**APPLICATION**

Building wiring for installation on cable tray, conduit, direct burial in ground and using for electrical home apparatus.  
The cable being suitable for use in grounded electrical system.

**CLASSIFICATION**

Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

**REFERENCE**


TIS 11-2553 Part 101 Table 8

AC Test Voltage : 2.5 kV

**NOTE**

CTW-VCT-G		Phase Core		Ground Core		Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C (Phase)	Maximum Conductor Resistance at 20°C (Ground)	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Min. Number and Max. Dia.of Wire	Thickness of Insulation	No./mm	mm							
CGA036004	3 x 4/4	56/0.31	0.9	56/0.31	0.9	1.8	17.0	375	4.95	4.95	0.0084	500/R
CGA036006	3 x 6/6	84/0.31	0.9	84/0.31	0.9	2.0	19.5	545	3.30	3.30	0.0071	500/R
CGA036010	3 x 10/10	80/0.41	1.1	80/0.41	1.1	2.2	24.0	830	1.91	1.91	0.0068	500/R
CGA036016	3 x 16/16	126/0.41	1.1	126/0.41	1.1	2.6	28.0	1,190	1.21	1.21	0.0050	500/R
CGA036025	3 x 25/16	196/0.41	1.3	126/0.41	1.1	2.8	33.0	1,670	0.780	1.21	0.0048	500/R
CGA036035	3 x 35/16	276/0.41	1.3	126/0.41	1.1	3.1	37.0	2,120	0.554	1.21	0.0041	500/R

450/750 V 70°C PVC INSULATED AND SHEATHED, FLEXIBLE FOUR CORES WITH GROUND

**CONSTRUCTION**

<b>Conductor</b>	Annealed copper, bunch stranded - Size 4 sq.mm. up to 35 sq.mm. (Phase Core) - Size 4 sq.mm. up to 16 sq.mm. (Ground Core)
<b>Insulation</b>	Polyvinyl chloride (PVC/D) Colour : Blue, Brown, Black, Grey, Green with Yellow stripe
<b>Sheath</b>	Polyvinyl chloride (PVC/ST5) Colour : Black

**APPLICATION**

Building wiring for installation on cable tray, conduit, direct burial in ground and using for electrical home apparatus.  
The cable being suitable for use in grounded electrical system.

**CLASSIFICATION**


Maximum conductor temperature 70°C  
Circuit voltage does not exceed 750 volts.

**REFERENCE**

 TIS 11-2553 Part 101 Table 8  
AC Test Voltage : 2.5 kV

**NOTE**

CTW-VCT-G		Phase Core		Ground Core		Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C (Phase)	Maximum Conductor Resistance at 20°C (Ground)	Minimum Insulation Resistance at 70°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Min. Number and Max. Dia.of Wire	Thickness of Insulation	No./mm	Thickness of Insulation							
CGA046004	4 x 4/4	56/0.31	0.9	56/0.31	0.9	1.8	18.5	450	4.95	4.95	0.0084	500/R
CGA046006	4 x 6/6	84/0.31	0.9	84/0.31	0.9	2.0	21.5	660	3.30	3.30	0.0071	500/R
CGA046010	4 x 10/10	80/0.41	1.1	80/0.41	1.1	2.2	26.5	1,005	1.91	1.91	0.0068	500/R
CGA046016	4 x 16/16	126/0.41	1.1	126/0.41	1.1	2.6	30.5	1,445	1.21	1.21	0.0050	500/R
CGA046025	4 x 25/16	196/0.41	1.3	126/0.41	1.1	2.8	36.5	2,050	0.780	1.21	0.0048	500/R
CGA046035	4 x 35/16	276/0.41	1.3	126/0.41	1.1	3.1	41.5	2,640	0.554	1.21	0.0041	500/R



## CONSTRUCTION

**Conductor** Compact or Round concentric lay stranded copper  
- CR : Concentric lay stranded of conductor :  $\leq 10$  sq.mm.  
- CP : Compact round concentric lay stranded of conductor :  $> 10$  sq.mm.

**Insulation** Cross-linked polyethylene (XLPE)

Colour : Natural

**Sheath** Polyvinyl chloride (PVC:ST2)

Optional : Polyethylene (PE:ST7)

Colour : Black

## APPLICATION

Preferably used for installation exposed or in raceway wet or dry location or direct burial in ground.

## CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 1,000 volts.


## REFERENCE

TIS 2143  
IEC 60228, IEC 60502-1  
AC Test Voltage : 3.5 KV

## NOTE

A special FR-PVC or Low Smoke Halogen Free (LSHF)\* Flame Retardant Sheath can be supplied in accordance with IEC 60332-3,  
\*For LSHF : IEC 60754, IEC 61034

CTW-CV	Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
	Nominal Cross-Sectional Area	Number of Wire	Diameter (Approx.)							
PRODUCT CODE	SIZE sq.mm.	sq.mm.	No.	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
C28014501	1 x 1.5	1.5	7:CR	1.56	0.7	1.4	7.5	55	12.10	1,1098
C28014502	1 x 2.5	2.5	7:CR	2.01	0.7	1.4	8.0	70	7.41	0.9229
C28014004	1 x 4	4	7:CR	2.52	0.7	1.4	8.5	90	4.61	0.7762
C28014006	1 x 6	6	7:CR	3.09	0.7	1.4	9.0	115	3.08	0.6598
C28014010	1 x 10	10	7:CR	3.99	0.7	1.4	10.0	160	1.83	0.5340
C28018016	1 x 16	16	7:CP	4.69	0.7	1.4	10.5	215	1.15	0.4636
C28018025	1 x 25	25	7:CP	5.90	0.9	1.4	12.0	315	0.727	0.4612
C28018035	1 x 35	35	7:CP	6.95	0.9	1.4	13.5	420	0.524	0.3996
C28018050	1 x 50	50	19:CP	8.33	1.0	1.4	15.0	575	0.387	0.3704
C28018070	1 x 70	70	19:CP	9.73	1.1	1.4	16.5	775	0.268	0.3482
C28018095	1 x 95	95	19:CP	11.45	1.1	1.5	18.5	1,025	0.193	0.3007
C28018120	1 x 120	120	19:CP	12.95	1.2	1.5	20.0	1,275	0.153	0.2890
C28018150	1 x 150	150	37:CP	14.27	1.4	1.6	22.0	1,585	0.124	0.3014
C28018185	1 x 185	185	37:CP	15.98	1.6	1.6	24.5	1,940	0.0991	0.3047
C28018240	1 x 240	240	37:CP	18.47	1.7	1.7	27.5	2,495	0.0754	0.2813
C28018300	1 x 300	300	61:CP	20.68	1.8	1.8	30.0	3,090	0.0601	0.2664
										500/R

**CONSTRUCTION**

**Conductor** Compact or Round concentric lay stranded copper  
 - CR : Concentric lay stranded of conductor :  $\leq 10$  sq.mm.  
 - CP : Compact round concentric lay stranded of conductor :  $> 10$  sq.mm.

**Insulation** Cross-linked polyethylene (XLPE)

Colour : Natural

**Sheath** Polyvinyl chloride (PVC:ST2)

Optional : Polyethylene (PE:ST7)

Colour : Black

**APPLICATION**

Preferably used for installation exposed or in raceway wet or dry location or direct burial in ground.

**CLASSIFICATION**

Maximum conductor temperature 90°C  
 Circuit voltage does not exceed 1,000 volts.


**REFERENCE**

TIS 2143  
 IEC 60228, IEC 60502-1  
 AC Test Voltage : 3.5 KV

**NOTE**

A special FR-PVC or Low Smoke Halogen Free (LSHF)\* Flame Retardant Sheath can be supplied in accordance with IEC 60332-3,  
 \*For LSHF : IEC 60754, IEC 61034

CTW-CV		Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire No.	Diameter (Approx.) mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
C28018400	1 x 400	400	61:CP	23.39	2.0	1.9	33.5	4,070	0.0470	0.2609	500/R
C28018500	1 x 500	500	61:CP	26.67	2.2	2.0	38.0	5,070	0.0366	0.2513	500/R
C28018630	1 x 630	630	91:CP	30.20	2.4	2.2	42.5	6,370	0.0283	0.2420	300/R
C28018800	1 x 800	800	91:CP	34.00	2.6	2.3	47.0	8,030	0.0221	0.2328	300/R
C28018000	1 x 1000	1000	127:CP	40.00	2.8	2.4	54.0	10,020	0.0176	0.2138	250/R

**CONSTRUCTION**

<b>Conductor</b>	Compact or Round concentric lay stranded copper - CR : Concentric lay stranded of conductor : ≤ 10 sq.mm. - CP : Compact round concentric lay stranded of conductor : > 10 sq.mm.
<b>Insulation</b>	Cross-linked polyethylene (XLPE) Colour : Blue, Brown
<b>Filler</b>	PVC/PE Rod or Polypropylene (Nonhygroscopic material)
<b>Wrapping Tape</b>	Polyester (Mylar) and / or Spunbond tape Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST2) Colour : Black

**APPLICATION**

Preferably used for installation exposed or in raceway wet or dry location or direct burial in ground.

**CLASSIFICATION**

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 1,000 volts.


**REFERENCE**

TIS 2143  
IEC 60228, IEC 60502-1  
AC Test Voltage : 3.5 kV

**NOTE**

A special FR-PVC or Low Smoke Halogen Free (LSHF)\* Flame Retardant Sheath can be supplied in accordance with IEC 60332-3,  
\*For LSHF : IEC 60754, IEC 61034

CTW-CV	Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
	Nominal Cross-Sectional Area	Number of Wire	Diameter (Approx.)							
PRODUCT CODE	SIZE sq.mm.	sq.mm.	No.	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
C28024501	2 x 1.5	1.5	7:CR	1.56	0.7	1.8	11.5	145	12.1	1,1098
C28024502	2 x 2.5	2.5	7:CR	2.01	0.7	1.8	12.5	180	7.41	0.9229
C28024004	2 x 4	4	7:CR	2.52	0.7	1.8	13.5	230	4.61	0.7762
C28024006	2 x 6	6	7:CR	3.09	0.7	1.8	14.5	295	3.08	0.6598
C28024010	2 x 10	10	7:CR	3.99	0.7	1.8	17.0	380	1.83	0.5340
C28028016	2 x 16	16	7:CP	4.69	0.7	1.8	18.5	505	1.15	0.4636
C28028025	2 x 25	25	7:CP	5.90	0.9	1.8	21.5	745	0.727	0.4612
C28028035	2 x 35	35	7:CP	6.95	0.9	1.8	24.0	975	0.524	0.3996
C28028050	2 x 50	50	19:CP	8.33	1.0	1.8	27.0	1,330	0.387	0.3704
C28028070	2 x 70	70	19:CP	9.73	1.1	1.8	30.5	1,785	0.268	0.3482
C28028095	2 x 95	95	19:CP	11.45	1.1	1.9	34.5	2,355	0.193	0.3007
C28028120	2 x 120	120	19:CP	12.95	1.2	2.0	38.0	2,945	0.153	0.2890
C28028150	2 x 150	150	37:CP	14.27	1.4	2.2	42.5	3,665	0.124	0.3014
C28028185	2 x 185	185	37:CP	15.98	1.6	2.3	47.0	4,500	0.0991	0.3047
C28028240	2 x 240	240	37:CP	18.47	1.7	2.5	53.0	5,785	0.0754	0.2813
C28028300	2 x 300	300	61:CP	20.68	1.8	2.6	58.5	7,145	0.0601	0.2664
C28028400	2 x 400	400	61:CP	23.39	2.0	2.9	65.5	9,405	0.0470	0.2609
C = Packing in coil R = Packing in reel										

**CONSTRUCTION**

<b>Conductor</b>	Compact or Round concentric lay stranded copper - CR : Concentric lay stranded of conductor : ≤ 10 sq.mm. - CP : Compact round concentric lay stranded of conductor : > 10 sq.mm.
<b>Insulation</b>	Cross-linked polyethylene (XLPE) Colour : Brown, Black, Grey
<b>Filler</b>	PVC/PE Rod or Polypropylene (Nonhygroscopic material)
<b>Wrapping Tape</b>	Polyester (Mylar) and / or Spunboun tape Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST2) Colour : Black

**APPLICATION**

Preferably used for installation exposed or in raceway wet or dry location or direct burial in ground.

**CLASSIFICATION**

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 1,000 volts.


**REFERENCE**

TIS 2143  
IEC 60228, IEC 60502-1  
AC Test Voltage : 3.5 kV

**NOTE**

A special FR-PVC or Low Smoke Halogen Free (LSHF)\* Flame Retardant Sheath can be supplied in accordance with IEC 60332-3,  
\*For LSHF : IEC 60754, IEC 61034

CTW-CV	Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
	Nominal Cross-Sectional Area	Number of Wire	Diameter (Approx.)							
PRODUCT CODE	SIZE sq.mm.	sq.mm.	No./mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
C28034501	3 x 1.5	1.5	7:CR	1.56	0.7	1.8	12.0	165	12.1	1,1098
C28034502	3 x 2.5	2.5	7:CR	2.01	0.7	1.8	13.0	210	7.41	0.9229
C28034004	3 x 4	4	7:CR	2.52	0.7	1.8	14.0	275	4.61	0.7762
C28034006	3 x 6	6	7:CR	3.09	0.7	1.8	15.5	360	3.08	0.6598
C28034010	3 x 10	10	7:CR	3.99	0.7	1.8	18.0	495	1.83	0.5340
C28038016	3 x 16	16	7:CP	4.69	0.7	1.8	19.5	670	1.15	0.4636
C28038025	3 x 25	25	7:CP	5.90	0.9	1.8	23.0	995	0.727	0.4612
C28038035	3 x 35	35	7:CP	6.95	0.9	1.8	25.5	1,320	0.524	0.3996
C28038050	3 x 50	50	19:CP	8.33	1.0	1.8	29.0	1,820	0.387	0.3704
C28038070	3 x 70	70	19:CP	9.73	1.1	1.9	33.0	2,480	0.268	0.3482
C28038095	3 x 95	95	19:CP	11.45	1.1	2.0	37.0	3,285	0.193	0.3007
C28038120	3 x 120	120	19:CP	12.95	1.2	2.1	41.0	4,110	0.153	0.2890
C28038150	3 x 150	150	37:CP	14.27	1.4	2.3	45.5	5,120	0.124	0.3014
C28038185	3 x 185	185	37:CP	15.98	1.6	2.4	50.5	6,300	0.0991	0.3047
C28038240	3 x 240	240	37:CP	18.47	1.7	2.6	57.0	8,100	0.0754	0.2813
C28038300	3 x 300	300	61:CP	20.68	1.8	2.7	62.5	10,025	0.0601	0.2664
C28038400	3 x 400	400	61:CP	23.39	2.0	3.0	70.5	13,220	0.0470	0.2609

**CONSTRUCTION**

<b>Conductor</b>	Compact or Round concentric lay stranded copper - CR : Concentric lay stranded of conductor : ≤ 10 sq.mm. - CP : Compact round concentric lay stranded of conductor : > 10 sq.mm.
<b>Insulation</b>	Cross-linked polyethylene (XLPE) Colour : Blue, Brown, Black, Grey
<b>Filler</b>	PVC/PE Rod or Polypropylene (Nonhygroscopic material)
<b>Wrapping Tape</b>	Polyester (Mylar) and / or Spunbond tape Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST2) Colour : Black

**APPLICATION**

Preferably used for installation exposed or in raceway wet or dry location or direct burial in ground.

**CLASSIFICATION**

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 1,000 volts.

**REFERENCE**

TIS 2143  
IEC 60228, IEC 60502-1  
AC Test Voltage : 3.5 kV


**NOTE**

A special FR-PVC or Low Smoke Halogen Free (LSHF)\* Flame Retardant Sheath can be supplied in accordance with IEC 60332-3,  
\*For LSHF : IEC 60754, IEC 61034

CTW-CV	Conductor			Thickness of Insulation	Thickness of Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
	PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire No.	Diameter (Approx.) mm					
C28044501	4 x 1.5	1.5	7:CR	1.56	0.7	1.8	13.0	195	12.1	1,1098
C28044502	4 x 2.5	2.5	7:CR	2.01	0.7	1.8	14.0	250	7.41	0.9229
C28044004	4 x 4	4	7:CR	2.52	0.7	1.8	15.0	335	4.61	0.7762
C28044006	4 x 6	6	7:CR	3.09	0.7	1.8	16.5	435	3.08	0.6598
C28044010	4 x 10	10	7:CR	3.99	0.7	1.8	19.5	625	1.83	0.5340
C28048016	4 x 16	16	7:CP	4.69	0.7	1.8	21.0	860	1.15	0.4636
C28048025	4 x 25	25	7:CP	5.90	0.9	1.8	25.0	1,285	0.727	0.4612
C28048035	4 x 35	35	7:CP	6.95	0.9	1.8	28.0	1,715	0.524	0.3996
C28048050	4 x 50	50	19:CP	8.33	1.0	1.8	32.0	2,365	0.387	0.3704
C28048070	4 x 70	70	19:CP	9.73	1.1	2.0	36.5	3,255	0.268	0.3482
C28048095	4 x 95	95	19:CP	11.45	1.1	2.1	41.0	4,315	0.193	0.3007
C28048120	4 x 120	120	19:CP	12.95	1.2	2.3	45.5	5,430	0.153	0.2890
C28048150	4 x 150	150	37:CP	14.27	1.4	2.4	50.5	6,740	0.124	0.3014
C28048185	4 x 185	185	37:CP	15.98	1.6	2.6	56.0	8,310	0.0991	0.3047
C28048240	4 x 240	240	37:CP	18.47	1.7	2.8	63.5	10,700	0.0754	0.2813
C28048300	4 x 300	300	61:CP	20.68	1.8	3.0	70.0	13,275	0.0601	0.2664
C28048400	4 x 400	400	61:CP	23.39	2.0	3.3	78.5	17,515	0.0470	0.2609
										150/R

C = Packing in coil

R = Packing in reel



## CONSTRUCTION

<b>Conductor</b>	Compact or Round concentric lay stranded copper - CR : Concentric lay stranded of conductor : ≤ 10 sq.mm. - CP : Compact round concentric lay stranded of conductor : > 10 sq.mm.
<b>Insulation</b>	Cross-linked polyethylene (XLPE) Colour : Natural
<b>Bedding</b>	Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST7) Colour : Black
<b>Armour</b>	Aluminium Wire (AWA)
<b>Separator Tape</b>	Polyester and/or Spunbond tape
<b>Outer Sheath</b>	Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST7) Colour : Black

## APPLICATION

Preferably used for installation exposed or in raceway wet or dry location or direct burial in ground.

## CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 1,000 volts.


## REFERENCE

TIS 2143  
IEC 60228, IEC 60502-1  
AC Test Voltage : 3.5 kV

## NOTE

A special FR-PVC or Low Smoke Halogen Free (LSHF)\* Flame Retardant Sheath can be supplied in accordance with IEC 60332-3,  
\*For LSHF : IEC 60754, IEC 61034

CTW-CV	Conductor			Thickness of Insulation	Thickness of Bedding	Armour Wire Diameter	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing	
	Product Code	Size sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire	Diameter (Approx.) mm								
C30014501	1 x 1.5	1.5	7:CR	1.56	0.7	1.0	0.90	1.4	11.0	135	12.1	1.1098	1,000/R
C30014502	1 x 2.5	2.5	7:CR	2.01	0.7	1.0	0.90	1.4	11.5	155	7.41	0.9229	1,000/R
C30014004	1 x 4	4	7:CR	2.52	0.7	1.0	0.90	1.4	12.0	180	4.61	0.7762	1,000/R
C30014006	1 x 6	6	7:CR	3.09	0.7	1.0	0.90	1.4	12.5	210	3.08	0.6598	1,000/R
C30014010	1 x 10	10	7:CR	3.99	0.7	1.0	0.90	1.4	13.5	265	1.83	0.5340	1,000/R
C30018016	1 x 16	16	7:CP	4.69	0.7	1.0	0.90	1.4	14.5	330	1.15	0.4636	1,000/R
C30018025	1 x 25	25	7:CP	5.90	0.9	1.0	0.90	1.4	16.0	445	0.727	0.4612	1,000/R
C30018035	1 x 35	35	7:CP	6.95	0.9	1.0	0.90	1.4	17.0	560	0.524	0.3996	1,000/R
C30018050	1 x 50	50	19:CP	8.33	1.0	1.0	1.25	1.5	19.5	770	0.387	0.3704	1,000/R
C30018070	1 x 70	70	19:CP	9.73	1.1	1.0	1.25	1.5	21.0	995	0.268	0.3482	1,000/R
C30018095	1 x 95	95	19:CP	11.45	1.1	1.0	1.25	1.6	23.0	1,265	0.193	0.3007	1,000/R
C30018120	1 x 120	120	19:CP	12.95	1.2	1.0	1.60	1.7	25.5	1,595	0.153	0.2890	1,000/R
C30018150	1 x 150	150	37:CP	14.27	1.4	1.0	1.60	1.7	27.5	1,940	0.124	0.3014	1,000/R
C30018185	1 x 185	185	37:CP	15.98	1.6	1.0	1.60	1.8	30.0	2,325	0.0991	0.3047	1,000/R
C30018240	1 x 240	240	37:CP	18.47	1.7	1.0	1.60	1.9	33.0	2,925	0.0754	0.2813	500/R
C30018300	1 x 300	300	61:CP	20.68	1.8	1.0	1.60	1.9	35.5	3,560	0.0601	0.2664	500/R



## CONSTRUCTION

<b>Conductor</b>	Compact or Round concentric lay stranded copper - CR : Concentric lay stranded of conductor : ≤ 10 sq.mm. - CP : Compact round concentric lay stranded of conductor : > 10 sq.mm.
<b>Insulation</b>	Cross-linked polyethylene (XLPE) Colour : Natural
<b>Bedding</b>	Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST7) Colour : Black
<b>Armour</b>	Aluminium Wire (AWA)
<b>Separator Tape</b>	Polyester and/or Spunbond tape
<b>Outer Sheath</b>	Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST7) Colour : Black

## APPLICATION

Preferably used for installation exposed or in raceway wet or dry location or direct burial in ground.

## CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 1,000 volts.


## REFERENCE

TIS 2143  
IEC 60228, IEC 60502-1  
AC Test Voltage : 3.5 KV

## NOTE

A special FR-PVC or Low Smoke Halogen Free (LSHF)\* Flame Retardant Sheath can be supplied in accordance with IEC 60332-3,  
\*For LSHF : IEC 60754, IEC 61034

CTW-CV	Conductor			Thickness of Insulation	Thickness of Bedding	Armour Wire Diameter	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
	PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire	Diameter (Approx.) mm							
C30018400	1 x 400	400	61:CP	23.39	2.0	1.2	2.00	2.1	40.5	4,725	0.0470	0.2609
C30018500	1 x 500	500	61:CP	26.67	2.2	1.2	2.00	2.2	45.0	5,815	0.0366	0.2513
C30018630	1 x 630	630	91:CP	30.20	2.4	1.2	2.00	2.3	49.0	7,175	0.0283	0.2420
C30018800	1 x 800	800	91:CP	34.00	2.6	1.4	2.50	2.5	55.5	9,155	0.0221	0.2328
C30018000	1 x 1000	1000	127:CP	40.00	2.8	1.4	2.50	2.7	62.5	11,300	0.0176	0.2138



## CONSTRUCTION

<b>Conductor</b>	Compact or Round concentric lay stranded copper - CR : Concentric lay stranded of conductor : ≤ 10 sq.mm. - CP : Compact round concentric lay stranded of conductor : > 10 sq.mm.
<b>Insulation</b>	Cross-linked polyethylene (XLPE) Colour : Blue, Brown
<b>Bedding</b>	Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST7) Colour : Black
<b>Armour</b>	Galvanized Steel Wire (SWA)
<b>Separator Tape</b>	Polyester and/or Spunbond tape
<b>Outer Sheath</b>	Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST7) Colour : Black

## APPLICATION

Preferably used for installation exposed or in raceway wet or dry location or direct burial in ground.

## CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 1,000 volts.


## REFERENCE

TIS 2143  
IEC 60228, IEC 60502-1  
AC Test Voltage : 3.5 KV

## NOTE

A special FR-PVC or Low Smoke Halogen Free (LSHF)\* Flame Retardant Sheath can be supplied in accordance with IEC 60332-3,  
\*For LSHF : IEC 60754, IEC 61034

CTW-CV-SWA	Conductor			Thickness of Insulation	Thickness of Bedding	Armour Wire Diameter	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
	PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number and Dia. of Wire No./mm	Diameter (Approx.) mm							
C31024501	2 x 1.5	1.5	7:CR	1.56	0.7	1.0	0.90	1.8	15.0	370	12.1	1.1098
C31024502	2 x 2.5	2.5	7:CR	2.01	0.7	1.0	0.90	1.8	16.0	420	7.41	0.9229
C31024004	2 x 4	4	7:CR	2.52	0.7	1.0	0.90	1.8	17.0	495	4.61	0.7762
C31024006	2 x 6	6	7:CR	3.09	0.7	1.0	0.90	1.8	18.0	585	3.08	0.6598
C31024010	2 x 10	10	7:CR	3.99	0.7	1.0	1.25	1.8	21.5	835	1.83	0.5340
C31028016	2 x 16	16	7:CP	4.69	0.7	1.0	1.25	1.8	22.5	995	1.15	0.4636
C31028025	2 x 25	25	7:CP	5.90	0.9	1.0	1.60	1.8	27.0	1,470	0.727	0.4612
C31028035	2 x 35	35	7:CP	6.95	0.9	1.0	1.60	1.8	29.0	1,775	0.524	0.3996
C31028050	2 x 50	50	19:CP	8.33	1.0	1.0	1.60	1.8	32.5	2,245	0.387	0.3704
C31028070	2 x 70	70	19:CP	9.73	1.1	1.0	1.60	2.0	36.0	2,825	0.268	0.3482
C31028095	2 x 95	95	19:CP	11.45	1.1	1.2	2.00	2.1	41.0	3,840	0.193	0.3007
C31028120	2 x 120	120	19:CP	12.95	1.2	1.2	2.00	2.2	45.0	4,600	0.153	0.2890
C31028150	2 x 150	150	37:CP	14.27	1.4	1.2	2.00	2.3	49.0	5,455	0.124	0.3014
C31028185	2 x 185	185	37:CP	15.98	1.6	1.4	2.50	2.5	55.0	6,980	0.0991	0.3047
C31028240	2 x 240	240	37:CP	18.47	1.7	1.4	2.50	2.7	61.5	8,590	0.0754	0.2813
C31028300	2 x 300	300	61:CP	20.68	1.8	1.6	2.50	2.8	67.5	10,310	0.0601	0.2664
C31028400	2 x 400	400	61:CP	23.39	2.0	1.6	2.50	3.1	74.5	12,880	0.0470	0.2609
												200/R



## CONSTRUCTION

<b>Conductor</b>	Compact or Round concentric lay stranded copper - CR : Concentric lay stranded of conductor : ≤ 10 sq.mm. - CP : Compact round concentric lay stranded of conductor : > 10 sq.mm.
<b>Insulation</b>	Cross-linked polyethylene (XLPE) Colour : Brown, Black, Grey
<b>Bedding</b>	Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST7) Colour : Black
<b>Armour</b>	Galvanized Steel Wire (SWA)
<b>Separator Tape</b>	Polyester and/or Spunbond tape
<b>Outer Sheath</b>	Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST7) Colour : Black

## APPLICATION

Preferably used for installation exposed or in raceway wet or dry location or direct burial in ground.

## CLASSIFICATION

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 1,000 volts.

## REFERENCE

TIS 2143  
IEC 60228, IEC 60502-1  
AC Test Voltage : 3.5 KV


## NOTE

A special FR-PVC or Low Smoke Halogen Free (LSHF)\* Flame Retardant Sheath can be supplied in accordance with IEC 60332-3,  
\*For LSHF : IEC 60754, IEC 61034

CTW-CV-SWA		Conductor			Thickness of Insulation	Thickness of Bedding	Armour Wire Diameter	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire	Diameter (Approx.) mm	mm	mm	mm	mm	mm	kg/km	Ω/km	MΩ-km	m
C31034501	3 x 1.5	1.5	7:CR	1.56	0.7	1.0	0.90	1.8	15.5	400	12.1	1.1098	1,000/R
C31034502	3 x 2.5	2.5	7:CR	2.01	0.7	1.0	0.90	1.8	16.5	465	7.41	0.9229	1,000/R
C31034004	3 x 4	4	7:CR	2.52	0.7	1.0	0.90	1.8	18.0	555	4.61	0.7762	1,000/R
C31034006	3 x 6	6	7:CR	3.09	0.7	1.0	0.90	1.8	19.0	665	3.08	0.6598	1,000/R
C31034010	3 x 10	10	7:CR	3.99	0.7	1.0	1.25	1.8	22.5	970	1.83	0.5340	1,000/R
C31038016	3 x 16	16	7:CP	4.69	0.7	1.0	1.25	1.8	24.0	1,185	1.15	0.4636	1,000/R
C31038025	3 x 25	25	7:CP	5.90	0.9	1.0	1.60	1.8	28.0	1,760	0.727	0.4612	1,000/R
C31038035	3 x 35	35	7:CP	6.95	0.9	1.0	1.60	1.8	30.5	2,175	0.524	0.3996	1,000/R
C31038050	3 x 50	50	19:CP	8.33	1.0	1.0	1.60	1.9	34.5	2,790	0.387	0.3704	1,000/R
C31038070	3 x 70	70	19:CP	9.73	1.1	1.2	2.00	2.0	39.5	3,880	0.268	0.3482	500/R
C31038095	3 x 95	95	19:CP	11.45	1.1	1.2	2.00	2.2	43.5	4,860	0.193	0.3007	500/R
C31038120	3 x 120	120	19:CP	12.95	1.2	1.2	2.00	2.3	48.0	5,840	0.153	0.2890	500/R
C31038150	3 x 150	150	37:CP	14.27	1.4	1.4	2.50	2.5	53.5	7,510	0.124	0.3014	250/R
C31038185	3 x 185	185	37:CP	15.98	1.6	1.4	2.50	2.6	59.0	8,990	0.0991	0.3047	250/R
C31038240	3 x 240	240	37:CP	18.47	1.7	1.6	2.50	2.8	65.5	11,145	0.0754	0.2813	250/R
C31038300	3 x 300	300	61:CP	20.68	1.8	1.6	2.50	3.0	71.5	13,425	0.0601	0.2664	200/R
C31038400	3 x 400	400	61:CP	23.39	2.0	1.6	2.50		79.5	17,005	0.0470	0.2609	150/R

C = Packing in coil

R = Packing in reel

**CONSTRUCTION**

<b>Conductor</b>	Compact or Round concentric lay stranded copper - CR : Concentric lay stranded of conductor : ≤ 10 sq.mm. - CP : Compact round concentric lay stranded of conductor : > 10 sq.mm.
<b>Insulation</b>	Cross-linked polyethylene (XLPE) Colour : Blue, Brown, Black, Grey
<b>Bedding</b>	Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST7) Colour : Black
<b>Armour</b>	Galvanized Steel Wire (SWA)
<b>Separator Tape</b>	Polyester and/or Spunbond tape
<b>Outer Sheath</b>	Polyvinyl chloride (PVC:ST2) Optional : Polyethylene (PE:ST7) Colour : Black

**APPLICATION**

Preferably used for installation exposed or in raceway wet or dry location or direct burial in ground.

**CLASSIFICATION**

Maximum conductor temperature 90°C  
Circuit voltage does not exceed 1,000 volts.

**REFERENCE**

TIS 2143  
IEC 60228, IEC 60502-1  
AC Test Voltage : 3.5 KV

**NOTE**

A special FR-PVC or Low Smoke Halogen Free (LSHF)\* Flame Retardant Sheath can be supplied in accordance with IEC 60332-3,  
\*For LSHF : IEC 60754, IEC 61034

CTW-CV-SWA	Conductor			Thickness of Insulation	Thickness of Bedding	Armour Wire Diameter	Thickness of Outer Sheath	Overall Diameter (Approx.)	Cable Weight (Approx.)	Maximum Conductor Resistance at 20°C	Minimum Insulation Resistance at 90°C	Standard Packing
	PRODUCT CODE	SIZE sq.mm.	Nominal Cross-Sectional Area sq.mm.	Number of Wire	Diameter (Approx.) mm							
C31044501	4 x 1.5	1.5	7:CR	1.56	0.7	1.0	0.90	1.8	16.5	445	12.1	1.1098
C31044502	4 x 2.5	2.5	7:CR	2.01	0.7	1.0	0.90	1.8	17.5	530	7.41	0.9229
C31044004	4 x 4	4	7:CR	2.52	0.7	1.0	0.90	1.8	19.0	640	4.61	0.7762
C31044006	4 x 6	6	7:CR	3.09	0.7	1.0	1.25	1.8	21.0	880	3.08	0.6598
C31044010	4 x 10	10	7:CR	3.99	0.7	1.0	1.25	1.8	24.0	1,140	1.83	0.5340
C31048016	4 x 16	16	7:CP	4.69	0.7	1.0	1.60	1.8	26.5	1,565	1.15	0.4636
C31048025	4 x 25	25	7:CP	5.90	0.9	1.0	1.60	1.8	30.5	2,125	0.727	0.4612
C31048035	4 x 35	35	7:CP	6.95	0.9	1.0	1.60	1.9	33.0	2,645	0.524	0.3996
C31048050	4 x 50	50	19:CP	8.33	1.0	1.0	1.60	2.0	37.5	3,450	0.387	0.3704
C31048070	4 x 70	70	19:CP	9.73	1.1	1.2	2.00	2.2	43.0	4,800	0.268	0.3482
C31048095	4 x 95	95	19:CP	11.45	1.1	1.2	2.00	2.3	47.5	6,045	0.193	0.3007
C31048120	4 x 120	120	19:CP	12.95	1.2	1.4	2.50	2.5	54.0	7,800	0.153	0.2890
C31048150	4 x 150	150	37:CP	14.27	1.4	1.4	2.50	2.6	59.0	9,430	0.124	0.3014
C31048185	4 x 185	185	37:CP	15.98	1.6	1.4	2.50	2.8	64.5	11,255	0.0991	0.3047
C31048240	4 x 240	240	37:CP	18.47	1.7	1.6	2.50	3.0	72.0	14,075	0.0754	0.2813
C31048300	4 x 300	300	61:CP	20.68	1.8	1.6	2.50	3.2	79.0	16,980	0.0601	0.2664
C31048400	4 x 400	400	61:CP	23.39	2.0	1.8	3.15	3.5	89.5	22,745	0.0470	0.2609


CHAROONG THAI WIRE & CABLE  
PUBLIC COMPANY LIMITED



# TECHNICAL DATA & GENERAL INFORMATION

Table 5-8 : Correction factor for groups of more than one circuit

Group of circuit	Correction factor
2	0.80
3	0.70
4	0.65
5	0.60
6	0.57
7	0.54
8	0.52
9	0.50
10-12	0.45
13-16	0.41
17-20	0.38



CT ELECTRIC SUPPLY CO., LTD.

**Note (Table 5-8)**

- 1) These factors are applicable to uniform groups of cables, equally loaded.
- 2) The correction factor are applied to:
- groups of two or three or four Single core cables
  - multi cores cables.
- 3) If a system consists of both two or three or four cables, the total number of cables is taken as the number of circuits, and the correction factor is applied to the table for two or three or four loaded conductors for the two or three or four core cables respectively.
- 4) If a group consists of n Single core cables it may either be considered as  $n/2$  circuits of two loaded conductor or  $n/3$  circuits of three loaded conductor.

โทร : 02 550 9555



# CHAROONG THAI WIRE & CABLE PUBLIC COMPANY LIMITED

**Table 5-20 :** Current-carrying capacities in amperes for copper conductor, PVC insulated, with or without sheathed for rated voltage 0.6/1 kV, conductor temperature 70°C / ambient temperature 40°C in conduit

	Group for installation method : Group 1				Group for installation method : Group 2			
	2		3		2		3	
No. of conductor	Single core	Multi cores	Single core	Multi cores	Single core	Multi cores	Single core	Multi cores
Single / Multi cores	Single core	Multi cores	Single core	Multi cores	Single core	Multi cores	Single core	Multi cores
Installation methods								
Type of cable	60227 IEC 01, 60227 IEC 02, 60227 IEC 05, 60227 IEC 06, 60227 IEC 10, NYY, NYY-G, VCT, VCT-G, IEC 60502-1 and special cable such as flame retardant (FR), low smoke and halogen free (LSHF) etc.							
Size (sq.mm.)	Current-carrying capacities (amperes)							
1	10	10	9	9	12	11	10	10
1.5	13	12	12	11	15	14	13	13
2.5	17	16	16	15	21	20	18	17
4	23	22	21	20	28	26	24	23
6	30	28	27	25	36	33	31	30
10	40	37	37	34	50	45	44	40
16	53	50	49	45	66	60	59	54
25	70	65	64	59	88	78	77	70
35	86	80	77	72	109	97	96	86
50	104	96	94	86	131	116	117	103
70	131	121	118	109	167	146	149	130
95	158	145	143	131	202	175	180	156
120	183	167	164	150	234	202	208	179
150	209	191	188	171	261	224	228	196
185	238	216	213	194	297	256	258	222
240	279	253	249	227	348	299	301	258
300	319	291	285	259	398	343	343	295
400	-	-	-	-	475	-	406	-
500	-	-	-	-	545	-	464	-

### Note (Table 5-20)

- Where the ambient temperature in the intended location of the cable differs from 40°C (reference ambient temperature), the correction factor given in Table 5-43.
- If installation more than 1 circuit in single conduit , the correction factor given in Table 5-8.
- Installation method given in Table 5-47.
- Type of cable given in Table 5-48.

**Table 5-21 :** Current-carrying capacities in amperes for copper insulated conductor with sheathed for rated voltage 0.6/1 kV, conductor temperature 70°C or 90°C / ambient temperature 40°C on wall

	Group for installation method : Group 3				
No. of conductor	2	Not more than 3		Not more than 3	
Type of cable	Flat	Round		Round	
Single / Multi cores	Multi cores	Single core		Multi cores	
Type of insulation	PVC	PVC	XLPE	PVC	XLPE
Conductor temperature	70°C	70°C	90°C	70°C	90°C
Installation methods		 or 		 or 	
Type of cable	VAF, VAF-G	NYY, IEC 60502-1	IEC 60502-1	NYY, NYG, 60227 IEC 10, IEC 60502-1	IEC 60502-1
Size (sq.mm.)	Current-carrying capacities (amperes)				
1	14	12	16	12	15
1.5	17	16	21	15	20
2.5	23	22	28	21	27
4	32	29	37	28	36
6	41	37	49	36	47
10	56	51	67	50	65
16	74	69	90	66	87
25	-	90	118	84	108
35	-	112	147	104	134
50	-	145	190	125	163
70	-	186	244	160	208
95	-	227	297	194	253
120	-	264	345	225	293
150	-	304	397	260	338
185	-	348	455	297	386
240	-	411	537	351	455
300	-	474	620	404	524
400	-	552	722	-	-
500	-	629	823	-	-

#### Note (Table 5-21)

- Where the ambient temperature in the intended location of the cable differs from 40°C (reference ambient temperature), the correction factor given in Table 5-43
- Installation method given in Table 5-47
- Type of cable given in Table 5-48





**Table 5-22 :** Current-carrying capacities in amperes accordance TIS 11-2553 for copper conductor, PVC insulated for rated voltage 450/750 V, conductor temperature 70°C / ambient temperature 40°C on insulator

		Group for installation method : Group 4	
Installation methods			
Type of cable	60227 IEC 01, 60227 IEC 10, NYY		
Size (sq.mm.)	Current-carrying capacities (amperes)		
4	30		
6	39		
10	56		
16	78		
25	113		
35	141		
50	171		
70	221		
95	271		
120	315		
150	365		
185	418		
240	495		
300	573		
400	692		

#### Note (Table 5-22)

- 1) Installation method given in Table 5-47
- 2) Type of cable given in Table 5-48

**Table 5-23 :** Current-carrying capacities in amperes for copper conductor, PVC insulated with sheathed for rated voltage 0.6/1 kV, conductor temperature 70°C / ambient temperature 30°C in duct in the ground or direct buria

	Group for installation method : Group 5		Group for installation method : Group 6	
No. of conductor	2	3	Not more than 3	
Type of cable	Single core and Multi cores	Single core and Multi cores	Single core and Multi cores	
Installation methods				
Type of cable	NYY, NYY-G, IEC 60502-1			
Size (sq.mm.)	Current-carrying capacities (amperes)			
1	17	15	21	
1.5	21	19	26	
2.5	28	25	35	
4	36	33	45	
6	46	41	57	
10	62	55	76	
16	81	72	99	
25	106	94	128	
35	129	114	154	
50	153	136	181	
70	190	168	223	
95	232	204	267	
120	265	234	304	
150	303	266	342	
185	344	303	386	
240	404	361	448	
300	462	404	507	
400	529	462	577	
500	605	527	654	

#### Note (Table 5-23)

- 1) Where the ambient temperature in the intended location of the cable differs from 30°C (reference ambient temperature), the correction factor given in Table 5-44
- 2) If installation more than 1 circuit, the correction factor given in table 5-45 or 5-46.
- 3) If installation more than 1 circuit in single conduit, the correction factor given in Table 5-8.
- 4) Installation method given in Table 5-47.
- 5) Type of cable given in Table 5-48.

**Table 5-24 :** Current-carrying capacities in amperes accordance TIS 11-2553 for copper conductor, PVC insulated for rated voltage 300/500 V, conductor temperature 70°C or 90°C / ambient temperature 40°C in free air

Conductor Temperature	70°C	90°C
Type of cable	60227 IEC 05, 60227 IEC 06	60227 IEC 07, 60227 IEC 08
Size (sq.mm.)	Current-carrying capacities (amperes)	
0.5	3	3
0.75	6	6
1	10 <sup>2)</sup>	10
1.5	-	16
2.5	-	25

#### Note (Table 5-24)

- 1) Where the ambient temperature in the intended location of the cable differs from 40°C (reference ambient temperature), the correction factor given in below table.

#### - For insulated with PVC 70°C.

Ambient Temperature (Degree celsius)	31-35	36-40	41-45	46-50	51-55
Correction factor	1.11	1.00	0.87	0.71	0.50

โทร : 02 550 9555

#### - For insulated with PVC 90°C.

Ambient Temperature (Degree celsius)	31-50	51-55	56-60	61-65	66-70
Correction factor	1.00	0.96	0.83	0.67	0.47

- 2) Current-carrying capacities for 60227 IEC 06 only.

- 3) Type of cable given in Table 5-48.

**Table 5-25 :** Current-carrying capacities in amperes accordance TIS 11-2553 for flexible copper conductor, PVC insulated for rated voltage 300/500 V, conductor temperature 70°C or 90°C / ambient temperature 40°C in free air

No. of conductor	2	3
Type of cable	60227 IEC 52 , 60227 IEC 53 , 60227 IEC 56 , 60227 IEC 57	
Size (sq.mm.)	Current-carrying capacities (amperes)	
0.5	3	3
0.75	6	6
1	10	10
1.5	16	16
2.5	25	20

#### Note (Table 5-25)

- 1) Where the ambient temperature in the intended location of the cable differs from 40°C (reference ambient temperature), the correction factor given in below table.

#### - For insulated with PVC 70°C.

Ambient Temperature (Degree celsius)	31-35	36-40	41-45	46-50	51-55
Correction factor	1.11	1.00	0.87	0.71	0.50

โทร : 02 550 9555

#### - For insulated with PVC 90°C.

Ambient Temperature (Degree celsius)	31-50	51-55	56-60	61-65	66-70
Correction factor	1.00	0.96	0.83	0.67	0.47

- 2) Type of cable given in Table 5-48.

**Table 5-26 :** Current-carrying capacities in amperes accordance TIS 11-2553 for flexible copper conductor, PVC insulated for rated voltage 450/750 V, conductor temperature 70°C / ambient temperature 40°C in free air

No./Type of conductor	Single core 2 wires or 2 cores with or without ground	3 , 4 , 5 Cores
Type of cable	60227 IEC 02 , VCT , VCT-G	VCT , VCT-G
Size (sq.mm.)	Current-carrying capacities (amperes)	
1.5	16	-
2.5	25	-
4	30	26
6	39	34
10	51	47
16	73	63
25	97	83
35	140	102
50	175	-
70	216	-
95	258	-
120	302	-
150	347	-
185	394	-
240	471	-

#### Note (Table 5-26)

- Where the ambient temperature in the intended location of the cable differs from 40°C (reference ambient temperature), the correction factor given in below table.

Ambient Temperature (Degree celsius)	31-35	36-40	41-45	46-50	51-55
Correction factor	1.11	1.00	0.87	0.71	0.50

- Type of cable given in Table 5-48.



# CHAROONG THAI WIRE & CABLE PUBLIC COMPANY LIMITED



**Table 5-27 :** Current-carrying capacities in amperes for copper conductor, XLPE insulated, with sheathed for rated voltage 0.6/1 kV, conductor temperature 90°C / ambient temperature 40°C in conduit

	Group for installation method : Group 1				Group for installation method : Group 2			
No. of conductor	2		3		2		3	
Single / Multi cores	Single core	Multi cores	Single core	Multi cores	Single core	Multi cores	Single core	Multi cores
Installation methods								
Type of cable	IEC 60502-1 and special cable such as flame retardant (FR), low smoke and halogen free (LSHF) etc.							
Size (sq.mm.)	Current-carrying capacities (amperes)							
1	13	13	12	12	15	15	14	14
1.5	17	17	15	15	21	20	18	18
2.5	24	23	21	20	28	27	25	24
4	32	30	28	27	38	36	34	32
6	41	38	36	35	49	46	44	40
10	56	52	49	46	68	63	60	55
16	74	69	66	62	91	83	80	73
25	96	90	86	81	121	108	106	96
35	119	110	106	99	149	133	131	116
50	144	132	128	118	180	159	159	140
70	182	167	163	149	230	201	202	177
95	219	200	197	179	278	241	245	212
120	253	230	227	207	322	278	284	244
150	289	264	259	236	358	304	311	273
185	329	299	295	268	409	349	349	309
240	386	351	346	315	480	418	410	362
300	442	402	396	360	549	484	468	414
400	-	-	-	-	622	-	531	-
500	-	-	-	-	713	-	606	-

### Note (Table 5-27)

- 1) Where the ambient temperature in the intended location of the cable differs from 40°C (reference ambient temperature), the correction factor given in Table 5-43.
- 2) If installation more than 1 circuit in single conduit , the correction factor given in Table 5-8.
- 3) Installation method given in Table 5-47.
- 4) Type of cable given in Table 5-48.





**Table 5-28 :** Current-carrying capacities in amperes for copper conductor, XLPE insulated for rated voltage 0.6/1 kV, conductor temperature 90°C / ambient temperature 40°C on insulator

	Group for installation method : Group 4				
Installation methods		or		or	
Type of cable	IEC 60502-1				
Size (sq.mm.)	Current-carrying capacities (amperes)				
4	47				54
6	60				68
10	82				90
16	110				124
25	147				166
35	183				206
50	224				250
70	289				321
95	354				391
120	413				455
150	480				525
185	551	โทร : 02 550 9555			602
240	654				711
300	758				821
400	917				987
500	1064				1140

#### Note (Table 5-28)

- 1) Installation method given in Table 5-47.

**Table 5-29 :** Current-carrying capacities in amperes for copper conductor, XLPE insulated for rated voltage 0.6/1 kV, conductor temperature 90°C / ambient temperature 30°C in duct in the ground or direct burial

	Group for installation method : Group 5		Group for installation method : Group 6	
No. of conductor	2	3	Not more than 3	
Type of cable	Single core and Multi cores	Single core and Multi cores	Single core and Multi cores	
Installation methods				
Type of cable	IEC 60502-1			
Size (sq.mm.)	Current-carrying capacities (amperes)			
1.5	25	22	33	
2.5	33	29	43	
4	43	38	55	
6	54	47	70	
10	71	63	92	
16	94	83	119	
25	124	109	152	
35	150	132	184	
50	180	159	217	
70	223	196	266	
95	271	238	318	
120	313	275	362	
150	355	312	406	
185	406	356	459	
240	477	418	533	
300	543	475	601	
400	625	545	684	
500	717	623	777	

#### Note (Table 5-29)

- 1) Where the ambient temperature in the intended location of the cable differs from 30°C (reference ambient temperature), the correction factor given in Table 5-44
- 2) If installation more than 1 circuit, the correction factor given in table 5-45 or 5-46.
- 3) If installation more than 1 circuit in single conduit, the correction factor given in Table 5-8.
- 4) Installation method given in Table 5-47.
- 5) Type of cable given in Table 5-48.

**Table 5-30 :** Current-carrying capacities in amperes for copper conductor, PVC insulated, with sheathed for rated voltage 0.6/1 kV, conductor temperature 70°C / ambient temperature 40°C install in perforated trays or ladder cleats

		Group for installation method : Group 7			
Single / Multi cores		Single core			Multi cores
Installation methods					
	Type of cable	60227 IEC 10, NY, NY-G and special cable flame retardant (FR), low smoke and halogen free (LSHF) etc.			
Size (sq.mm.)		Current-carrying capacities (amperes)			
1	-	-	-	-	13
1.5	-	-	-	-	16
2.5	-	-	-	-	22
4	-	-	-	-	30
6	-	-	-	-	37
10	-	-	-	-	52
16	-	-	-	-	70
25	99	96	127	113	88
35	124	119	157	141	110
50	151	145	191	171	133
70	196	188	244	221	171
95	239	230	297	271	207
120	279	268	345	315	240
150	324	310	397	365	278
185	371	356	453	418	317
240	441	422	535	495	374
300	511	488	617	573	432
400	599	571	741	692	-
500	686	652	854	800	-

#### Note (Table 5-30)

- Where the ambient temperature in the intended location of the cable differs from 40°C (reference ambient temperature), the correction factor given in Table 5-43.
- If installation more than 1 circuit, the correction factor given in table 5-40 or 5-41 for Single core and Multi cores respectively.
- Installation method given in Table 5-47.
- Type of cable given in Table 5-48.

**Table 5-31 :** Current-carrying capacities in amperes for copper conductor, PVC insulated with sheathed for rated voltage 0.6/1 kV, conductor temperature 70°C / ambient temperature 40°C install in ventilated or unventilated cable channel

		Group for installation method : Group 7		
Single / Multi cores		Single core	Multi cores	
Installation methods		     		
Type of cable	60227 IEC 10, NYY, NYY-G, IEC 60502-1 and special cable flame retardant (FR), low smoke and halogen free (LSHF) etc.			
Size (sq.mm.)	Current-carrying capacities (amperes)			
1	-	-	12	10
1.5	-	-	15	13
2.5	-	-	21	17
4	-	-	28	23
6	-	-	36	30
10	-	-	50	40
16	-	-	66	54
25	90	77	84	70
35	112	96	104	86
50	145	117	125	103
70	186	149	160	130
95	227	180	194	156
120	264	208	225	179
150	304	228	260	196
185	348	258	297	222
240	411	301	351	258
300	474	343	404	295
400	552	406	-	-
500	629	464	-	-

#### Note (Table 5-31)

- Where the ambient temperature in the intended location of the cable differs from 40°C (reference ambient temperature), the correction factor given in Table 5-43.
- If number of conductor more than 1 circuit for install in ventilated, correction factor given in table 5-8 and table 5-41 for install in unventilated.

**Exception : If spacing for circuit more than two time of cable diameter, the correction factor do not apply.**

**Table 5-32 :** Current-carrying capacities in amperes for copper conductor, XLPE insulated with sheathed for rated voltage 0.6/1 kV, conductor temperature 90°C / ambient temperature 40°C install in perforated trays or ladder cleats

		Group for installation method : Group 7			
Single / Multi cores	Single core			Multi cores	
Installation methods					
Type of cable	IEC 60502-1 and special cable flame retardant (FR), low smoke and halogen free (LSHF) etc.				
Size (sq.mm.)	Current-carrying capacities (amperes)				
1	-	-	-	-	16
1.5	-	-	-	-	21
2.5	-	-	-	-	29
4	-	-	-	-	38
6	-	-	-	-	49
10	-	-	-	-	68
16	-	-	-	-	91
25	128	123	166	147	116
35	160	154	206	183	144
50	197	188	250	224	175
70	254	244	321	289	224
95	311	298	391	354	271
120	364	349	455	413	315
150	422	404	525	480	363
185	485	464	602	551	415
240	577	552	711	654	490
300	670	640	821	758	565
400	790	749	987	917	-
500	908	861	1,140	1,064	-

#### Note (Table 5-32)

- Where the ambient temperature in the intended location of the cable differs from 40°C (reference ambient temperature), the correction factor given in Table 5-43.
- If installation more than 1 circuit , the correction factor given in table 5-40 or 5-41 for Single core and Multi cores respectively.
- Installation method given in Table 5-47.

**Table 5-33 :** Current-carrying capacities in amperes for copper conductor, XLPE insulated with sheathed for rated voltage 0.6/1 kV, conductor temperature 90°C / ambient temperature 40°C install in ventilated / unventilated cable channel

		Group for installation method : Group 7		
Single / Multi cores		Single core	Multi cores	
Installation methods		     		
Type of cable	IEC 60502-1 and special cable flame retardant (FR), low smoke and halogen free (LSHF) etc.			
Size (sq.mm.)	Current-carrying capacities (amperes)			
1	-	-	15	14
1.5	-	-	20	18
2.5	-	-	27	24
4	-	-	36	32
6	-	-	47	40
10	-	-	65	55
16	-	-	87	73
25	118	106	108	96
35	147	131	134	116
50	190	159	163	140
70	244	202	208	177
95	297	245	253	212
120	345	284	293	244
150	397	311	338	273
185	455	349	386	309
240	537	410	455	362
300	620	468	524	414
400	722	531	-	-
500	823	606	-	-

#### Note (Table 5-33)

- Where the ambient temperature in the intended location of the cable differs from 40°C (reference ambient temperature), the correction factor given in Table 5-43.
- If number of conductor more than 1 circuit for install in ventilated, correction factor given in table 5-8 and table 5-41 for install in unventilated.

**Exception : If spacing for circuit more than two time of cable diameter, the correction factor do not apply.**

**Table 5-40 : The correction factor for groups more than one circuit for Single core cable install on tray**

Installation method	No. of cable tray	Number of circuit per cable tray						
		1	2	3	4	5-6	7-9	
Perforated tray (note2)	1	1.00	0.91	0.87	0.82	0.78	0.77	Cable in horizontal formation
	2	0.96	0.87	0.81	0.78	0.74	0.69	
	3	0.95	0.85	0.78	0.75	0.70	0.65	
Vertical perforated trays (note 3)	1	1.00	0.86	0.80	0.75	0.71	0.70	Cable in vertical formation
	2	0.95	0.84	0.77	0.72	0.67	0.66	
Ladder cleats (note2)	1	1.00	0.97	0.96	0.94	0.93	0.92	Cable in horizontal formation
	2	0.98	0.93	0.89	0.88	0.86	0.83	
	3	0.97	0.90	0.86	0.83	0.80	0.77	
Perforated tray (note2)	1	1.00	0.98	0.96	0.93	0.89	-	
	2	0.97	0.93	0.89	0.85	0.80	-	
	3	0.96	0.92	0.86	0.82	0.76	-	
Vertical perforated trays (note 3)	1	1.00	0.91	0.89	0.88	0.87	-	Cable in trefoil formation space between circuit more than 2 time of cable diameter
	2	1.00	0.90	0.86	0.85	0.83	-	
Ladder cleats (note2)	1	1.00	1.00	1.00	1.00	1.00	-	
	2	0.97	0.95	0.93	0.92	0.91	-	
	3	0.96	0.94	0.90	0.89	0.86	-	

**Table 5-40 : The correction factor for groups more than one circuit for Single core cable install on tray**

Installation method	No. of cable tray	Number of circuit per cable tray						
		1	2	3	4	5-6	7-9	
Perforated tray (note2)	1	1.00	0.93	0.9	0.87	0.83	-	Spacing between cable not less than diameter of cable
	2	0.97	0.89	0.85	0.81	0.76	-	
	3	0.96	0.88	0.82	0.78	0.72	-	
Vertical perforated trays (note 3)	1	1.00	0.91	0.89	0.88	0.87	-	
	2	0.94	0.90	0.86	0.85	0.83	-	
Ladder cleats (note2)	1	1.00	0.97	0.96	0.96	0.96	-	
	2	0.97	0.94	0.93	0.92	0.91	-	
	3	0.96	0.93	0.92	0.91	0.88	-	

#### Note (Table 5-40)

- 1) Factors are given for single layer of cables (or trefoil groups) only as shown in table and do not apply when cables are installed in more than one layer touching each other.
- 2) Values are given for vertical spacing between trays of at least 300 mm. and at least 20 mm. between the trays and any wall only.
- 3) Values are given for horizontal spacing between trays of at least 225 mm. with trays mounted back to back only.
- 4) For trays having more than one circuit, the correction factor should be considered as a maximum circuit in tray.

**Table 5-41 : The correction factor for groups more than one circuit for Multi cores cable install on perforated or unperforated tray or ladder cleats**

Installation method	No. of tray	Number of cable tray						
		1	2	3	4	5-6	7-9	
Perforated tray (note2)	1	1.00	0.88	0.82	0.77	0.73	0.72	
	2	1.00	0.87	0.8	0.77	0.73	0.68	
	3	1.00	0.86	0.79	0.76	0.71	0.66	
	4-6	1.00	0.84	0.77	0.73	0.68	0.64	
	1	1.00	1.00	0.98	0.95	0.91	-	
	2	1.00	0.99	0.96	0.92	0.87	-	
	3	1.00	0.98	0.95	0.91	0.85	-	
Vertical perforated trays (note 3)	1	1.00	0.88	0.82	0.77	0.73	0.72	
	2	1.00	0.88	0.81	0.76	0.71	0.70	
	1	1.00	0.91	0.89	0.88	0.87	-	
	2	1.00	0.91	0.88	0.87	0.85	-	
Unperforated tray (note2)	1	0.97	0.84	0.78	0.75	0.71	0.68	
	2	0.97	0.83	0.76	0.72	0.68	0.63	
	3	0.97	0.82	0.75	0.71	0.66	0.61	
	4-6	0.97	0.81	0.73	0.69	0.63	0.58	
Ladder cleats (note2)	1	1.00	0.87	0.82	0.80	0.79	0.78	
	2	1.00	0.86	0.80	0.78	0.76	0.73	
	3	1.00	0.85	0.79	0.76	0.73	0.70	
	4-6	1.00	0.84	0.77	0.73	0.68	0.64	
	1	1.00	1.00	1.00	1.00	1.00	-	
	2	1.00	0.99	0.98	0.97	0.96	-	
	3	1.00	0.98	0.97	0.96	0.93	-	

#### Note (Table 5-41)

- Factors are given for single layer of cables (or trefoil groups) only given in table and do not apply when cables are installed in more than one layer touching each other.
- Values are given for vertical spacing between trays of at least 300 mm. and at least 20 mm. between the trays and any wall only.
- Values are given for horizontal spacing between trays of at least 225 mm. with trays mounted back to back only.
- For trays having more than one circuit, the correction factor should be considered as a maximum circuit in tray.

**Table 5-43 : Correction factor for ambient air temperatures other than 40°C to be applied to current-carrying capacities for cables in free air**

Ambient Temperature (Degree celsius)	Insulation			MI	
	PVC	XLPE or EPR	MI		
			70°C	110°C	
11-15	1.34	1.23	1.41	1.21	
16-20	1.29	1.19	1.34	1.16	
21-25	1.22	1.14	1.26	1.13	
26-30	1.15	1.10	1.18	1.09	
31-35	1.08	1.05	1.09	1.04	
36-40	1.00	1.00	1.00	1.00	
41-45	0.91	0.96	0.91	0.96	
46-50	0.82	0.90	0.79	0.91	
51-55	0.70	0.84	0.67	0.87	
56-60	0.57	0.78	0.53	0.82	
61-65	-	0.71	-	0.76	
66-70	-	0.64	-	0.70	
71-75	-	0.55	-	0.65	
76-80	-	0.45	-	0.59	
81-85	-	-	-	0.51	
86-90	-	-	-	0.43	
91-95	-	-	-	0.35	

**Table 5-44 : Correction factors for ambient ground temperatures other than 30°C to be applied to the current-carrying capacities for the cables in ducts in the ground**

Ambient temperature (Degree celsius)	Insulation	
	PVC	XLPE or EPR
11-15	1.18	1.12
16-20	1.12	1.08
21-25	1.07	1.03
26-30	1.00	1.00
31-35	0.94	0.96
36-40	0.87	0.91
41-45	0.80	0.86
46-50	0.71	0.82
51-55	0.62	0.76
56-60	0.51	0.70
61-65	-	0.65
66-70	-	0.57
71-75	-	0.49
76-80	-	0.41

โทร : 02 550 9555

**Table 5-45 and Table 5-46 :** Correction factor for Single core or Multi cores, rated voltaed 0.6/1 kV when group of circuit more than 1 circuit, flat horizontal.










**Table 5-45 :** Correction factor for Single core or Multi cores, rated voltaed 0.6/1 kV install in direct burial when group of circuit more than 1 circuit, flat horizontal.

No. of circuit	Space between outside of each cable (mm.)				
	Touching	1 time of cable diameter	125	250	500
2	0.75	0.80	0.85	0.90	0.90
3	0.65	0.70	0.75	0.80	0.85
4	0.60	0.60	0.70	0.75	0.80
5	0.55	0.55	0.65	0.70	0.80
6	0.50	0.55	0.60	0.70	0.80



**Table 5-46 :** Correction factor for Single core or Multi cores, rated voltaed 0.6/1 kV, install in conduit in direct burial when group of circuit more than 1 circuit, flat horizontal.

No. of circuit	Space between outside of conduit (mm.)			
	Touching	125	500	1,000
2	0.85	0.90	0.95	0.95
3	0.75	0.85	0.90	0.95
4	0.70	0.80	0.85	0.90
5	0.65	0.80	0.85	0.90
6	0.60	0.80	0.80	0.90

**Table 5-47 : Schedule of reference method of installation which form the basis of the tabulated current-carrying capacities**

	Methods of Installation	Group of Installation	Note
Insulated conductors single core or multi cores with or without sheathed wiring in metallic or non-metallic conduit in thermal insulated wall.	 Or 	Group 1	Ceiling or thermal insulated wall has a thermal conductance not less than $10 \text{ W/m}^2\text{K}$
Insulated conductors single core or multi cores with or without sheathed wiring in metallic or non-metallic conduit in concrete wall.	 Or 	Group 2	The inner skin of the concrete has a thermal conductance not greater than $2 \text{ k.m/w}$
Single core or multi cores cable, insulated and sheathed on a wall	 Or 	Group 3	-
Single core or multi cores cable, insulated with or without sheathed wiring in spacing on insulator.	 Or 	Group 4	Spacing between cable and cable, wall and cable not less than diameter of cable.
Single core or multi cores cable with sheathed install in duct in ground.	 Or 	Group 5	-
Single core or multi cores cable with sheathed install direct burial.	 Or 	Group 6	-

**Table 5-47 (continue) : Schedule of reference method of installation which form the basis of the tabulated current-carrying capacities**

	Methods of Installation	Group of Installation	Note
Single core or multi cores cable with sheathed install on perforated or unperforated tray or ladder cleats.	 <p>Or</p> 	Group 7	Perforated tray must have ventilated area not less than 30 percent of surface tray.

**Note (Table 5-47)**

\*\* If no confirmation that thermal conductance not less than  $10 \text{ W/m}^2\cdot\text{K}$ , consider that install in conduit or ceiling or thermal insulated wall shall be apply current-carrying capacities in group 1.



บริษัท ซีที อิเลคทริก ซัพพลาย จำกัด  
CT ELECTRIC SUPPLY CO., LTD.

โทร : 02 550 9555

Gauge				Diameter		Sectional Area			Weight	
B.W.G.	A.W.G.	S.W.G.	mm.G.	Mil	mm.	Cir. Mil	In <sup>2</sup>	mm <sup>2</sup>	lb/1,000 ft.	kg./km.
5/0	-	7/0	-	500	12.700	250,000	0.1964	126.7	756.9	1,126
-	-	-	12	472.4	12.000	223,162	0.1753	113.1	675.6	1,005
-	-	6/0	-	464	11.786	215,296	0.1691	109.1	651.7	969.9
-	4/0	-	-	460	11.684	211,600	0.1662	107.2	640.5	953
4/0	-	-	-	454	11.532	206,100	0.1619	104.4	624	928.1
-	-	5/0	-	432	10.973	186,624	0.1466	94.56	565	840.6
3/0	-	-	-	425	10.795	180,600	0.1419	91.52	546.9	813.6
-	3/0	-	-	409.6	10.404	167,772	0.1318	85.03	508	755.9
-	-	4/0	-	400	10.160	160,000	0.1257	81.07	484.5	720.7
-	-	-	10	393.7	10.000	155,000	0.1217	78.54	468	698.2
2/0	-	-	-	380	9.652	144,400	0.1134	73.17	437.1	650.5
-	-	3/0	-	372	9.440	138,384	0.1087	70.12	418.9	623.4
-	2/0	-	-	364.8	9.266	133,079	0.1045	67.42	402.7	599.4
-	-	-	9	354.3	9.000	125,528	0.09859	63.62	380	565.6
-	-	2/0	-	348	8.839	121,104	0.09512	61.36	366.6	545.5
0	-	-	-	340	8.636	115,600	0.09079	58.58	349.9	520.8
-	0	-	-	324.9	8.250	105,560	0.08291	53.49	319.5	475.5
-	-	0	-	324	8.230	104,976	0.08245	53.19	317.8	472.8
-	-	-	8	315	8.000	99,225	0.07793	50.27	300.3	446.9
1	-	1	-	300	7.629	90,000	0.07069	45.60	272.4	405.4
-	1	-	-	289.3	7.348	83,694	0.06573	42.41	253.3	377
2	-	-	-	284	7.214	80,660	0.06335	40.87	244.2	363.3
-	-	2	-	276	7.010	76,176	0.05983	39.60	230.6	343.2
-	-	-	7	275.6	7.000	75,955	0.05966	38.48	229.9	342.1
3	-	-	-	259	6.579	67,080	0.05269	33.99	203.1	302.2
-	2	-	-	257.6	6.544	66,358	0.05212	33.63	200.9	299
-	-	-	6.5	255.9	6.500	65,485	0.05143	22.18	189.2	295
-	-	3	-	252	6.401	63,504	0.04988	32.18	192.2	286.1
4	-	-	-	238	6.045	56,640	0.04449	28.70	171.5	255.1
-	-	-	6.0	236.2	6.000	55,790	0.04382	28.27	168.9	251.1
-	-	4	-	232	5.893	53,824	0.04227	27.27	162.9	242.4
-	3	-	-	229.4	5.827	52,624	0.04133	26.66	159.3	237
5	-	-	-	220	5.588	48,400	0.03801	24.52	146.5	218
-	-	-	5.5	216.5	5.500	46,872	0.03681	23.72	141.9	210.9
-	-	5	-	212	5.385	44,944	0.03530	22.77	136	202.4
-	4	-	-	204.3	5.189	41,738	0.03278	21.15	126.3	188
6	-	-	-	203	5.156	41,210	0.03237	20.88	124.8	185.6
-	-	-	5.0	196.9	5.000	38,770	0.03045	19.63	117.4	174.5
-	-	6	-	192	4.877	36,864	0.02895	18.68	111.6	166.3
-	5	-	-	181.9	4.621	33,088	0.02599	16.77	100.2	149.1
7	-	-	-	180	4.572	32,400	0.02545	16.42	98.08	146
-	-	-	4.5	177.2	4.500	31,400	0.02466	15.90	95.04	141.4
-	-	7	-	176	4.470	30,976	0.02433	15.70	93.77	139.6
8	-	-	-	165	4.191	27,220	0.02138	13.80	82.40	122.7
-	6	-	-	162	4.115	26,244	0.02061	13.30	79.43	118.2
-	-	8	-	160	4.064	25,600	0.02011	12.97	44.50	115.30
-	-	-	4.0	157.5	4.000	24,806	0.01948	12.57	75.08	111.80

Gauge				Diameter		Sectional Area			Weight	
B.W.G.	A.W.G.	S.W.G.	mm.G.	Mil	mm.	Cir. Mil	In <sup>2</sup>	mm <sup>2</sup>	lb/1,000 ft.	kg./km.
9	-	-	-	148	3.759	21,900	0.01720	11.10	66.29	98.68
-	7	-	-	144.3	3.665	20,822	0.01635	10.55	63.01	93.79
-	-	9	-	144	3.658	20,736	0.01629	10.52	62.78	93.52
-	-	-	3.5	137.8	3.500	18,989	0.01491	9.621	57.46	58.53
10	-	-	-	134	3.404	17,960	0.01410	9.098	54.34	80.88
-	8	-	-	128.5	3.264	16,512	0.01297	8.368	49.99	74.39
-	-	10	-	128	3.251	16,384	0.01287	8.302	49.60	73.81
-	-	-	3.2	126	3.200	15,876	0.01247	8.042	48.06	71.49
11	-	-	-	120	3.048	14,400	0.01131	7.297	43.59	64.87
-	-	11	-	116	2.946	13,456	0.01057	6.818	40.74	60.61
-	9	-	-	114.4	2.906	13,087	0.01028	6.632	39.62	58.96
-	-	-	2.9	114.2	2.900	13,042	0.01024	6.605	39.47	58.72
12	-	-	-	109	2.769	11,880	0.009331	6.020	35.96	53.52
-	-	12	-	104	2.642	10,816	0.008495	5.481	32.74	48.73
-	-	-	2.6	102.4	2.600	10,486	0.008246	5.309	31.78	47.29
-	10	-	-	101.9	2.588	10,384	0.008156	5.262	31.43	46.78
13	-	-	-	95	2.413	9,025	0.007088	4.573	27.32	40.65
-	-	13	-	92	2.337	8,464	0.006648	4.289	25.62	38.13
-	11	-	-	90.74	2.305	8,234	0.006467	4.172	24.92	37.09
-	-	-	2.3	90.55	2.300	8,199	0.006439	4.155	24.82	36.94
14	-	-	-	83	2.108	6,889	0.005411	3.491	20.85	31.04
-	12	-	-	80.81	2.053	6,530	0.005129	3.309	19.77	29.42
-	-	14	-	80	2.032	6,400	0.005027	3.243	19.37	28.83
-	-	-	2.0	78.74	2.000	6,200	0.004869	3.142	18.77	27.93
15	-	15	-	72	1.829	5,184	0.004072	2.627	18.46	27.36
-	13	-	-	71.96	1.828	5,178	0.004067	2.624	15.67	23.33
-	-	-	1.8	70.87	1.800	5,023	0.003945	2.545	15.20	22.63
16	-	-	-	65	1.651	4,225	0.003318	2.141	12.79	19.03
-	14	-	-	64.08	1.628	4,106	0.003225	2.081	12.43	18.50
-	-	16	-	64	1.626	4,096	0.003217	2.075	12.40	18.45
-	-	-	1.6	62.99	1.600	3,968	0.003116	2.011	12.01	17.88
17	-	-	-	58	1.473	3,364	0.002642	1.705	10.18	15.16
-	15	-	-	57.07	1.450	3,257	0.002558	1.650	9.859	14.67
-	-	17	-	56	1.422	3,136	0.002463	1.589	9.493	14.13
-	-	-	1.4	55.12	1.400	3,038	0.002386	1.539	9.196	13.68
-	16	-	-	50.82	1.291	2,583	0.002029	1.309	7.820	11.64
18	-	-	-	49	1.245	2,401	0.001886	1.217	7.269	10.82
-	-	18	-	48	1.219	2,304	0.001810	1.167	6.976	10.38
-	-	-	1.2	47.24	1.200	2,232	0.001753	1.131	6.756	10.06
-	17	-	-	45.26	1.150	2,048	0.001608	1.037	6.197	9.219
19	-	-	-	42	1.067	1,764	0.001385	0.8938	5.388	7.946
-	18	-	-	40.30	1.024	1,624	0.001275	0.8226	4.914	7.313
-	-	19	-	40	1.016	1,600	0.001257	0.8107	4.845	7.207
-	-	-	1.0	39.37	1.000	1,550	0.001217	0.7854	4.690	6.982
-	-	20	-	36	0.9144	1,296	0.001018	0.6576	3.923	5.838
-	19	-	-	35.89	0.9116	1,288	0.001012	0.6529	3.900	5.804
-	-	-	0.90	35.43	0.9000	1,255	0.0009857	0.6362	3.799	5.656

Gauge				Diameter		Sectional Area			Weight	
B.W.G.	A.W.G.	S.W.G.	mm.G.	Mil	mm.	Cir. Mil	In <sup>2</sup>	mm <sup>2</sup>	lb/1,000 ft.	kg./km.
20	-	-	-	35	0.8890	1,225	0.0009621	0.6207	3.708	5.518
21	-	21	-	32	0.8128	1,024	0.0008042	0.5189	3.099	4.613
-	20	-	-	31.96	0.8118	1,021	0.0008019	0.5174	3.091	4.600
-	-	-	0.80	31.50	0.8000	992.3	0.0007794	0.5027	3.004	4.469
-	21	-	-	28.46	0.7229	810	0.0006362	0.4105	2.452	3.649
22	-	22	-	28	0.7112	784	0.0006158	0.3973	2.373	3.532
-	-	-	0.70	27.56	0.7000	759.6	0.0005966	0.3848	2.299	3.421
-	-	-	0.65	25.59	0.6500	654.8	0.0005143	0.3318	1.982	2.950
-	22	-	-	25.35	0.6438	642.6	0.0005047	0.3256	1.945	2.895
23	-	-	-	25	0.6350	625	0.0004909	0.3167	1.892	2.816
-	-	23	-	24	0.6096	576	0.0004524	0.2919	1.744	2.595
-	-	-	0.60	23.62	0.6000	557.9	0.0004382	0.2827	1.689	2.513
-	23	-	-	22.57	0.5733	509.4	0.0004001	0.2581	1.542	2.295
24	-	24	-	22	0.5583	484	0.0003801	0.2452	1.465	2.180
-	-	-	0.50	21.65	0.5500	468.7	0.0003681	0.2376	1.419	2.112
-	24	-	-	20.10	0.5106	404	0.0003173	0.2047	1.223	1.820
25	-	25	-	20	0.5080	400	0.0003142	0.2027	1.211	1.802
-	-	-	0.50	19.69	0.5000	387.7	0.0003045	0.1963	1.174	1.745
26	-	26	-	18	0.4572	324	0.0002545	0.1642	0.9809	1.460
-	25	-	-	17.90	0.4547	320.4	0.0002516	0.1623	0.9697	1.443
-	-	-	0.45	17.72	0.4500	314	0.0002466	0.1590	0.9504	1.414
-	-	27	-	16.4	0.4166	269	0.0002113	0.1363	0.8146	1.212
27	-	-	-	16	0.4064	256	0.0002011	0.1297	0.7750	1.153
-	26	-	-	15.94	0.4049	254.1	0.0001996	0.1288	0.7693	1.145
-	-	-	0.40	15.75	0.4000	248.1	0.0001946	0.1257	0.7512	1.118
-	-	28	-	14.8	0.3759	219	0.0001720	0.1110	0.6629	0.9868
-	27	-	-	14.20	0.3606	201.6	0.0001583	0.1021	0.6101	0.9077
28	-	-	-	14	0.3556	196	0.0001539	0.09932	0.5931	0.8330
-	-	-	0.35	13.78	0.3500	189.9	0.0001491	0.09621	0.5746	0.8553
-	-	29	-	13.6	0.3454	185	0.0001453	0.09372	0.5600	0.8332
29	-	-	-	13	0.3302	169	0.0001327	0.08563	0.5114	0.7613
-	28	-	-	12.64	0.3211	159.8	0.0001255	0.08097	0.4837	0.7198
-	-	-	0.30	12.60	0.3200	158.8	0.0001246	0.08042	0.4805	0.7149
-	-	30	-	12.4	0.3150	153.8	0.0001208	0.07791	0.4656	0.6926
30	-	-	-	12	0.3048	144	0.0001131	0.07297	0.4359	0.6487
-	-	31	-	11.6	0.2946	134.6	0.0001057	0.06818	0.4074	0.6061
-	-	-	0.29	11.42	0.2900	130.4	0.0001024	0.06605	0.3947	0.5872
-	29	-	-	11.26	0.2859	126.8	0.00009959	0.06425	0.3838	0.5712
-	-	32	-	10.8	0.2743	116.6	0.00009158	0.05913	0.3530	0.5257
-	-	-	26	10.24	0.2600	104.9	0.00008239	0.05309	0.3175	0.4720
-	30	-	-	10.03	0.2546	100.6	0.00007901	0.05097	0.3045	0.4531
31	-	33	-	10	0.2540	100	0.00007954	0.05067	0.3027	0.4505
-	-	34	-	9.2	0.2337	84.64	0.00006648	0.04289	0.2562	0.3813
-	-	-	0.23	9.055	0.2300	81.99	0.00006440	0.04155	0.2482	0.3694
32	-	-	-	9	0.2286	81.102	0.00006362	0.04104	0.2452	0.3649
-	31	-	-	8.928	0.2238	79.71	0.00006260	0.04039	0.2413	0.3591
-	-	35	-	8.4	0.2134	70.56	0.00005542	0.03575	0.2136	0.3178

Gauge				Diameter		Sectional Area			Weight	
B.W.G.	A.W.G.	S.W.G.	mm.G.	Mil	mm.	Cir. Mil	In <sup>2</sup>	mm <sup>2</sup>	lb/1,000 ft.	kg./km.
33	-	-	-	8	0.2032	64	0.00005027	0.03243	0.1937	0.2883
-	32	-	-	7.950	0.2019	63.20	0.00004964	0.03203	0.1913	0.2847
-	-	-	0.20	7.874	0.2000	62	0.00004869	0.03142	0.1877	0.2793
-	-	36	-	7.6	0.1930	57.76	0.00004536	0.02927	0.1748	0.2602
-	-	-	0.18	7.087	0.1800	50.23	0.00003945	0.02545	0.1520	0.2263
-	33	-	-	7.080	0.1798	50.13	0.00003937	0.02540	0.1517	0.2258
34	-	-	-	7	0.1778	49	0.00003848	0.02483	0.1483	0.2207
-	-	37	-	6.8	0.1727	46.24	0.00003632	0.02343	0.1400	0.2083
-	34	-	-	6.305	0.1601	39.75	0.00003122	0.02014	0.1203	0.1790
-	-	-	0.16	6.299	0.1600	39.68	0.00003116	0.02011	0.1201	0.1788
-	-	38	-	6	0.1524	36	0.00002827	0.01824	0.1090	0.1622
-	35	-	-	5.615	0.1426	31.53	0.00002476	0.01597	0.09543	0.1420
-	-	-	0.14	5.512	0.1400	30.38	0.00002386	0.01539	0.09196	0.1368
-	-	39	-	5.2	0.1321	27.04	0.00002124	0.01370	0.08186	0.1218
35	36	-	-	5.000	0.1270	25	0.00001963	0.01267	0.07565	0.1126
-	-	40	-	4.8	0.1219	23.04	0.00001810	0.01167	0.06976	0.1037
-	-	-	0.12	4.724	0.1200	22.32	0.00001753	0.01131	0.06756	0.1006
-	37	-	-	4.453	0.1131	19.83	0.00001557	0.01005	0.06001	0.08934
-	-	41	-	4.4	0.1118	19.36	0.00001521	0.009810	0.05812	0.08721
36	-	42	-	4	0.1016	16.00	0.00001257	0.008107	0.04845	0.07207
-	38	-	-	3.965	0.1007	15.72	0.00001235	0.007968	0.04760	0.07084
-	-	-	0.10	3.937	0.1000	15.50	0.00001217	0.007854	0.04690	0.06982
-	-	43	-	3.6	0.09114	12.96	0.00001018	0.006567	0.03923	0.05838
-	39	-	-	3.531	0.08969	12.47	0.000009794	0.006319	0.03775	0.05618
-	-	44	-	3.2	0.08138	10.24	0.000008042	0.005819	0.03099	0.04613
-	40	-	-	3.145	0.07987	9.891	0.000007768	0.005012	0.02994	0.04456
-	41	45	-	3.800	0.07113	7.842	0.000006159	0.003973	0.02374	0.03532
-	42	-	-	2.494	0.06334	6.219	0.000004884	0.003151	0.01882	0.02801
-	-	46	-	2.4	0.06096	5.760	0.000004528	0.002929	0.01744	0.02595
-	43	-	-	2.221	0.05641	4.932	0.000003873	0.002495	0.01498	0.02222
-	-	47	-	2	0.05080	4.000	0.000003142	0.002027	0.01211	0.01802
-	44	-	-	1.987	0.05023	3.911	0.000003072	0.001982	0.01184	0.01762
-	-	-	0.05	1.969	0.05000	3.877	0.000003045	0.001963	0.01174	0.01745
-	45	-	-	1.761	0.04473	3.102	0.000002436	0.001572	0.009383	0.01398
-	-	48	-	1.6	0.04064	2.560	0.000002011	0.001297	0.007750	0.01153
-	46	-	-	1.568	0.03984	2.460	0.000001931	0.001246	0.007446	0.01108
-	47	-	-	1.397	0.03547	1.951	0.000001532	0.0009884	0.005904	0.008787
-	48	-	-	1.224	0.03159	1.547	0.000001215	0.0007838	0.004683	0.006968
-	-	49	-	1.2	0.03048	1.440	0.000001131	0.0007297	0.004359	0.006487
-	49	-	-	1.108	0.02813	1.227	0.0000009635	0.0006216	0.003713	0.005526
-	-	50	-	1	0.02540	1.000	0.0000007854	0.0005067	0.003027	0.004505
-	50	-	-	0.986	0.02505	0.9728	0.0000007641	0.0004929	0.002945	0.004382

NOTE : B.W.G. - Birmingham Iron Wire Gauge

A.W.G. - American Wire Gauge

S.W.G. - British Standard Wire Gauge

mm.G. - Millimeter Gauge

Item	Descriptions			
1. LENGTH	1 micron	= 0.001 mm	= $3.94 \times 10^{-5}$ in.	
	1 mil	= 0.0254 mm.	= 0.001 in.	
	1 mm	= 39.37 mils	= 0.03937 in.	
	1 cm	= 0.3937 in.	= 0.0328 ft.	
	1 inch	= 25.4 mm.	= 0.083 ft.	= 0.0278 yd. = 2.54 cm.
	1 feet	= 0.305 m.	= 0.333 yd.	
	1 yard	= 0.914 m.	= 91.44 cm.	
	1 meter	= 39.37 in.	= 3.28 ft	= 1.094 yd.
	1 kilometer	= 3,281 ft.	= 1,094 yd.	= 0.6213 mile
	1 mile	= 5,280 ft.	= 1,760 yd.	= 1,609 m = 1.609 km.
2. AREA	1 MCM	= 1000 CM (Circular Mil)	= 0.5067 mm <sup>2</sup>	= 1/1000 in <sup>2</sup>
	1 CM	= 0.0005067 mm <sup>2</sup>	= 0.0000007854 in. <sup>2</sup>	= 0.7854 sq.mil.
	1 mm <sup>2</sup>	= 1973 CM.	= 0.00155 in. <sup>2</sup>	= 1,550 sq.mil.
	1 in <sup>2</sup>	= 1273240 CM.	= 645.1 mm <sup>2</sup>	= 0.0069 ft. <sup>2</sup>
	1 yd <sup>2</sup>	= 1,296 in. <sup>2</sup>	= 0.83613 m <sup>2</sup>	
	1 m <sup>2</sup>	= 1,550 in. <sup>2</sup>	= 10.7 ft. <sup>2</sup>	= 1.195 yd. <sup>2</sup>
	1 km <sup>2</sup>	= 0.001562 mile <sup>2</sup>		
3. VOLUME	1 mile <sup>3</sup>	= 27,880,000 ft <sup>3</sup>	= 3,098,000 yd. <sup>3</sup>	= 2,590,000 m <sup>3</sup> = 7.48 gal
	1 cm <sup>3</sup>	= 0.061 in. <sup>3</sup>		
	1 in <sup>3</sup>	= 16.39 cm <sup>3</sup>	= 0.0036 gal.	= 0.0005787 ft. <sup>3</sup>
	1 l	= 1,000 cm <sup>3</sup>	= 61,023 in. <sup>3</sup>	= 0.2642 gal.
	1 gal	= 3,785 cm <sup>3</sup>	= 231 in. <sup>3</sup>	= 0.1337 ft. <sup>3</sup> = 0.03531 ft. <sup>3</sup>
	1 ft <sup>3</sup>	= 28,317 cm <sup>3</sup>	= 1,728 in. <sup>3</sup>	= 0.034951 yd. <sup>3</sup>
	1 yd <sup>3</sup>	= 46,656 in. <sup>3</sup>	= 0.7676 m <sup>3</sup>	= 7.48 gal.
4. WEIGHT	1 m <sup>3</sup>	= 61,023 in. <sup>3</sup>	= 35.31 ft. <sup>3</sup>	= 1.308 yd. <sup>3</sup>
	1 g.	= 15.43 gr.	= 0.03527 oz.	= 0.002205 lb.
	1 oz.	= 437.5 gr.	= 28.35 g.	= 0.0625 lb.
	1 lb.	= 7,000 gr.	= 453.6 g.	= 16 oz. = 0.4536 kg.
	1 kg.	= 15,432 gr.	= 35.27 oz.	= 2.205 lb.
	1 ton (short)	= 2,000 lb.	= 907.2 kg.	= 0.8928 ton (long)
	1 ton (long)	= 2,240 lb.	= 1.12 ton (short)	= 1.016 ton (metric)
5. ENERGY	1 ton (metric)	= 2,240.62 lb.		
	1 B.t.u.	= 1,055 joules	= 778.1 ft.-lb.	= 252 g.-cal. = 107.6 kg.-m.
		= 0.2930 watt-hr.		
	1 watt-hr.	= 3,600 joules	= 2,655.4 ft.-lb.	= 860 g.-cal. = 367.1 kg.-m.
		= 3,413 B.t.u.	= 0.001341 hp.-hr	
6. POWER	1 hp.-hr.	= 2,684,000 joules	= 1,980,000 ft.-lb.	= 273,700 kg.-cm
		= 745.6 watt-hr.		
	1 kw-hr.	= 2,655,000 ft.-lb.	= 367,100 kg.-m.	= 1.34 hp.-hr.
	1 watt	= 44.26 ft.-lb./min	= 6.119 kg.-m./min.	= 0.001341 hp.
7. TEMPERATURE	1 hp.	= 33,000 ft.-lb./min		= 745.6 watts = 550 ft.-lb./sec.
		= 76.04 kg.-m./sec.		
	1 kw.	= 44,256.7 ft.-lb./min		= 101.979 kg.-m./sec. = 1.341 hp.
		= 1,000 watts.		
Temp°C		= 5/9 (temp°F - 32)		
Temp°F		= (9/5 x temp °C) + 32		

Electrical Unit	Symbol
CURRENT	A
VOLTAGE	V (kV)
RESISTANCE	$\Omega$ ( $k\Omega$ , M $\Omega$ )
ELECTRIC POWER	W (kW, MW.)
ELECTRIC ENERGY	Wh (kWh)
HORSE POWER	HP
POWER FACTOR	P.F.
FREQUENCY	Hz
CAPACITANCE	F ( $\mu F$ , pF)
APPARENT POWER	VA (kVA)
DIRECT CURRENT	DC
ALTERNATIVE CURRENT	AC
EFFICIENCY	Eff.
MAXIMUM VALUES	$E_m$ , $I_m$
AVERAGE VALUES	$E_{av}$ , $I_{av}$
EFFECTIVE VALUES	$E$ , $I$
INSTANTANEOUS VALUES	$e$ , $i$

บริษัท อิเลคทริก ซัพพลาย จำกัด

## ELECTRICAL FORMULAS

ELECTRICAL FORMULAS FOR DETERMINING AMPERE, KILOVOLT - AMPERE AND POWER

Direct Current	Alternating Current	
	Single Phase	Three Phase
$A = \frac{kW \times 1000}{V}$	$A = \frac{kW \times 1000}{V \times P.F.}$	$A = \frac{kW \times 1000}{1.73 \times V \times P.F.}$
$A = \frac{kVA \times 1000}{V}$	$A = \frac{kVA \times 1000}{V}$	$A = \frac{kVA \times 1000}{1.73 \times V}$
$A = \frac{HP \times 746}{V \times (\%Eff.)}$	$A = \frac{HP \times 746}{V \times (\%Eff.) \times P.F.}$	$A = \frac{HP \times 746}{1.73 \times V \times (\%Eff.) \times P.F.}$
$kW = \frac{A \times V}{1000}$	$kW = \frac{A \times V \times P.F.}{1000}$	$kW = \frac{A \times V \times 1.73 \times P.F.}{1000}$
$kVA = \frac{A \times V}{1000}$	$kVA = \frac{A \times V}{1000}$	$kVA = \frac{A \times V \times 1.73}{1000}$
$HP = \frac{KW \times 1000}{V}$	$HP = \frac{A \times V \times (\%Eff.) \times P.F.}{746}$	$HP = \frac{A \times V \times 1.73(\%Eff.) \times P.F.}{746}$

## APPROXIMATE MOTOR AMPERES PER TERMINAL :

3 phase	220 V a - C = 4	ampères per H.P.
3 phase	220 V a - C = 2.5	ampères per H.P.
3 phase	380 V a - C = 1.41	ampères per H.P.
3 phase	440 V a - C = 1.25	ampères per H.P.
3 phase	550 V a - C = 1	ampères per H.P.

Motor ratings in HP at service voltage					Rating of motor starter A	Reply Setting A	Max. Quick-blow back-up fuse A	Min. cross section of cables mm²	
220 V		380 V		440 V					
HP	Full load current A	HP	Full load current A	HP	Full load current A				
0.05		0.05		0.05		15	0.15 - 0.25	1	1.5
		0.1		0.1		15	0.25 - 0.4	2	1.5
		0.15		0.2		15	0.4 - 0.65	4	1.5
0.1		0.2		0.25	0.5	15	0.4 - 0.65	4	1.5
0.15		0.25	0.6	0.5	0.9	15	0.6 - 1.0	6	1.5
0.25	1.1	0.5	1.0			15	1.0 - 1.6	6	1.5
0.5	1.8	0.75	1.5	0.75	1.2	15	1.0 - 1.6	6	1.5
		1.0	1.9	1.0	1.6	15	1.5 - 2.5	15 (10)	1.5
		2.5	1.5	2.6	2	15	2.5 - 4	25 (15)	1.5
1.0	3.2	2	3.4	2.5	3.9	15	2.5 - 4	25 (15)	1.5
1.5	4.4	2.5	4.2	3	4.5	15	4 - 6.5	25 (20)	1.5
2.0	5.8	3	4.9	4	6.0	15	4 - 6.5	25 (20)	1.5
2.5	7.3	4	6.3	5	7.5	15	6 - 10	35 (25)	1.5
3	8.4	5	7.8	6	8.5	15	6 - 10	35 (25)	1.5
4	11	6	9.3	7.5	11.0	15	9 - 14	35	1.5
5	13.5	7.5	11.5			15	9 - 14	35	1.5
		10	15	10	14	25	13 - 20	60	2.5
		19.5	15	22	15	25	16 - 25	60	4
10	26	20	29	20	27	60	20 - 31	100	6
15	39	25	36	30	39	60	28 - 43	125	10
20	51	30	42			60	40 - 60	160	16
25	63	35	50	35	46	60	40 - 60	160	16
		40	56	40	52	60	40 - 60	160	16
		50	69	50	65	100	50 - 75	200	16
35	91	60	83	60	76	100	70 - 100	200	25
40	100	75	104	75	96	200	84 - 120	400	35
50	125	100	136	100	125	200	105 - 150	500	50
75	184	125	167	125	155	200	140 - 200	500	95
		150	200	150	180	350	175 - 250	600	120
		245	175	235	175	215	350	175 - 250	600
120	295	200	268	200	240	350	210 - 300	850	150
150	370	250	335	250	300	600	280 - 400	850	240
175	425	300	400	300	360	600	350 - 500	1000	400
200	475	350	470	350	410	600	350 - 500	1000	400
225	540	400	535	400	450	600	420 - 600	1000	

EXISTING POWER FACTOR (%)	Corrected Power Factor					
	100%	95%	90%	85%	80%	75%
50	1.732	1.403	1.247	1.112	0.982	0.850
52	1.643	1.314	1.158	1.023	0.893	0.761
54	1.558	1.229	1.073	0.938	0.808	0.676
55	1.518	1.189	1.033	0.898	0.768	0.636
56	1.479	1.150	0.994	0.859	0.729	0.597
58	1.404	1.075	0.919	0.784	0.654	0.522
60	1.333	1.004	0.848	0.713	0.583	0.451
62	1.265	0.936	0.780	0.645	0.515	0.383
64	1.201	0.872	0.716	0.581	0.451	0.319
65	1.168	0.839	0.683	0.548	0.418	0.286
66	1.139	0.810	0.654	0.519	0.389	0.257
68	1.078	0.749	0.593	0.458	0.328	0.196
70	1.020	0.691	0.535	0.400	0.270	0.138
72	0.964	0.635	0.479	0.344	0.214	0.082
74	0.909	0.580	0.424	0.289	0.159	0.027
75	0.882	0.553	0.397	0.262	0.132	
76	0.855	0.526	0.370	0.235	0.105	
78	0.802	0.473	0.317	0.182	0.052	
80	0.750	0.421	0.265	0.130		
82	0.698	0.369	0.213	0.078		
84	0.646	0.317	0.161			
85	0.620	0.291	0.135			
86	0.594	0.265	0.109			
88	0.540	0.211	0.055			
90	0.485	0.156				
92	0.426	0.097				
94	0.363	0.034				
95	0.329					

**Typical Problem :** With a load of 500 kW. at 80% power factor it is desired to find the kVAR of capacitors required to correct the power factor to 90%

**Solution :** From the table select the multiplying factor 0.265 corresponding to the existing 80% and the corrected 90% power factor

$0.265 \times 500 = 132.5$  kVAR of capacitors required





Transformer Size (kVA)	12 kV Primary Current (A)		Secondary Current (A)			
	1 Ø	3 Ø	220V		380V	
			1 Ø	3 Ø Δ	1 Ø	3 Ø Y
5	0.4	0.2	22.7	13.1	13.2	7.6
10	0.8	0.5	45.5	26.3	26.4	15.2
15	1.3	0.7	68.2	39.4	39.5	22.8
20	1.7	0.9	90.9	52.5	52.6	30.4
25	2.1	1.2	113.5	65.6	65.8	37.9
30	2.5	1.4	136.4	78.7	78.9	45.6
37.5	3.1	1.8	170.5	98.4	98.7	56.9
45	3.8	2.2	204.5	118.1	118.4	68.4
50	4.2	2.4	227.3	131.2	131.6	75.9
67.5	5.6	3.3	306.8	177.3	177.6	102.6
75	6.3	3.6	340.9	196.8	197.4	113.9
100	8.3	4.8	454.5	262.4	263.2	151.9
112.5	9.4	5.4	511.4	294.2	296.0	170.9
150	12.5	7.2	681.8	393.7	394.7	227.9
167	13.9	8.0	759.1	438.3	439.5	253.7
200	16.7	9.6	909.1	524.9	526.3	303.9
225	18.8	10.8	1,022.7	590.5	592.0	341.9
250	20.8	12.0	1,136.4	656.1	657.9	379.8
300	25.0	14.4	1,363.6	787.3	789.5	455.8
333	27.8	16.0	1,513.6	873.9	876.3	505.9
350	29.2	16.8	1,590.9	918.5	921.1	531.8
400	33.3	19.3	1,818.2	1,049.8	1,052.6	607.8
450	37.5	21.7	2,045.5	1,180.9	1,184.2	683.7
500	41.7	24.0	2,272.7	1,312.2	1,315.8	759.7
550	45.8	26.5	2,500.0	1,443.2	1,447.4	835.7
600	50.0	28.9	2,727.3	1,574.6	1,579.9	911.6
650	54.1	31.3	2,954.3	1,709.9	1,710.5	987.6
700	58.3	33.7	3,181.8	1,836.4	1,842.4	1,063.6
750	62.7	36.1	3,409.1	1,968.3	1,973.7	1,139.5
800	66.7	38.5	3,636.4	2,099.5	2,105.3	1,215.5
900	75.0	43.3	4,090.9	2,361.9	2,369.4	1,367.5
1000	83.3	48.1	4,545.5	2,624.4	2,631.6	1,519.4

บริษัท อีเลคทริก สพลาย จำกัด  
CT ELECTRIC SUPPLY CO. LTD.


โทร: 02 550 9555

△ △ Or DELTA-DELTA CONNECTION


Y Y Or STAR-STAR CONNECTION



Y  $\Delta$  Or STAR-DELTA CONNECTION




PRIMARY




SECONDARY

$\Delta$  Y Or DELTA-STAR CONNECTION



PRIMARY



SECONDARY

## Electrical Formulas for Power Transformer

### Current Calculation per phase of 3Ø transformer

Where :

I = Line Current

kW = Kilowatts (1 kW = 1000 watts)

kVA = Kilovolt-amperes = kW ÷ Power factor

$$I = \frac{kW \times 1000}{\text{Power factor} \times \text{Voltage} \times \sqrt{3}}$$

$$I = \frac{kVA \times 1000}{\text{Voltage} \times \sqrt{3}}$$

### Current Calculation of 1Ø Transformation

$$I = \frac{kW \times 1000}{\text{Power factor} \times \text{Voltage}}$$

$$I = \frac{kVA \times 1000}{\text{Voltage}}$$

E = Line current

e = Voltage of T.w (Transformer windings)

I = Line current

i = Current of T.w.

W = Total power in watts of three phase lines.

w = Power in watts of one phase or one leg of transformer.

P.F. = Power factor

### Delta Connection

$$E = e, I = i \sqrt{3}, i = \frac{I}{\sqrt{3}}$$

$$W = 3w, w = ei \times P.F., W = 3ei \times P.F.$$

### Star Connection

$$I = i, E = e \sqrt{3}, e = \frac{E}{\sqrt{3}}$$

$$W = 3w, w = ei \times P.F., W = 3ei \times P.F.$$

### Total Power in watt of three phase line ( W ) Calculation by I , V (Star or Delta Connection)

$$W = \frac{3EI \times P.F.}{\sqrt{3}}$$

$$= \sqrt{3} EI \times P.F.$$

Wire Size (mm <sup>2</sup> )	Maximum Resistance per Kilometer ( at 20 °C ) in Ohms		
	Solid or Stranded Conductor		Flexible Conductor
	Singer core & Multi cores	Singer core & Multi cores	-
0.5 (Solid)	36.0	-	-
0.5 (28W)	-	39.0	-
0.5 (16W)	-	39.0	-
0.75 (42W)	-	26.0	-
0.75 (24W)	-	26.0	-
1	18.1	-	19.5
1.5	12.1	-	13.3
2.5	7.41	-	7.98
4	4.61	-	4.95
6	3.08	-	3.30
10	1.83	-	1.91
16	1.15	-	1.21
25	0.727	-	0.780
35	0.524	-	0.554
50	0.387	-	0.386
70	0.268	-	0.272
95	0.193	-	0.206
120	0.153	-	-
150	0.124	-	-
185	0.0991	-	-
240	0.0754	-	-
300	0.0601	-	-
400	0.0470	-	-
500	0.0366	-	-

บริษัท ชต. อิเลคทริก ซัพพลาย จำกัด  
**CT ELECTRIC SUPPLY CO., LTD.**  
 โทร : 02 550 9555

#### TEMPERATURE CORRECTION FACTOR FOR RESISTANCE

Temperature ( °C )	Reciprocal Factor
25	1.0197
30	1.0393
35	1.0590
40	1.0786
45	1.0983
50	1.1179
55	1.1376
60	1.1572
65	1.1769
70	1.1965
75	1.2162

Factor for correcting resistances at various temperatures of the standard reference temperature of 20°C and reciprocals of the factors for calculating resistances at other temperatures from the value at 20°C.

Temperature °C	Correction Factor		Reciprocal of Factor	
	Copper	Aluminum	Copper	Aluminum
0	1.085	1.088	0.921	0.919
5	1.063	1.064	0.941	0.940
10	1.041	1.042	0.961	0.960
15	1.020	1.021	0.980	0.980
20	1.000	1.000	1.000	1.000
25	0.981	0.980	1.020	1.020
30	0.962	0.961	1.039	1.040
35	0.944	0.943	1.059	1.060
40	0.927	0.925	1.079	1.081
45	0.911	0.908	1.098	1.101
50	0.895	0.892	1.118	1.121
55	0.879	0.876	1.138	1.141
60	0.864	0.861	1.157	1.161
65	0.850	0.846	1.177	1.181
70	0.836	0.832	1.197	1.202
75	0.822	0.819	1.216	1.222
80	0.809	0.805	1.236	1.242
85	0.797	0.792	1.255	1.262
90	0.784	0.780	1.275	1.282

The correction factor is given by :

$$k = \frac{1}{k_1} = \frac{1}{1 + \alpha(\theta - 20)}$$

Where :

k = temperature correction factor of conductor

$k_1$  = reciprocal of k

$\alpha$  = constant mass temperature coefficient at 20°C per deg C

0.00393 for copper (based on 100% conductivity)

0.00403 for aluminium (base on 61% conductivity)

$\theta$  = referred temperature. °C

**THE AC / DC RESISTANCE RATIO OF THE CONDUCTOR IS GIVEN BY THE FOLLOW FORMULA**

$$k_2 = 1 + \lambda_s + \lambda_p$$

**Where :**

- $k_2$  = AC / DC resistance ratio of conductor
- $\lambda_s$  = skin effect factor
- $\lambda_p$  = proximity effect factor

**The skin effect factor is given by :**

$$\lambda_s = \frac{X^4}{192 + 0.8X^4}$$

**Where :**

$$X = \sqrt{\frac{8\pi f}{R_0 k_1 \times 10^4}}$$

$f$  = supply frequency, Hz

$R_0$  = DC resistance of conductor at 20°C Ω/km

$k_1$  = reciprocal factor of temperature correction factor

**The proximity effect factor is given by :** โทร : 02 550 9555

$$\lambda_p = \frac{X'}{192 + 0.8X'^4} \left( \frac{d_1}{S} \right)^2 \left\{ 0.312 \left( \frac{d_1}{S} \right)^2 + \frac{1.18}{\frac{X'^4}{192 + 0.8X'^4} + 0.27} \right\}$$

**Where :**

$$X' = \sqrt{0.8X}$$

$d_1$  = diameter of conductor, mm

$S$  = distance between conductor axes, mm

Kind	Symbol	Conductivity (% iacs)	Density (g/cm <sup>3</sup> )
Silver	Ag	108.6	10.50
Standard Copper (Annealed)	Cu	100.0	8.89
Gold	Au	72.5	19.30
Aluminium	Al	61.0	2.70
Iron	Fe	13.0	7.78
Tin	Sn	12.2	7.29
Steel	-	11.6	7.78

## CONDUCTOR MATERIALS

Material	Specific Resistance, 20 °C			Temperature coefficient 20 °C	Mass g per cu.cm.
	Micro Ohms per cm. cube	Micro Ohms per in. cube	Ohms - per cir. mil - ft.		
Annealed copper	1.724	0.6788	10.37	0.00393	8.89
Hard-drawn copper	1.79	0.695	10.77	0.00378	8.89
Annealed aluminium	2.82	1.113	17.0	0.0039	2.7
Hard-drawn aluminium	2.92	1.15	17.5	0.0038	2.7
Pure iron	10.0	3.93	60	0.006	7.86
Steel wire	10.7 - 17.5	4.2 - 6.9	64 - 106	0.006-0.00036	7.78
Cast iron	75 - 100	29.5 - 39.4	450 - 600	0.001-0.00074	7.32

Reagent	Relative Rating						Reagent	Relative Rating						
	BR	CR	EPR	PVC	PE	XLPE		BR	CR	EPR	PVC	PE	XLPE	NYLON
Acetone	◎ ◎	○ ○	○ ○	○ X	○ ○	○ ○	○	Chlorine Gas	△	△	○ X	○ X	○ X	○ ○
Aniline	○ ○	○ X	○ ○	○ ○	○ ○	○ ○	Ozone	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○	X X
Ethanol	○ ○	○ ○	○ ○	△	○ ○	○ ○	Bromine	✗	✗	✗	✗	✗	✗	○ ○
Ethyleneglycol	○ ○	○ ○	○ ○	△	○ ○	○ ○	Nitric Acid, conc.	✗	✗	✗	✗	△	△	X X
Xylene	✗	✗	✗	✗	○ ○	○ ○	Nitric Acid, 10%	✗	✗	△	○ ○	○ ○	○ ○	△
Glycerin	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○	Fuming Nitric Acid	✗	✗	✗	✗	○ ○	○ ○	X X
Cresol	○ ○	△	○ ○	△	○ ○	○ ○	Tap Water	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○
Chloroform	✗	✗	✗	✗	△	△	Sea Water	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○
Acetic Acid, conc.	○ ○	△	○ ○	✗	○ ○	○ ○	Sulfuric Acid, conc.	✗	✗	✗	△	△	△	X X
Acetic Acid, 10%	○ ○	✗	○ ○	△	○ ○	○ ○	Sulfuric Acid, 10%	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○
Ethyl Acetate	○ ○	✗	△	✗	○ ○	○ ○	Phosphoric Acid	○ ○	△	○ ○	○ ○	○ ○	○ ○	○ ○
Carbon Tetrachloride	✗	✗	✗	✗	✗	✗	Sodium Hydroxide, 10%	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○
Cyclohexane	△	✗	✗	✗	△	△	Freon	✗	✗	○ ○	○ ○	○ ○	○ ○	○ ○
Diethyl Phthalate	○ ○	✗	✗	✗	✗	✗	Formic Acid	△	✗	○ ○	○ ○	○ ○	○ ○	○ ○
Trichloroethylene	✗	✗	✗	△	△	△	JIS No.1 Oil (OF Oil)	✗	△	✗	△	○ ○	○ ○	○ ○
Trichlorobenzene	✗	✗	✗	△	△	△	ASTM No.1 Oil	○ ○	△	△	○ ○	○ ○	○ ○	○ ○
Toluene	✗	✗	✗	✗	△	△	ASTM No.2 Oil	△	○ ○	△	△	○ ○	○ ○	○ ○
Carbon Disulfide	✗	✗	✗	△	○ ○	○ ○	ASTM No.3 Oil	✗	△	✗	△	△	△	△
Phenol	○ ○	△	○ ○	✗	○ ○	○ ○	Gasoline	✗	△	✗	✗	○ ○	○ ○	○ ○
Furfural	○ ○	○ ○	○ ○	△	○ ○	○ ○	Creosote Oil	△	✗	✗	✗	△	△	△
Hexane	✗	△	✗	△	○ ○	○ ○	JIS No.2 Oil	✗	✗	✗	△	○ ○	○ ○	○ ○
Benzene	✗	✗	✗	✗	△	△	Heavy Oil	✗	✗	✗	△	△	△	○ ○
Methanol	○ ○	○ ○	○ ○	✗	○ ○	○ ○	Lube Oil	✗	△	△	△	△	△	△
Methyl Ethyl Ketone	△	✗	△	✗	○ ○	○ ○	Silicone Oil	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○
Dioxane	○ ○	○ ○	○ ○	✗	○ ○	○ ○	Vegetable Oil	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○
Nitrobenzene	○ ○	✗	○ ○	✗	○ ○	○ ○	Petroleum Ether	△	△	✗	○ ○	○ ○	○ ○	○ ○
Formaline	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○	Trans Oil	✗	△	✗	○ ○	○ ○	○ ○	○ ○
Ammonia, conc.	○ ○	○ ○	○ ○	△	○ ○	○ ○	Naphtha	✗	✗	✗	○ ○	○ ○	○ ○	○ ○
Ammonia, 10%	○ ○	△	○ ○	○ ○	○ ○	○ ○	Coal Tar				○ ○	○ ○	○ ○	○ ○
Sodium Chloride	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○								
Hydrochloric Acid, Conc.	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○								
Hydrochloric Acid, 10%	○ ○	○ ○	○ ○	○ ○	○ ○	○ ○								

Where :

◎ : High Resistance

✗ : Not Applicable

○ : Fair Resistance

△ : Poor Resistance, care on use



**CHAROONG THAI WIRE & CABLE PUBLIC COMPANY LIMITED**

# PROPERTIES OF INSULATION AND SHEATH MATERIALS

## GENERAL COMPARISON DATA


Material	Polyvinyl Chloride	Low Density Polyethylene	Cross-linked Polyethylene	Polyisoprene	Styrene Butadiene Copolymer	Polychloroprene	Chlorosulphonated Polyethylene
Designation	PVC	PE	XLPE	NR	SBR	CR	CSM
Chemical structure	$-\text{CH}_2\text{CH}(\text{Cl})\text{CH}_2-$	$-\text{CH}_2\text{CH}_2\text{CH}_2-$	$\sim \text{CH}_2-\text{CH}-\text{CH}_2-$ $\sim \text{CH}_2-\text{CH}-\text{CH}_2-$	$\text{CH}_3$ $-\text{CH}_2-\text{C}=\text{CH}-$ $\text{CH}_2\text{CH}_2-$	$\text{CH}_2-\text{CH}=\text{CH}_2$ $-\text{CH}_2-\text{CH}-\text{CH}_2-$ $\text{C}_6\text{H}_5$	$\text{C}_1$ $-\text{CH}_2\text{CH}_2\text{x}-\text{CH}_2\text{y}-$ $-\text{CH}_2\text{CH}_2\text{x}-\text{CH}_2\text{y}-$ $\text{CH}_2\text{CH}_2\text{n}$	$\text{Cl}$ $-\text{CH}_2\text{CH}_2\text{x}-\text{CH}_2\text{y}-$ $-\text{CH}_2\text{CH}_2\text{x}-\text{CH}_2\text{y}-$ $\text{SO}_2\text{Cl}$
Density Hardness (Shore)	1.3-1.5 D30-90	0.91-0.93 D45-60	0.91-0.93	0.93-0.94 30-90	0.93-0.94 10-95	0.93-0.94 20-90	1.15-1.23 50-90
Max. Operating Temp. Emergency Temp. Rating Short Circuit Temp. Rating Brittleness Temp. Softening Temp.	60 85 120 ~40 120-140	75 90 150 <70 100-115	90 130 250 <70	60 85 150 -55-58	75 -30-65	80 -30-50	90 -20-50
Thermal Expansion Thermal Conductivity Cal/cm <sup>2</sup> sec °C Specific Heat	/°C 3.0-4.0x10 <sup>-4</sup> 0.3-0.5	0.7-2.5x10 <sup>-4</sup> 8.0x10 <sup>-4</sup> 0.55	1.6-1.8x10 <sup>-4</sup> 8.0x10 <sup>-4</sup> 0.55	1.6-1.8x10 <sup>4</sup> 8.0x10 <sup>-4</sup> 0.55	1.8x10 <sup>-4</sup> 5.1x10 <sup>-4</sup> 0.52	1.8x10 <sup>-4</sup> 5.8x10 <sup>-4</sup> -	1.8x10 <sup>-4</sup> 5.6x10 <sup>-4</sup> 0.52
Tensile Strength Elongation Abrasion Resistance	kg/mm <sup>2</sup> % Excellent	1.5-2.5 200-400 Good	1.5-2.0 300-700 Good	1.8-3.0 300-700 Excellent	0.8-3.0 300-700 Good	0.4-3.0 100-700 Good	0.7-3.0 400-900 Good
Voltage Breakdown Volume Resistivity Dielectric Constant Dissipation Factor (tanδ)	Ω kV/mm *cm	20-30 10 <sup>12</sup> -10 <sup>15</sup>	30-50 >10 <sup>16</sup>	16-32 2.2-2.4 <0.0005	16-32 10 <sup>15</sup> 3-5 0.3-0.5	16-30 10 <sup>-4</sup> -10 <sup>15</sup> 3-5 2-5	15-25 10 <sup>10</sup> -10 <sup>12</sup> 7-10 1.7-4
Weathering Ozone Resistance Flame Resistance Track Resistance Water Resistance Acid Resistance Alカリ Resistance Oil Resistance Solvent Resistance	Good Excellent Self-Extinguish Inferior Fair Excellent Excellent Good Excellent	Poor Excellent Burns Excellent Excellent Good Excellent Excellent Good	Inferior* Excellent Burns Excellent Excellent Good Good Good Good	Poor Poor Burn Fair Fair Fair Good Good Good	Poor Good Self-Extinguish Inferior Fair Fair Good Good Good	Poor Good Self-Extinguish Inferior Fair Fair Good Good Good	Good Good Self-Extinguish Good Good Fair Good Excellent Excellent Good Good Fair

Improved to “good” with mixture of carbon black.


**PROPERTIES OF INSULATION AND SHEATH MATERIALS**  
GENERAL COMPARISON DATA (Continued)


Material	Ethylene Propylene Copolymer	Hexafluoropropylene Vinylidenefluoride Copolymer	Polyorganosiloxane	Polypropylene	Polytetra Fluoroethylene	Polychloro Trifluoroethylene	Polyamide
Designation	EPM, EPDM	FPM	PP	PTFE	PCTFE	Nylon(12)	
Chemical Structure	$\left[-\text{CH}_2-\text{CH}_{2x}\right]_n$ $\left[-\text{CH}-\text{CH}_{2y}\right]_n$	$\left[-\text{C}(\text{F})_3-\text{C}(\text{F})_x-(\text{CH}_2-\text{C}(\text{F})_y)_z\right]_n$	$\left(-\text{CH}_2-\text{CH}\right)_n$ $\text{CH}_3$	$\left(-\text{CH}_2-\text{CH}\right)_n$ $\text{CH}_3$	$\left(-\text{C}(\text{F})_3-\text{C}(\text{F})_z\right)_n$	$\left(-\text{HN}(\text{CH}_2)_{11}\text{C}(\text{F})_6\right)_n$	$\left(-\text{HN}(\text{CH}_2)_{11}\text{C}(\text{F})_6\right)_n$
Density	0.86-0.87 40-85	1.82-1.85 60-90	0.97-1.40 50-85	0.9-0.915 R85-110	2.13-2.2 D50-65	2.1 R110-115	-1.01-1.02 R100-110
Max. Operating Temp.	90	200	180	80	260	180	90
Emergency Temp. Rating	0°C						
Short Circuit Temp. Rating	0°C						
Brittleness Temp.	0°C	-40-60	-44-60	150	310	<-70	120
Softening Temp.	0°C			-70--100	<-70	210	-70
Thermal Expansion	/°C						
Thermal Conductivity	Cal/cm²sec °C						
Specific Heat	Cal/°C·g						
Tensile Strength	kg/mm²	0.5-1.5	1.5-2.5	2.6x10⁻⁴	6.0-8.5x10⁻⁵	4.5-7.0x10⁻⁵	12x10⁻⁵
Elongation	%	300-700	200-600	5.7x10⁻⁴	2.8x10⁻⁴	6x10⁻⁴	5.9-8.3x10⁻⁴
Abrasion Resistance	Good	Good	Fair	0.46	0.25	0.22	0.62
Voltage Breakdown	kV/mm	20-35	24	20-40	1.4-2.1	2.8-3.5	5.0-6.0
Volume Resistivity	Ω·cm	$10^{14}-10^{15}$	$10^{12}-10^{14}$	$10^{14}-10^{15}$	200-700	10-100	180-285
Dielectric Constant	3-5	6-7	3-4	2.0-2.2	200	Excellent	Excellent
Dissipation Factor ( $\tan\delta$ )	0.2-0.8	0.1-1.0	0.0002-0.0006	<0.0002			
Weathering	Excellent	Good	Good	Good	Inferior*	Excellent	Inferior*
Ozone Resistance	Excellent	Good	Self-Extinguish	Excellent	Excellent	Excellent	Good
Flame Resistance	Burn	Fair	Burn	Burn	No Burn	No Burn	Burn
Track Resistance	Excellent	Excellent	Excellent	Excellent	Excellent	Excellent	Good
Water Resistance	Good	Excellent	Excellent	Excellent	Excellent	Excellent	Excellent
Acid Resistance	Excellent	Excellent	Excellent	Excellent	Excellent	Excellent	Good
Alkali Resistance	Excellent	Excellent	Excellent	Excellent	Excellent	Excellent	Excellent
Oil Resistance	Inferior*	Excellent	Excellent	Excellent	Excellent	Excellent	Excellent
Solvent Resistance	Poor	Fair	Fair	Fair	Fair	Fair	Good

\*Improved to "good" with mixture of carbon black.




### Operating Temperature






บริษัท ชัย อะล็อกทริค จำกัด  
 CT ELECTRIC SUPPLY CO., LTD.

โทร : 02 550 9555




% Retention Critical Tensile Strength



บริษัท ซีที อิเลคทริค ซัพพลาย จำกัด  
CT ELECTRIC SUPPLY CO., LTD.

% Retention Critical Elongation




โทร : 02 550 9555



**CTW**

# **ISO 9001**

To be confident  
in our international standard





# CHAROONG THAI WIRE & CABLE PUBLIC COMPANY LIMITED

บริษัท จรุงไทยไวร์แอนด์เคเบิล จำกัด (มหาชน)

## **Head Office : Executive & Sales Office**

Floor 12A. Central City Tower, 589/71 Bangna-Trad Road.

Km.3 Bangna, Bangna District, Bangkok 10260, Thailand

Website : <http://www.ctw.co.th>

Email : [sales@ctw.co.th](mailto:sales@ctw.co.th)

Tel. : 66-2-745-6118-30

Fax : 66-2-745-6131-32

## **Head Office : Executive & Sales Office**

35/1 Moo 22 Suwinthawong Road. Km.63 Suwinthawong

Bangnamprieo District, Chachoengsao 24000, Thailand

Tel. : 66-38-593401-10

Fax : 66-38-593400

CT ELECTRIC SUPPLY CO., LTD.

โทร : 02 550 9555