

## CLASS 150 CAST STAINLESS STEEL SWING CHECK VALVE FLANGED ENDS

KITZ Fig: 150UOAMT

Sizes: 11/2-14inch(40-350mm)

Standards

- End to End: ASME B16.10 CLASS 150
  - End Connection: ASME B16.5 CLASS 150
  - Wall Thickness: ASME B16.34 CLASS 150
- Test Standard
- API 598

Dimensions


SIZE (inch/mm)	L	L1	H	D1	Kg
11/2 40	165.0	0.0	109.0	0.0	0.00
2 50	203.0	0.0	119.0	0.0	0.00
2 1/2 65	216.0	0.0	134.0	0.0	0.00
3 80	241.0	0.0	146.0	0.0	0.00
4 100	292.0	0.0	164.0	0.0	0.00
5 125	330.0	0.0	192.0	0.0	0.00
6 150	356.0	0.0	214.0	0.0	0.00
8 200	495.0	0.0	264.0	0.0	0.00
10 250	622.0	0.0	286.0	0.0	0.00
12 300	698.0	0.0	315.0	0.0	0.00
14 350	787.0	0.0	363.0	0.0	0.00

Material List

NAME OF PART	MATERIAL	SPECIFICATION
BODY	STAINLESS STEEL	A351 Gr. CF8M/SCS14A
COVER	STAINLESS STEEL	A351 Gr. CF8M/SCS14A
DISC	STAINLESS STEEL	A351 Gr. CF8M/SCS14A

Specifications

CLASS 150 CAST STAINLESS STEEL SWING CHECK VALVE FLANGED ENDS  
 End to End : ASME B16.10 CLASS 150, End Connection : ASME B16.5  
 CLASS 150, Wall Thickness : ASME B16.34 CLASS 150, Test Standard :  
 API 598, Sizes : 11/2-14inch(40-350mm), BODY MATERIAL : STAINLESS  
 STEEL, COVER MATERIAL : STAINLESS STEEL, DISC MATERIAL : STAINLESS  
 STEEL, KITZ Fig : 150UOAMT



For more details, please refer to the drawing.

Pressure-temperature ratings and other performance data published in this catalog have been developed from our design calculation, in-house testing, field reports provided by our customers and/or published official standards or specifications. They are good only to cover typical applications as a general guideline to users of KITZ products introduced in this catalog. For any specific application, users are kindly requested to contact KITZ Corporation for technical advice, or to carry out their own study and evaluation for proving suitability of these products to such an application. Failure to follow this request could result in property damage and/or personal injury, for which we shall not be liable. Read instruction manual carefully before use.

# KITZ

KITZ CORPORATION Tokyo Shiodome Building, 1-9-1, Higashi-Shimbashi, Minato-ku, Tokyo 105-7305, Japan  
 © KITZ Corporation. All Right Reserved.

ISO 9001  
 CERTIFIED  
 Since 1989