

## TYPE 400 DUCTILE IRON BALL VALVE SCREWED ENDS

KITZ Fig: STZ

Sizes: 1/4-2inch(8-50mm)

REDUCED BORE

Standards

- . End to End: KITZ STANDARD
  - . End Connection: JIS B0203
  - . Wall Thickness: KITZ STANDARD
- Test Standard
- . KITZ STANDARD

Dimensions

SIZE (inch/mm)	L	L1	H	D1	Kg
1/4 8	46.0	24.5	37.0	80.0	0.00
3/8 10	51.0	27.5	37.0	80.0	0.00
1/2 15	57.0	28.5	41.0	100.0	0.00
3/4 20	65.0	32.5	46.0	130.0	0.00
1 25	76.0	38.0	49.0	130.0	0.00
1 1/4 32	86.0	43.5	56.0	130.0	0.00
1 1/2 40	95.0	47.5	61.0	130.0	0.00
2 50	115.0	57.5	68.0	150.0	0.00


Material List

NAME OF PART	MATERIAL	SPECIFICATION
BODY	DUCTILE IRON	FCD-S
BODY CAP	DUCTILE IRON	FCD-S
STEM	BRASS	C3531
BALL	FORGED BRASS	C3771

Specifications

TYPE 400 DUCTILE IRON BALL VALVE SCREWED ENDS, REDUCED BORE

End to End : KITZ STANDARD, End Connection : JIS B0203, Wall Thickness : KITZ STANDARD, Test Standard : KITZ STANDARD, Sizes : 1/4-2inch(8-50mm), BODY MATERIAL : DUCTILE IRON, BODY CAP MATERIAL : DUCTILE IRON, STEM MATERIAL : BRASS, BALL MATERIAL : FORGED BRASS, KITZ Fig : STZ



For more details, please refer to the drawing.

Pressure-temperature ratings and other performance data published in this catalog have been developed from our design calculation, in-house testing, field reports provided by our customers and/or published official standards or specifications. They are good only to cover typical applications as a general guideline to users of KITZ products introduced in this catalog. For any specific application, users are kindly requested to contact KITZ Corporation for technical advice, or to carry out their own study and evaluation for proving suitability of these products to such an application. Failure to follow this request could result in property damage and/or personal injury, for which we shall not be liable. Read instruction manual carefully before use.

# KITZ

KITZ CORPORATION Tokyo Shiodome Building, 1-9-1, Higashi-Shimbashi, Minato-ku, Tokyo 105-7305, Japan  
© KITZ Corporation. All Right Reserved.

ISO 9001  
CERTIFIED  
Since 1989