

WELLIS WADU-02 Test
inside ICU of Guangzhou end
General hospital (600M²/ 1800 M³)

December, 2019

GUANG ZHOU INSTITUTE OF MICROBIOLOGY
TEST REPORT

Date Received: Dec. 01, 2019
Date Analyzed: Dec. 03, 2019

6. Test results

Test time (h)	Sampling location	Original Bacteria Count	Bacteria Count after Treatment	Death rate
		V_0 (cfu/m ³)	V_t (cfu/m ³)	K_t (%)
24	Sample point 1	2.56×10^2	80	68.75
	Sample point 2	1.44×10^2	40	72.22
	Sample point 3	2.08×10^2	48	76.92
	Sample point 4	2.88×10^2	64	77.78
	Sample point 5	2.24×10^2	64	71.43
	Sample point 6	2.16×10^2	64	70.37
	Sample point 7	2.56×10^2	56	78.13
	Sample point 8	2.40×10^2	56	76.67



