



TEST REPORT

Sample's name

PP-R Pipe

Mark / Brand

Trachang

Laboratory No.

L56/00803.1

Test Results

Effect on water, mg/dm³

Toxic Substance

Aluminium (Al)	not detected
Antimony (Sb)	not detected
Arsenic (As)	not detected
Barium (Ba)	not detected
Cadmium (Cd)	not detected
Chromium (Cr)	not detected
Iron (Fe)	not detected
Lead (Pb)	not detected
Manganese (Mn)	not detected
Mercury (Hg)	not detected
Nickel (Ni)	not detected
Selenium (Se)	not detected
Silver (Ag)	not detected

Customer's name Nawaplastic Industries (Saraburi) Co.,Ltd.

Customer's address 42 Moo 8, SIL Industrial Land, Nong Pling, Nong Kae, Saraburi 18140.

Sample's description Green rectangular test pieces with length, width and thickness of approximately 85 mm, 70 mm and 11 mm, respectively.

Test date 4 February - 14 March 2013

Test method BS 6920: Section 2.6: 1990

Approved by

(Mr. Apinun Ubpakarakun)

Scientist, Senior Professional Level

Reported by

(Mr. Songpon Radispong)

Scientist, Professional Level

This report is only valid for the sample received. The above statement is not intended for advertising purposes and shall not be reproduced or shall not manifest partially without the written permission of the Department of Science Service.

Department of Science Service, Ministry of Science and Technology

Rama VI Road, Ratchathewi, Bangkok 10400, Thailand